
Controller for Electro-Pneumatic Regulator


Series IC

Converts digital input signal into analog output signal




10 bit parallel input signal (maximum)

Pressure can be set with 2¹⁰ = 1024 steps.




4 point preset output pressure





4 point pressure switch function Switch output is enabled by setting the upper and lower limits of pressure.



Power voltage and output signals

Output power voltage and output signal to the electro-pneumatic regulator can be set with keys on the front panel.

16	guiatoi	can be set t	vitii keys on	tile mont b	Janei.			
	Power supply voltage	Output signal		Controller	Power supply	Electro-pneumatic regulator	No need of power supply for ITV	
1	12 VDC	4 to 20 mA DC		©SAC CONTROLLER OUT PASSURE	voltage		Power supply for	
2	12 VDC	0 to 10 VDC	Power supply for controller		C Fower supply for controller			electro-pneumatic
3	24 VDC	4 to 20 mA DC		SW 1 2 3 4			regulator	
4	24 VDC	0 to 10 VDC		UP 700 7550 5100 0000	Output signal	Series ITV		
				Series IC				

This product is mainly used in combination with Series ITV0000 without a display function.

ARJ AR425 to 935

ARX

ARM

ARP IR

IRV

VEX SRH

SRP

SRF

ITV

IC ITVX

PVQ VEF VEP

VER VEA


VY1

VBA VBAT

AP100

Controller for Electro-Pneumatic Regulator **Series IC**

How to Order




Option

When only optional parts are required, order using the part numbers listed below.

Description	Part no.	Note
Panel mount adapter set	P398050-1	Gasket, Screw 2 pcs.
Display protective cover	P2992136	-





Specifications

Model

	Model	IC1□	IC3□	IC5□	IC9□	
Pressure rang	ge	0.1 MPa	0.5 MPa	0.9 MPa	-0.1 MPa	7
Proof pressur	re	500 kPa	1.5 !	MРа	500 kPa	
Fluid		Air/Non-corrosive gas				ARJ
Dimensions		48 x 48 x 100.5				Anj
Power supply		12 to 24 VDC (15 W or more), Ripple (p-p) 1% or less				AR425
		(1)No. of inputs: Up to 10 bit input from sequencer (parallel) Note 5)) Note 5)	to 935
		Input method: No-voltage contact or NPN open collector input				ARX
Input		Minimum pulse width: 50 msec			Ana	
		②Input method: 4 point input with keys				AMR
		(Interval time can be set by programming.)				VIAIL
Power supply	, output	12 V	DC (Max. 300 mA) with acc	curacy of 12 to 14.4 VDC	Vote 2)	ARM
rower suppry	Catput	24	VDC (Max. 300 mA) with a	accuracy of 22.0 to 26.8 V	C	AITIN
Command ou	stout	①0 to 10 Vc (0	Output resistance: 6.5 kΩ or	more with accuracy of 0.5	5%F.S. or less)	ARP
Command ou	при	②4 to 20 mA [OC (Output resistance: 800	Ω or less with accuracy of	0.5%F.S. or less)	ANP
			Output: 4 points			IR
			Output type: NPN, PNP op	en collector output		
Switch outpu	+		Withstand voltage: Max. 30	V		IRV
Ownton Gutpu	•	Current: Max. 100 mA				1110
		Internal voltage drop: 1 V or less				VEX
		Switching between N.O. and N.C. modes is possible.				VLA
Switch response		5 to 640 ms			− SRH	
Display		Power indication: 3 1/2-digit LED indicator (red)				
		Output power supply voltage and current signal indication: 1-digit LED indicator (red)			D indicator (red)	SRP
		LED lights for RUN, CH, SW (red and green)				
Display accu		±0.5%F.S.±1dig (at 25°C) Approx. 4 times/s ±0.12%F.S./°C Displayed on pressure indication LED			─ SRF	
Display samp						_ 🚞
	characteristics				VCHR	
Error indicati						
Operating temperature range			0 to 5			ITV
	Storage temperature range	−20 to 60°C				
Resistance	Operating humidity range	0 to 85%R.H.				
	Vibration resistance	10 to 55 Hz 1.5 mm amplitude X, Y, Z directions for 2 hrs. each				
	Impact resistance	100 m/s² (approx. 10 G) X, Y, Z direction				— ∣ITVX
Water resistance		Only display unit with cover is equivalent to IP65. It is equivalent IP40 without cover.				
Sensor type		Built-in sensor type, External sensor type Note 3)				− PVQ
Set value retention		10 years when deenergized (EEPROM)				- WEE
Port size Material			M5 female (built	-in sensor type)		VEF VEP
		Enclosure: POM				
		Display: PC			VER	
		Gasket: NBR				
		Panel mount adapter: POM			VEA	
		Display protective cover: PC Approx. 330 q (Built-in sensor type)			$\dashv \vdash =$	
Weight				* * *		VY1
			Approx. 345 g (Ex	ternal sensor type)		

Note 1) The display accuracy is the accuracy of the LED indication when the sensor port of the built-in sensor type is pressurized.

Note 2) The external sensor type has the same output power supply voltage specifications.

Note 3) The sensor for the external sensor type is not attached and must be ordered separately.

Any pressure sensor that transmits analog output signals can be connected.

Recommended sensor: Series PSE530 (For more information, please refer to Best Pneumatics No. 6.)

Note 4) Button operation is required when turning the power on again. However, the made-to-order specification (-X2) automatically returns to the pre-shutdown state when power is switched on again.

Note 5) For the ITV1000 to 3000 series, a 10-bit input (parallel) through a sequencer is available for -X93, -X157 (CE-compliant).



VBA

VBAT


AP100

Series IC

Functions


■ 4 point preset output

- · Four points (CH1 to CH4) of pressure and switch output ranges can be set with the front panel keys.
- · Up to 20 steps of programming is possible.
- · Interval time (1 to 999 sec) can be set by programming.
- · The set pressures can be arranged in a random order.




■ 10 bit parallel input

- · Up to 10 bits of parallel input is possible from PLC.
- · Pressure can be set with 210 = 1024 steps.



■ Pressure switch function (4 point)

Switch output is enabled by setting the upper and lower limits.



Power supply voltage and output signal switch function

- Output power supply voltage and output signal to the electro-pneumatic regulator can be selected with the front panel keys.
- \cdot No need of power supply for the electro-pneumatic regulator.
- · Stable power supply is possible.

	Power supply voltage	Output signal
1	12 VDC	4 to 20 mA DC
2	12 VDC	0 to 10 VDC
3	24 VDC	4 to 20 mA DC
4	24 VDC	0 to 10 VDC

Set pressure correction function (only for 4 point preset input)

Either automatic or manual adjustment is possible in pressure adjustment mode.

<Automatic adjustment mode>

The controller automatically calculates the deviation and converts the correction value into the output signal. The deviation converges within the range of $\pm 0.5\% F.S.$

Note) If the set pressure is 250 kPa and the output pressure on the pressure sensor is 245 kPa, the deviation is 250-245=5 kPa. In order to correct the deviation, the controller increases the output signal until the pressure on the pressure sensor converges at 250 kPa.

<Manual adjustment mode>

The deviation is corrected manually (with keys).

■ Zero span correction function

Deviation of the zero span point of the sensor can be corrected.

■ Keypad lock function

To prevent erroneous operation, operation on the key can be disabled. Keys which cannot be locked:



■ Reset function

The data is reset to the initial condition at the time of shipment.

Anti-chattering function

Large bore cylinders and ejectors consume a large volume of air in operation and occasionally experience temporary drops in supply pressure. This function prevents detection of such momentary supply pressure drops. It regards them as abnormalities and changes the response time settings. Possible response time settings: 5 ms, 20 ms, 160 ms, 640 ms

<Principle>


The controller equalizes the pressures measured during the specified response time. It then compares the equalized pressure and the set pressure to output switch signals accordingly.

■ Error display

Error nam	ne	Error indication	Description
	SW1	Er 1	
Overcurrent	SW2	ErZ	Excess current is running through
error	SW3	E - 3	switch.
	SW4	Ery	
Switch range e	error	Er5	Lower limit of switch output exceeds upper limit.
Pressurization	error		Pressure exceeding upper limit of set pressure is applied.




Descriptions



No.	Description
1	OUT display Displays output specification to electro-pneumatic regulator.
2	RUN display Displays control status.
3	CH channel (display) (for 4 point input) Of CH1 to CH4 for pressure selection, channel with output ON lights up.
4	SW (switch) output display Displays output type and output status of SW1 to 4.
(5)	UP button Used to change mode and set value.
6	SET/RUN button Used to confirm mode and set value, or to change to control ON state.
7	D-IN/READ button Used to select mode and turn on or off power supply to electro-pneumatic regulator.
8	P-ON/STOP button Used to turn on or off main power supply, escape from mode, or change to stand-by state.
9	DOWN button Used to change mode and set value.
10	Pressure display Displays measured value, settings, and error code.


Breathing port (M3 x 0.5 x 9.5) Sensor pressure port (M5 x 0.8 x 7)



)	No.	Description	Note
	1	Power supply, 10 bit input cable	13 wire, O.D. 6.8 mm, 1 m length
	2	Cable for 4 point switch output	5 wire, O.D. 6 mm, 1 m length
	3	Pneumatic regulator connection cable	Quire QD Q4 mm 4 m length
	4	Cable for external sensor	3 wire, O.D. 3.4 mm, 1 m length


Note 1) Keep the bending radius of the cable greater than 50 mm. Note 2) Since the electro-pneumatic regulator connection cable 3 and the cable for external sensor 4 are identical in shape, take precautions against erroneous connection.

Internal Circuit and Connection



For the setting procedure and detailed cable connection specifications, please refer to the instruction manual.

Note 1) If the power supply for loads and main power supply are provided by a common source, the power supply (GND) can be used for SW-DC (GND).



Note 1) Connection to the pressure sensor is required only when using the external sensor type.



AR425 to 935 ARX

ARJ

AMR

ARM ARP

IR

IRV VEX

SRH

SRP

SRF

VCHR ITV

IC

ITVX

PVQ

VEF VEP

VER

VEA VY1


VBA VBAT

AP100


859

Series IC

Dimensions



Option





Series IC Specific Product Precautions

Be sure to read before handling. Refer to front matter 43 for Safety Precautions.

■ Controller for Electro-pneumatic Regulator

Handling

△Warning

- Do not drop, bump, or apply excessive impacts (980 m/s²) while handling. Although the body of the sensor may not be damaged, the inside of the sensor could be damaged and lead to a malfunction.
- The tensile strength of the cord is 20 N. Applying a greater pulling force on it can cause a malfunction.
 When handling, hold the body of the sensor – do not dangle it from the cord.
- Do not exceed the tightening torque of 3.5 N·m when installing piping. Exceeding this value may cause malfunctioning of the sensor.
- 4. The minimum bending radius of the cable is 50 mm.
- 5. Do not use pressure sensors with corrosive and/or inflammable gases or liquids.

Operating Environment

Δ Warning

 This controller for electro-pneumatic regulator is not rated as explosion proof.

Never use it in an atmosphere of corrosive or explosive gas.

△Caution

 Only the display unit of the controller for electropneumatic pressure regulator has an enclosure equivalent to IP65 rating.

Connection


∆Caution

- Incorrect wiring can damage the switch and cause a malfunction or erroneous switch output. Connections should be done while the power is turned off.
- Do not attempt to insert or pull the pressure sensor or its connector when the power is on. Switch output may malfunction.
- Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- 4. If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.

Mounting

⚠ Caution

1. Mounting with panel mount adapter



Tighten screws by 1/4 to 1/2 turn after the heads are flush with the panel.

ARJ

AR425 to 935

AMR

ARM

IR

IRV VEX

SRH

SRP

SRF

VCHR

IC ITVX

PVQ

VEP

VEA VY1

VBA VBAT