Compact 5-Port Solenoid Valve

JSY1000/3000/5000 Series

Plug-in


Size reduction has been made possible thanks to a flow increase.






This allows for space saving weight reduction and a large flow rate


*2 The cylinder speed is 300 mm/s.




Refer to pages 30 to 33 for detailed conditions regarding the above cylinder speeds










Power consumption

With powersaving circuit JSY3000/5000 O_1 W JSY1000 **0.2** W

Standard


JSY3000/5000 *2 O_4 w

*2 The JSY1000 series is only available as the power-saving type.




A 4-position dual 3-port valve is available.

• Features two 3-port valves built into one body



- The 3-port valves on the A and B sides can be operated independently.
- . When used as a 3-port valve, only half the number of stations are required.
- Can also be used as a 4-position, 5-port valve
 - Can also be used as a 4-position, 5-port valve
 Combination examples

Series	A side	B side
JSY□A0□	N.C. valve	N.C. valve
JSY□B0□	N.O. valve	N.O. valve
JSY□C0□	N.C. valve	N.O. valve



Compatible with wireless systems 584

■ Noise resistance

- Uses the 2.4 GHz ISM frequency band
- Frequency hopping: Every 2 ms/5 ms

Communication cables not required

- · Reduced wiring work, space, and cost
- Minimized disconnection risk

■ High-speed connection

- · From the remote power supply ON to start of communication:
 - Min. 250 ms

Number of I/O points

 Max. 128 inputs/128 outputs per module (EX600-W Series)

■ Communication response

 Wireless communication signal Response time: 2 ms/5 ms

Application Examples


For tool changing



For spot welding



For rotary tables



The EX260 series supports safety communication.

■ This is a Fieldbus unit which supports safety standard ISO 13849-compliant safety circuit constructions.

The safety communication protocol is a communication protocol that transmits safety-related data by network communication and can be used up until safety standards ISO 13849-1 PL e and IEC 61508/IEC 62061 SIL 3.

Using the safety communication protocol

Refer to the EX260 Web Catalog for details on units that support the safety communication protocol.

When using a manifold valve within an ISO 13849-compliant safety system, the device needs to be considered from both the pneumatic circuit and the electric side.

Devices (including valves) need to be selected based on whether their functions are in line with the safety level of the equipment as a whole.

The use of valves that have been validated as being compliant with ISO 13849-2 may be required. For details on valves that have been validated, please contact SMC.


In addition, refer to "Safety Instructions" for precautions on model selection.





Ejector can be mounted on a compact-size JSY1000

The devices have been integrated into one for applications in which an actuator and vacuum suction are used together.



Application Examples

and complicated


Magnet gripper Vacuum pad. et

Metal workpiece with holes

Material handling

Small robot Air gripper + Vacuum pad, etc.

Pick and place



turned piping, be sure to turn plug the unused port.

Small box making process

Cartoner




Separate fieldbus-compatible manifold JSY1000-E types are available to built-in pressure sensor and enable energy-saving control of ejector.




Valve manifold integrated with ejector system **JSY1000-E**



Series Variations







	Wir	ring				Manifold	options	;				Va	lve optic	ns	
Ditab	Common sp	pecifications	ate	P.	¥	pacer ssure	ᅮ 왕	. ¥s	uch type)	cer	≱ ⊑	(0		Б	ø.
Pitch width [mm]	Positive common	Negative common	Blanking plate	Individual SUP spacer	Individual EXH spacer	SUP stop valve spacer with residual pressure release valve	SUP/EXH blocking disk	Label for blocking disk	Silencer (One-touch fitting connection type)	Built-in silencer	Vacuum/Low- pressure specification	Different pressures	Reverse pressure	Mixed fitting sizes	Enclosure IP67*1
6.5															
9	•	•	0	0	0	O p. 153-1	0	0	0	•	A	0	A	•	_
11.5			p. 153	p. 153	p. 153		p. 154	p. 154	p. 154		External pilot	Individual SUP	External pilot		•
16						_									•

*1 Refer to "Manifold Specifications" on pages 38 and 39 for details on IP67.

Manifold Options

SUP/EXH blocking disk

(For the connector type manifold, Type 10)

[SUP blocking disk]

Inserting an SUP blocking disk in the pressure supply passage of a manifold valve can allow for the use of 2 different pressures (high and low) in 1 manifold.

[EXH blocking disk]

Inserting an EXH blocking disk in the exhaust passage of a manifold valve can separate the exhaust from the valve so it does not affect the other valves. It can also be used in positive pressure and vacuum pressure mixed manifolds. (2 pieces are required to block both the EA and EB sides of the EXH.)




Labels for blocking disks

These labels can be used to indicate and confirm where on the manifold the SUP/EXH blocking disk assemblies were inserted. (3 labels of each)







Tube Releasing Tool This tool can be used to remove tubes from ports A and B. TG-0204 TG-0608 TG-1012 012



p. **154**

Vacuum Unit ZK2 Combination Manifold 6.140

JSY3000 valves and ZK2 ejectors can be connected to the same manifold.

This allows for a compact body and reduced wiring/wiring labor.

Fieldbus compatible

The centralized electrical wiring can be connected to the fieldbus system.

For Input/Output

DeviceNet®, PROFIBUS DP, CC-Link, EtherNet/IP™, EtherCAT®, PROFINET EX600

FX245

DeviceNet®. PROFIBUS DP, EtherNet/IP™

EX250 AS-Interface

For Output

EX260

DeviceNet®, PROFIBUS DP, CC-Link, EtherNet/IP™, EtherCAT, PROFINET Ethernet POWERLINK, IO-Link, PROFIsafe, CC-Link IE TSN, Safety over EtherCAT

EX120 DeviceNet®, CC-Link, CompoNet®

Various selectable wiring methods

D-sub connector

- · Compact type: FC type (IP20) · Connector entry direction
- adjustable: F type (IP40)
- FW type (IP67)

Terminal block box Lead wire

Connecting part

Spring type: TC type

T type

Valve Manifold JSY3000 Series

> **Ejector Manifold** ZK2 Series

Flat ribbon cable

• Compact type: PC/PGC/PHC type

Connector entry direction

adjustable: P/PG/PH type

Individual pressure supply

15×300 supply expansi

Integrated manifold

Centralized electrical wiring for

ejectors and valves (Reduced

wiring)

The individual pressure supply to the valve manifold (JSY3000) and ejector manifold (ZK2) prevents the reduction of vacuum pressure due to pressure interference.

Specifications

Max. number of outputs: 32 (Valve + Ejector) Valve stations: 2 to 24 stations (Max. number of outputs: 30, Depends on whether single or double) Ejector stations: 1 to 8 stations (Max. number of outputs: 16)

Centralized wiring and piping directions

Wiring and piping for valves and ejectors can be arranged in the same direction. (Wiring method: Terminal block box and lead wire or EX250 and EX260)



The supplies haust


CONTENTS

•	Size Chart of Air Cylinde	•	Plug-in Connect	or Connecting Ba	ise
•		•	Manifold Specific	ations ·····	p. 38
Response Time		p. 35	Manifold Weight		p. 38
Valve Weight ·····		p. 35	Manifold Flow Ra	te Characteristics	p. 38
Valve Construction		p. 36	ZK2 Combination	Manifold Weight	p. 39
Valve Replacement	Parts: Pilot Valve ·······	p. 37	Connector Wiring	Layout	p. 40
D-sub connector	Terminal block box	EX600		EX250	EX120
. 8					
Flat ribbo	n cable Lea	d wire	EX245	EX260	ZK2 combination manifold

How to Order p	. 40
How to Order p Dimensions	. 42
D-sub Connector (IP40/Connector Entry Direction Adjustable): F · · · · · p	. 11
D-sub Connector (IP67): FW	
D-sub Connector (IP20/Compact Type): FC p	
Flat Ribbon Cable	. 00
(IP40/Connector Entry Direction Adjustable): P/PG/PH p	. 53
Flat Ribbon Cable (IP20/Compact Type): PC/PGC/PHC	
Electrical Wiring Specifications: D-sub Connector Cable p	
Electrical Wiring Specifications: Flat Ribbon Cable Connector p	
Spring Type Terminal Block Box, Terminal Block Bo	
How to Order	
Dimensions	
Spring Type Terminal Block Box: TC p	. 66
Terminal Block Box: T p	. 70
Connection/Electrical Wiring Specifications p	. 74
Lead Wire	
How to Order p	. 76
Dimensions p	. 78
Electrical Wiring Specifications p	
EX600 Integrated Type (For Input/Output)	
Serial Transmission System	
How to Order p	. 84
Dimensions	. 86
EX245 Integrated Type (For Input/Output)	
Serial Transmission System	
How to Order p	. 94
Dimensions p	. 96
EX250 Integrated Type (For Input/Output)	
Serial Transmission System	
How to Order p	. 98
Dimensions p.	100
EX260 Integrated Type (For Output)	
Serial Transmission System	
How to Orderp.	
Dimensions p.	108
EX120 Integrated Type (For Output)	
Serial Transmission System	
	112
riow to Order	

Type 10/Side Ported: Common Dimensions	
(External Pilot, Built-in Silencer/Mixed Size, Straight Port Type)	-
Manifold Exploded View [By Wiring]	···· p. 122
D-sub Connector/Flat Ribbon Cable	
(IP40/Connector Entry Direction Adjustable)	···· p. 123
D-sub Connector (IP67)	···· p. 124
D-sub Connector/Flat Ribbon Cable (IP20/Compact Type)	
Spring Type Terminal Block Box	
Terminal Block Box	
Lead Wire ····	
EX600	
EX245	
EX250	
EX260	
EX120	
Manifold Exploded View [Common Parts]	···· p. 136
Type 10: How to Increase Connector Type Manifolds	···· p. 136
For the JJ5SY1-10, JJ5SY3-10, JJ5SY5-10/	
Manifold Parts Nos.	···· p. 137
Vacuum Unit ZK2 Combination Manifold	
How to Order	···· p. 140
Dimensions	···· p. 144
ZK2 Combination Manifold Exploded View	p. 147
For the JJ5SY3-10-M (ZZK2□A)	
Manifold Parts Nos.	p. 148
ZK2□A Vacuum Ejector Manifold Exploded Vie	w .
How to Increase Manifold Stations	···· p. 149
	•
One-touch Fittings, Plug, Clip, Port Plate,	
Tube Releasing Tool	
Manifold Options	
Made to Order	
Specific Product Precautions	···· p. 157

For JSY1000, A, B port: Ø4



^{*} Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.




^{*} Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.

^{*} The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.

^{*} Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%

^{*} Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.


For JSY1000, A, B port: Ø6



- * Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.
- * The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.
- * Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%
- * Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.
- * Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.



For JSY3000, A, B port: Ø8



^{*} Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.




^{*} Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.

^{*} The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.

^{*} Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%

^{*} Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.

For JSY5000, A, B port: Ø12



^{*} Operating piston speed is different depending on the applicable cylinder. Refer to the cylinder catalog for details.



^{*} Values at extension of a directly coupled cylinder when meter-out speed controllers are used with the needle full open.

^{*} The average speed of the cylinder is obtained by dividing the stroke by the total stroke time.

^{*} Formula for load ratio: Load ratio = ((Load mass x 9.8)/Theoretical output) x 100%

^{*} Cylinder for horizontal use are based on the coefficient of rolling friction 0.1.

JSY1000/3000/5000 Series Valve Specifications

Valve Specifications

Valve type			Rubber seal			
Fluid			Air			
	2-position sing	gle	0.15 to 0.7			
Internal pilot operating pressure range	2-position dou	ble	0.1 to 0.7			
	3-position		0.2 to 0.7			
[iiii u]	4-position dua	l 3-port valve	0.15 to 0.7			
	Operating pres	ssure range	-100 kPa to 0.7 (4-position: -100 kPa to 0.5)			
(Made to Order)	Pilot	2-position single/double	0.25 to 0.7			
operating pressure range	pressure	4-position dual 3-port valve* 1	Operating pressure + 0.2 or more (Min. 0.25) to 0.7			
[MPa]	range	3-position	0.25 to 0.7			
Ambient and fluid tempera	tures [°C]		-10 to 50 (No freezing)			
		2-position single/double	5			
	JSY1000/3000	4-position dual 3-port valve	5			
Max. operating frequency		3-position	3			
[Hz]	JSY5000	2-position single/double	5			
		4-position dual 3-port valve	3			
		3-position	3			
			Non-locking push type			
Manual override			Push-turn locking slotted type			
			Push-turn locking lever type*2			
Pilot exhaust type	Internal pilot		Individual exhaust			
Pilot extiaust type	External pilot	(Made to Order)				
Lubrication			Not required			
Mounting orientation*3			Unrestricted			
Impact/Vibration resistance	e*3 [m/s²]		150/30			
Enclosure			JSY1000: IP40 JSY3000/5000: IP67 (Based on IEC 60529)			
Coil rated voltage [DC]			24 V			
Allowable voltage fluctuation [V]			±10% of the rated voltage			
	Standard	JSY3000/5000	0.4			
Power consumption [W]	With power-	JSY1000	0.2*4 [Inrush 0.5, Holding 0.2]			
	saving circuit	JSY3000/5000	0.1*5 [Inrush 0.4, Holding 0.1]			
Surge voltage suppressor			Diode (Varistor for non-polar type)			
Indicator light			LED			
			h			

- *1 Only the JSY3000 can be selected for the 4-position dual 3-port valve external pilot specification.
- *2 Not available for the JSY1000 series
- * Impact resistance: No malfunction occurred when tested in the axial direction and at a right angle to the main valve and armature in both an energized and a de-energized state, once in each condition. (Value in the initial state)
 - Vibration resistance: No malfunction occurred in a one-sweep test between 45 and 2000 Hz in the axial direction and at a right angle to the main valve and armature in both an energized and a de-energized state, once in each condition. (Value in the initial state)
 Refer to page 160 for details on securing the DIN rail mounting type manifold.
- *4 The JSY1000 series is only available as the power-saving type. Standard type (without power-saving circuit) cannot be selected.
- *5 For details, refer to page 158.

Valve Specifications JSY1000/3000/5000 Series

Response Time

			Response	time [ms]*1
Series	Model	Type of actuation	With light/surge v	oltage suppressor
			Z type U type 15 7 16 19 27 18 13 12 27 24 27 24 valve 23 23 35 25 19 17	U type
	JSY1100	2-position single	15	
JSY1000	JSY1200	2-position double	7	
3511000	JSY13/4/500	3-position	16	_
	JSY1A/B/C00	4-position dual 3-port valve	19	
	JSY3100	2-position single	27	18
JSY3000	JSY3200	2-position double	13	12
3513000	JSY33/4/500	3-position	27	24
	JSY3A/B/C00	4-position dual 3-port valve	23	23
	JSY5100	2-position single	35	25
ICVENO	JSY5200	2-position double	19	17
JSY5000	JSY53/4/500	3-position	41	37
	JSY5A/B/C00 4-position dual 3-port valve		37	37

^{*1} Based on dynamic performance test, JIS B 8419-2010 (Coil temperature: 20°C, at rated voltage)

Valve Weight

JSY1000 Series

Valve model	Т	Weight [g]	
	O manitian	Single	24
	2-position	Double	27
JSY1⊓00		Closed center	
J311 L00	3-position	Exhaust center	30
		Pressure center	
	4-position	Dual 3-port valve	27

JSY5000 Series

Valve model	T	ype of actuation	Weight [g]	
	Onesition	Single	91	
	2-position	Double	100	
JSY5□00		Closed center		
JS15_00	3-position	Exhaust center	110	
		Pressure center]	
	4-position	Dual 3-port valve	96	

JSY3000 Series


Valve model	Т	Weight [g]			
	2-position	Single	54		
	2-005111011	Double	63		
JSY3□00		Closed center			
J513_00	3-position	Exhaust center	67		
		Pressure center]		
	4-position	Dual 3-port valve	63		

SMC


JSY1000/3000/5000 Series Valve Construction

Rubber Seal


2-position single (A) (BA) (A) (P) (B) (EB) (CA) (A) (P) (B) (EB)




3-position closed center/exhaust center/pressure center



4-position dual 3-port valve






Component Parts

	p c c u . u c				
No.	Description	Material			
1	Body	Aluminum die-casted			
2	Spool valve	Aluminum/HNBR (4-position solenoid valve: Resin/HNBR			
3	Piston	Resin			
4	Pilot valve assembly	_			


JSY3000/5000 Series Valve Replacement Parts: Pilot Valve

How to Order Pilot Valves (With a gasket and two mounting screws)*



↑ Caution

- The coil specification and voltage (including light/ surge voltage suppressor) cannot be changed by changing the pilot valve assembly.
- When selecting the standard coil type, it is not possible to change to the power-saving circuit type.
- 3. Replacement pilot valve for the JSY3000/5000



- Loosen B tight flat head screw to remove the pilot cover in the direction indicated by the arrow ①.
- Remove the pilot valve mounting screws.
- Remove the pilot valve in the direction indicated by the arrow 2.
- * Assemble by following the removal procedure in reverse.
- *1 Ensure the gasket is mounted, and take care not to bend the socket.
- *2 Be noted for mounting that there are two types of lengths for the pilot valve mounting screws.
- *3 The pilot valve of the JSY1000 cannot be removed. This is irreplaceable.



JSY1000/3000/5000 Series Type 10 Plug-in Connector Connecting Base

Manifold Specifications

			D	-sub connect	or			Flat ribb	on cable			
	Model		F type	FW type*1	FC type*2	P type	PG type	PH type	PC type*2	PGC type*2	PHC type*2	
Manifo	ld type					Plug-in cor	nnector conne	ecting base	•	,	•	
SUP/E	XH port type				Co	mmon SUP/E	XH (Commor	n for the 3/5 p	ort)			
Valve s	stations			2 to 24	stations		2 to 18 stations	2 to 8 stations	2 to 24 stations	2 to 18 stations	2 to 8 stations	
Annlia	Applicable connector		D-sub connector conforming to	Dedicated connector	D-sub connector conforming to			Flat ribbon ca g to MIL-C-83				
Applic			MIL-C-24308 (Refer to page 60.)	(Refer to page 60.)	MIL-C-24308 (Refer to page 60.)	Socket: 26 pins MIL type	Socket: 20 pins MIL type	Socket: 10 pins MIL type	Socket: 26 pins MIL type	Socket: 20 pins MIL type	Socket: 10 pins MIL type	
Interna	al wiring			Positive common, Negative common								
	JSY1			ø8 One-touch fitting								
	1(P), 3/5(E) port	JSY3000		ø10 One-touch fitting								
Port	port	JSY5000		ø12 One-touch fitting								
size	4(A) 0(D)	JSY1000		ø2 One-touch fitting, ø4 One-touch fitting, ø6 One-touch fitting								
	4(A), 2(B) port	JSY3000		ø4 One-touch fitting, ø6 One-touch fitting, ø8 One-touch fitting								
	port	JSY5000		ø6 One-te	ouch fitting, ø	3 One-touch f	fitting, ø10 Or	ne-touch fitting	g, ø12 One-to	uch fitting		
	Enclosure (Based on IEC 60529)			ı	IP20					IP20		
			IP40	IP67	11 20		IP40		IF20			
		JSY5000		11 07	_			_				

^{*1} The FW type is not available for the JSY1000. Protection class for the JSY1000 is IP20 or IP40.

Manifold Weight

											Unit: g	
							② Wiring					
	Mandal		D-sub connector			Flat ribbon cable						
Model		1 Per station	F type	FW type*2	FC type*3	P type	PG type	PH type	PC type*3	PGC type*3	PHC type*3	
JSY1000	for ø4	21.3	308	_	233	306	304	298	233	231	225	
3511000	for ø6	26.9	319	_	244	317	315	309	244	242	236	
JSY3000	for ø8	42.7	332	330	287	330	328	322	257	255	249	
JSY5000) for ø12	104	509	507	_	507	505	499	_	_	_	

Formula for manifold weight*1

W = 1 x n1 + 2 (n1: stations)

JSY3000 series, D-sub connector, F type, 5 stations: (42.7 x 5) + 332 = 545.5 (g)

Manifold Flow Rate Characteristics

	Port	size	Valve flow rate characteristics					
Model	1, 3/5	4, 2	1 → 4/2 (P →	A/B)	4/2 → 3/5 (A/B → E)			
	(P, E)	(A, B)	C [dm ³ /(s-bar)]	b	C [dm ³ /(s-bar)]	b		
JJ5SY1-10	C8	C4	0.63	0.46	0.87	0.47		
(Side ported)	Co	C6	0.96	0.30	0.91	0.48		
JJ5SY3-10 (Side ported)	C10	C8	2.23	0.30	2.77	0.27		
JJ5SY5-10 (Side ported)	C12	C12	6.40	0.22	6.59	0.22		

^{*} Calculation of effective area S and sonic conductance C: S = 5.0 x C

^{*2} The FC, PC, PGC, and PHC types are not available for the JSY5000.

^{*} Values measured in accordance with ISO 6358:1989, JIS B 8390:2000



Terminal	block box	Lead wire	e Serial wiring						
T type	TC type	L type	S6□ type (EX600)	SA□ type (EX245)	S□ type (EX250)	S□ type (EX260)	S3□ type (EX120)		
	,		Plug-in connecto	r connecting base					
Common SUP/EXH (Common for the 3/5 port)									
2 to 20 stations 2 to 24 stations 2 to 16 stations									
_									
	Positive common,	Negative common		Negative common	Positive	common, Negative	common		
ø8 One-touch fitting									
ø10 One-touch fitting									
ø12 One-touch fitting									
ø2 One-touch fitting, ø4 One-touch fitting, ø6 One-touch fitting									
ø4 One-touch fitting, ø6 One-touch fitting, ø8 One-touch fitting									
ø6 One-touch fitting, ø8 One-touch fitting, ø10 One-touch fitting, ø12 One-touch fitting									
IP40									
	IP67		IP67 (I/O unit: partially IP40)	IP65	IP67	IP67 D-sub communication connector: IP40	IP20		

									Unit: g
	② Wiring								
Terminal	block box		Lead wire				Serial wiring		
T type	TC type	L type (0.6 m)	L type (1.5 m)	L type (3 m)	S6□ type (EX600)*4	SA□ type (EX245)*4	S□ type (EX250)*4	S□ type (EX260)	S3□ type (EX120)
680	471	404	514	698	829	_	520	448	367
689	480	413	523	707	838	_	529	457	367
709	500	433	543	727	858	935	549	477	391
914	705	638	748	932	1063	1100	754	682	568

^{*1} Weight: "W" is the value for the internal pilot specification, the max. fitting size, and the manifold only. The valve weight is not included. To obtain the weight with valves attached, add the valve weight given on page 35 for the appropriate number of stations.

ZK2 Combination Manifold Weight

Single Unit			

onigio onic	
Single unit model	Weight [g]
ZK2 (1 station for manifold, Without pressure sensor/switch)	99

Pressure Sensor/Pressure Switch for Vacuum

Pressure sensor/Pressure switch for vacuum model	Weight [g]
ZK2-PS□-A (Excludes the cable portion weight)	5
ZK2-ZS□-A (Excludes the lead wire with connector weight)	14

Formula for ZK2 combination manifold weight

Wz = 1 x n1 + 2 + 3 x n2 + 3 (n1: JSY3000 stations, n2: ZK2 stations)

	- 1
JSY3000 P, E port entry	3
D side	158
U side	275
B side	292

The weight "Wz" is the value for the internal pilot specification, the max. fitting size, and the manifold only. To obtain the weight with valves and ejectors mounted, add the valve weight and the weight of the ejector, pressure sensor, and pressure switch for vacuum above, respectively, for the appropriate number of stations.



^{*2} The FW type is not available for the JSY1000.

^{*3} The FC, PC, PGC, and PHC types are not available for the JSY5000.


^{*4} The serial unit weight is included, but the I/O unit weight is not included. Add the weight of the I/O unit for calculation.

Connector Wiring Layout

Station 3

For both serial and parallel wiring, additional valves are sequentially assigned pins on the connector. This makes it completely unnecessary to disassemble the connector unit.

■ Single solenoid valve is installed to all double wiring. (in the case of all double wiring) (Manifold specification sheet is not necessary.)



■ Single/double wiring are mixed. (Manifold specification sheet is necessary.) Connector side Solenoid (D-sub connector, etc.) Common (+, -) SOL.a 0 -Station 1 ----SOL.b 0 SOL.a Station 2 SOL.a -Station 3 SOL.b -Double solenoid Single solenoid Double solenoid

Station 1

Station 2



^{*} These diagrams are for the purpose of explanation, and differ from the actual connector wiring.

Plug-in Connector Connecting Base

D-sub Connector Flat Ribbon Cable

Type 10 Side Ported

JSY1000/3000/5000 Series


(E UK RoHS





Internal Pilot

How to Order Manifolds





External pilot (SUP/EXH block assembly)

Series JSY1000 JSY3000 JSY5000

4 Connector entry direction

2. Lateral

10 Side ported

The connector entry direction


for connector types "FW," "FC," and "P□C" cannot be rotated. If it is necessary to

change, order connector

block assembly and SUP/

EXH block assembly (pages

3 Connector type



1: Upward

6 P, E port entry				
U	U side (2 to 10 stations)			
D	D side (2 to 10 stations)			
В	Both sides (2 to 24 stations)			

124 and 125) separately. SUP/EXH block assembly

Nil	Internal pilot				
s	Internal pilot,				
3	Built-in silencer				

- The 3/5(E) port is plugged for the built-in silencer type. The external pilot specification
- should be ordered as Made to Order. For details, refer to page

A B port size (Metric/One-touch fitting)

O A, I	Þρ	ort size (ivie	tric/One-	touch iit	urig)	
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	_	_	~ E)
C4		ø4	•	•	_	
C6	ᆂ	ø6	•	•	•	
C8	Straight	ø8	_	•	•	
C10	ŝ	ø10	_	_	•	
C12		ø12	_	_	•	00
CM*1	1	Straight port, mixed sizes	•	•	•	- Order
P, E port size (One-touch fittings)		ø8	ø10	ø12		

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM." * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6.
- When CM is selected, the manifold pitch is different depending on the selected fitting

Mounting and Option

Mounting
Direct mounting
DIN rail mounting

DIN Rail Ontion

Nil	DIN rail mounting (With DIN rail)										
0	DIN rail ı	mounting (Without DIN rail)									
3	For 3 stations	Specify a length longer									
- i	:	than that of the standard									
24	For 24 stations	rail.									

- * Enter the number of stations inside

 when it is larger than the number of valve stations (Refer to "DIN Rail Option" shown on the left.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.

- *1 FW is not available for the JSY1000.
- *2 Compact type is not available for the JSY5000.

Valve stations

F/FW	//FC : D	-sub connector (25 pins)	P/P	C: Flat	ribbon cable (26 pins)								
Symbol	Stations	Note	Symbol	Stations	Note								
02	2 stations		02	2 stations									
:		Double wiring*1	:	:	Double wiring*1								
12	12 stations	·	12	12 stations									
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2								
:		(Up to 24	:	:	(Up to 24								
24	24 stations	solenoids available)	24	24 stations	solenoids available)								
PG/F	PG/PGC: Flat ribbon cable (20 pins) PH/PHC: Flat ribbon cable (10 pins)												
Symbol	Stations	Note	Symbol	Stations	Note								
02	2 stations		02	2 stations									
1	-:-	Double wiring*1	1	1	Double wiring*1								
09	9 stations		04	4 stations									
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2								
:		(Up to 18	:		Up to 8								
18	18 stations	solenoids available)	08	8 stations	solenoids available)								
-1 D	ouble v	viring: 2 position single	doub	do 2 no	scition and 4 position								

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused
 - control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of blanking plates.

How to Order Manifold Assembly

Example (JJ5SY3-10F1-□) 2-position double (24 VDC) JSY3100-5U (2 sets) Manifold base (5 stations) JJ5SY3-10F1-05D-C8

- JJ5SY3-10F1-05D-C8 ··· 1 set (Type 10 5-station manifold base part no.)

 * JSY3100-5U ··············· 2 sets (2-position single part no.)


 * JSY3200-5U ·············· 3 sets (2-position double part no.)

 T
 - The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the valve, etc.
- · For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 Series

_	
1	JSY1000
3	JSY3000
5	JSY5000

2 Type of actuation

1	O manitian	Single				
2	2-position	Double				
3		Closed center				
4	3-position	Exhaust center				
5		Pressure center				
Α	4	N.C./N.C.				
В	4-position dual 3-port	N.O./N.O.				
С	duai 3-port	N.C./N.O.				

3 Coil specifications

Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
Nil	Standard	_	•	•
T	With power-saving circuit (Continuous duty type)	•	•	•

- * For the JSY1000 series, only the power-saving circuit specification is available.
- $\ast\,$ Be careful of the energizing time when the power-saving circuit is selected.

For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

- * When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.
- * Only "Z" and "NZ" types are available with a power saving circuit.

6 Manual override

Symbol/Specification	JSY1000	JSY3000	JSY5000
Nii: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.





If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.




Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to Ø2 and Ø4 fittings)

D-sub Connector (IP40/Connector Entry Direction Adjus



JJ5SY1-10F₂-Stations D-C₂(D)





- * These figures show the "JJ5SY1-10F2-05D-C4."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

I · Dimensions n: Stations

	II I I I I I I I I I I I I I I I I I I														
L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	96	102.5	109	115.5	122	128.5	135	141.5	148	154.5	161	167.5	174	180.5	187
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21


_ n	17	18	19	20	21	22	23	24
L1	193.5	200	206.5	213	219.5	226	232.5	239
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	223	235.5	248	248	260.5	260.5	273	273
L4	212.5	225	237.5	237.5	250	250	262.5	262.5
L5	18	21	24	20.5	23.5	20.5	23.5	20


Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to Ø6 fittings)
D-sub Connector (IP40/Connector Entry Direction Adjustable)



JJ5SY1-10F₂¹-Stations P-C6(D)





- * These figures show the "JJ5SY1-10F2-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to
- Order)and silencer.
- When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dimensions n: Stat															n: Stations
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	101	110	119	128	137	146	155	164	173	182	191	200	209	218	227
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	135.5	148	160.5	160.5	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5
L4	125	137.5	150	150	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250
L5	20.5	22	24	19.5	21	23	18.5	20	22	23.5	19	21	22.5	18	20


_ n	17	18	19	20	21	22	23	24
L1	236	245	254	263	272	281	290	299
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	273	285.5	285.5	298	310.5	310.5	323	335.5
L4	262.5	275	275	287.5	300	300	312.5	325
L5	21.5	23.5	19	20.5	22.5	18	19.5	21.5


Type 10/Side Ported

Dimensions: JSY3000 Series

D-sub Connector (IP40/Connector Entry Direction Adjustable

JJ5SY3-10F2-Stations D-C6 (D)





- * These figures show the "JJ5SY3-10F2-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	L: Dimensions n: Sta														
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	93.8	105.3	116.8	128.3	139.8	151.3	162.8	174.3	185.8	197.3	208.8	220.3	231.8	243.3	254.8
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275
L5	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	18	18.5


L	17	18	19	20	21	22	23	24
L1	266.3	277.8	289.3	300.8	312.3	323.8	335.3	346.8
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	298	310.5	323	335.5	348	360.5	373	385.5
L4	287.5	300	312.5	325	337.5	350	362.5	375
L5	19	19.5	20	20.5	21	21.5	22	22.5


Dimensions: JSY5000 Series

Type 10/Side Ported

D-sub Connector (IP40/Connector Entry Direction Adjustable

JJ5SY5-10F $_2^1$ -Stations $_{\text{D}}^{\text{U}}$ - $_{\text{C10}}^{\text{C6}}$ (D)





- * These figures show the "JJ5SY5-10F2-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions n: Stations

															010110110
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	139	155	171	187	203	219	235	251	267	283	299	315	331	347
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	185.5	210.5	223	235.5	260.5	273	285.5	298	323	335.5	348	360.5	385.5
L4	150	162.5	175	200	212.5	225	250	262.5	275	287.5	312.5	325	337.5	350	375
L5	22	20	18.5	23	21	19.5	24	22	20.5	18.5	23	21.5	19.5	18	22.5

_ n	17	18	19	20	21	22	23	24
L1	363	379	395	411	427	443	459	475
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	398	410.5	435.5	448	460.5	473	498	510.5
L4	387.5	400	425	437.5	450	462.5	487.5	500
L5	20.5	19	23.5	21.5	20	18	22.5	21

C10: ø10 (SMC) C12: ø12 (SMC)


Dimensions: JSY3000 Series


Type 10/Side Ported

D-sub Connector (IP67)

JJ5SY3-10FW2-Stations D-C6 (D)







- * These figures show the "JJ5SY3-10FW2-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ensior	ıs												r	n: Stations
L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	108.6	120.1	131.6	143.1	154.6	166.1	177.6	189.1	200.6	212.1	223.6	235.1	246.6	258.1	269.6
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	148	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298
L4	137.5	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	275	287.5	287.5
L5	22	16	16.5	17	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	16.5


_ n	17	18	19	20	21	22	23	24
L1	281.1	292.6	304.1	315.6	327.1	338.6	350.1	361.6
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	310.5	323	335.5	348	360.5	373	385.5	398
L4	300	312.5	325	337.5	350	362.5	375	387.5
L5	17	17.5	18	18.5	19	19.5	20	20.5


. Di-----

Dimensions: JSY5000 Series

Type 10/Side Ported
D-sub Connector (IP67)

JJ5SY5-10FW $_2^1$ -Stations $\stackrel{\text{U}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{D}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel$





- * These figures show the "JJ5SY5-10FW2-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions n: Stations

_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	128	144	160	176	192	208	224	240	256	272	288	304	320	336	352
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	198	210.5	223	248	260.5	273	285.5	310.5	323	335.5	348	373	385.5
L4	150	162.5	187.5	200	212.5	237.5	250	262.5	275	300	312.5	325	337.5	362.5	375
L5	18.5	17	21.5	19.5	18	22.5	20.5	19	17	21.5	20	18	16.5	21	19

L	17	18	19	20	21	22	23	24
L1	368	384	400	416	432	448	464	480
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	398	423	435.5	448	460.5	485.5	498	510.5
L4	387.5	412.5	425	437.5	450	475	487.5	500
L5	17.5	22	20	18.5	16.5	21	19.5	17.5

C12: ø12 (SMC)


Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to 92 and 94 fittings)

D-sub Connector (IP20/Compact Type)

JJ5SY1-10FC2-Stations D-C2(D)







- * These figures show the "JJ5SY1-10FC2-05D-C4."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions n: Stations

L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	77.1	83.6	90.1	96.6	103.1	109.6	116.1	122.6	129.1	135.6	142.1	148.6	155.1	161.6	168.1
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198
L4	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5
L5	20	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18

L_n	17	18	19	20	21	22	23	24
L1	174.6	181.1	187.6	194.1	200.6	207.1	213.6	220.1
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	210.5	210.5	223	235.5	235.5	248	248	260.5
L4	200	200	212.5	225	225	237.5	237.5	250
L5	21	18	21	24	20.5	23.5	20.5	23.5


Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to of fittings)

D-sub Connector (IP20/Compact Type)



JJ5SY1-10FC2-Stations D-C6(D)





- * These figures show the "JJ5SY1-10FC2-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ensior	ıs												r	n: Stations
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	82.1	91.1	100.1	109.1	118.1	127.1	136.1	145.1	154.1	163.1	172.1	181.1	190.1	199.1	208.1
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	123	123	135.5	148	148	160.5	173	185.5	185.5	198	210.5	210.5	223	235.5	248
L4	112.5	112.5	125	137.5	137.5	150	162.5	175	175	187.5	200	200	212.5	225	237.5
L5	23.5	19	21	22.5	18	20	21.5	23.5	19	20.5	22.5	18	19.5	21.5	23


_ n	17	18	19	20	21	22	23	24
L1	217.1	226.1	235.1	244.1	253.1	262.1	271.1	280.1
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	248	260.5	273	285.5	285.5	298	310.5	310.5
L4	237.5	250	262.5	275	275	287.5	300	300
L5	18.5	20.5	22	24	19.5	21	23	18.5

Dimensions: JSY3000 Series


Type **10/Side** Ported

D-sub Connector (IP20/Compact Type)

JJ5SY3-10FC2-Stations D-C6(D)



(5.3)



L2 (L4)

(DIN rail mounting hole pitch: 12.5)

(L3)

- * These figures show the "JJ5SY3-10FC2-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

(Fitting for the type with

P/E ports on the U and/or D sides)


L:	Dim	ension	ıs												r	n: Stations
_	n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L	_1	93.3	104.8	116.3	127.8	139.3	150.8	162.3	173.8	185.3	196.8	208.3	219.8	231.3	242.8	254.3
L	2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L	.3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	260.5	273	285.5
L	4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	250	262.5	275
	.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	17.5	18	18.5


L	17	18	19	20	21	22	23	24
L1	265.8	277.3	288.8	300.3	311.8	323.3	334.8	346.3
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	298	310.5	323	335.5	348	360.5	373	385.5
L4	287.5	300	312.5	325	337.5	350	362.5	375
L5	19	19.5	20	20.5	21	21.5	22	22.5


Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to ©2 and ©4 fittings)
Flat Ribbon Cable (IP40/Connector Entry Direction Adjustable)


JJ5SY1-10 EG 1- Stations D-C2 (D)











- * These figures show the "JJ5SY1-10P2-05D-C4."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- Only connectors are different for 10PG and 10PH. L1 to L5 dimensions are the same as 10P type.
- When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions n: Stations

L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	96	102.5	109	115.5	122	128.5	135	141.5	148	154.5	161	167.5	174	180.5	187
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	23	19.5	22.5	19.5	22.5	19	22	19	22	18.5	21.5	18.5	21.5	18	21

n	17	18	19	20	21	22	23	24
L1	193.5	200	206.5	213	219.5	226	232.5	239
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	223	235.5	248	248	260.5	260.5	273	273
L4	212.5	225	237.5	237.5	250	250	262.5	262.5
L5	18	21	24	20.5	23.5	20.5	23.5	20


Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to Ø6 fittings)


Flat Ribbon Cable (IP40/Connector Entry Direction Adju




JJ5SY1-10 PG 1-Stations U-C6(D)










- * These figures show the "JJ5SY1-10P2-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * Only connectors are different for 10PG and 10PH. L1 to L5 dimensions are the same as 10P type.
- When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


L: Din	L: Dimensions n: Sta															tations							
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	101	110	119	128	137	146	155	164	173	182	191	200	209	218	227	236	245	254	263	272	281	290	299
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	135.5	148	160.5	160.5	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5	273	285.5	285.5	298	310.5	310.5	323	335.5
L4	125	137.5	150	150	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250	262.5	275	275	287.5	300	300	312.5	325
L5	20.5	22	24	19.5	21	23	18.5	20	22	23.5	19	21	22.5	18	20	21.5	23.5	19	20.5	22.5	18	19.5	21.5


Dimensions: JSY3000 Series

Type 10/Side Ported
Flat Ribbon Cable (IP40/Connector Entry Direction Adjustable)

JJ5SY3-10 PG 1- Stations D - C6 (D)







- * These figures show the "JJ5SY3-10P2-05D-C8."
- Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.
- Only connectors are different for 10PG and 10PH. L1 to L5 dimensions are the same as 10P type.

L: Dimensions

L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	93.8	105.3	116.8	128.3	139.8	151.3	162.8	174.3	185.8	197.3	208.8	220.3	231.8	243.3	254.8	266.3	277.8	289.3	300.8	312.3	323.8	335.3	346.8
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275	287.5	300	312.5	325	337.5	350	362.5	375
L5	17.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5	23	23.5	18	18.5	19	19.5	20	20.5	21	21.5	22	22.5


n: Stations


Type 10/Side Ported


Dimensions: JSY5000 Series

Flat Ribbon Cable (IP40/Connector Entry Direction Adjustable)

JJ5SY5-10 PG 1- Stations B - C80 (D)







- * These figures show the "JJ5SY5-10P2-05D-C12."
- Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

C8: ø8 (SMC) C10: ø10 (SMC) C12: ø12 (SMC)

n: Stations

 Only connectors are different for 10PG and 10PH. L1 to L5 dimensions are the same as 10P type.

L:	Dir	nens	ions	;															
$\overline{}$	- n	_	1	4	-	6	7	0	10	44	10	12	14	45	10	17	10	10	20

Ln	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	123	139	155	171	187	203	219	235	251	267	283	299	315	331	347	363	379	395	411	427	443	459	475
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	160.5	173	185.5	210.5	223	235.5	260.5	273	285.5	298	323	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5
L4	150	162.5	175	200	212.5	225	250	262.5	275	287.5	312.5	325	337.5	350	375	387.5	400	425	437.5	450	462.5	487.5	500
L5	22	20	18.5	23	21	19.5	24	22	20.5	18.5	23	21.5	19.5	18	22.5	20.5	19	23.5	21.5	20	18	22.5	21


U side

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 02 and 04 fittings) Flat Ribbon Cable (IP20/Compact Type)

D side

JJ5SY1-10 PG C2-Stations D-C2(D)



- * Refer to page 118 for dimensions of external pilot (Made to
- * Only connectors are different for 10PGC and 10PHC. L1 to L5
- * When CM is selected for mixed A, B port size and C6 (9 mm

L: Dimensions

Applicable connector: 20 pins

(Conforming to MIL-C-83503)

Triangle mark

42.4

n. Stations

9.5

(35)

59.9

(For DIN rail mounting)

27

78 က

L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	72.1	78.6	85.1	91.6	98.1	104.6	111.1	117.6	124.1	130.6	137.1	143.6	150.1	156.6	163.1
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	110.5	123	123	135.5	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198
L4	100	112.5	112.5	125	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5
L5	25	28	24.5	27.5	24.5	27.5	24	27	24	27	23.5	26.5	23.5	26.5	23

_ n	17	18	19	20	21	22	23	24
L1	169.6	176.1	182.6	189.1	195.6	202.1	208.6	215.1
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	210.5	210.5	223	235.5	235.5	248	248	260.5
L4	200	200	212.5	225	225	237.5	237.5	250
L5	26	23	26	29	25.5	28.5	25.5	28.5


Applicable connector: 10 pins (Conforming to MIL-C-83503)

Triangle mark

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 06 fittings)
Flat Ribbon Cable (IP20/Compact Type)

JJ5SY1-10 PG C2-Stations P-C6(D)



n: Stations

Triangle mark

=- =															
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	77.1	86.1	95.1	104.1	113.1	122.1	131.1	140.1	149.1	158.1	167.1	176.1	185.1	194.1	203.1
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	123	123	135.5	148	148	160.5	173	185.5	185.5	198	210.5	210.5	223	235.5	248
L4	112.5	112.5	125	137.5	137.5	150	162.5	175	175	187.5	200	200	212.5	225	237.5
L5	28.5	24	26	27.5	23	25	26.5	28.5	24	25.5	27.5	23	24.5	26.5	28


L_n	17	18	19	20	21	22	23	24
L1	212.1	221.1	230.1	239.1	248.1	257.1	266.1	275.1
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	248	260.5	273	285.5	285.5	298	310.5	310.5
L4	237.5	250	262.5	275	275	287.5	300	300
L5	23.5	25.5	27	29	24.5	26	28	23.5

Triangle mark

Dimensions: JSY3000 Series

Type 10/Side Ported
Flat Ribbon Cable (IP20/Compact Type)

JJ5SY3-10 PG C2-Stations D-C6 (D)




L: Dimensions n: Stations n: Stations

_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	88.3	99.8	111.3	122.8	134.3	145.8	157.3	168.8	180.3	191.8	203.3	214.8	226.3	237.8	249.3
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5
L4	112.5	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275
L5	23	23.5	24	24.5	25	25.5	26	26.5	27	27.5	28	28.5	29	23	23.5

	17	18	19	20	21	22	23	24
L1	260.8	272.3	283.8	295.3	306.8	318.3	329.8	341.3
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	298	310.5	323	335.5	348	360.5	373	385.5
L4	287.5	300	312.5	325	337.5	350	362.5	375
L5	24	24.5	25	25.5	26	26.5	27	27.5

Electrical Wiring Specifications



When using a valve with no polarity, either positive common or negative common can be used.

C<u>OM.</u> ∘ 13

SOL.b_{o 25}

Specified Layout

(25 pins)

Station 12 4



A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 24 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.

(-)

(+)

Positive

common

(+)

(+)


(-)

Negative

common

COM.

Connector Cable



D-sub connector cable [IP20/40 compliant]

Cable length (L)	Assembly part no.	Note
1.5 m	AXT100-DS25-015	
3 m	AXT100-DS25-030	Cable 0.3 mm ² x 25 cores
5 m	AXT100-DS25-050	U.STIIII X 25 COIes

- * When using a standard commercial connector, use a 25-pin type female connector conforming to MIL-C-24308.
- Cannot be used for movable wiring
- Lengths other than the above are also available

D-sub connector cable [IP67 compliant]

Cable length (L)	Assembly part no.	Note
1.5 m	SY30M-DS25-015	
3 m	SY30M-DS25-030	Cable 0.3 mm ² x 25 cores
5 m	SY30M-DS25-050	0.511111 x 25 00165

- Be sure to use the connector cable in the table, to satisfy enclosure IP67.
- Cannot be used for movable wiring
- rtrical characteristics

Electrical cris	aracteri
Item	Property
Conductor resistance Ω/km , 20°C	65 or less
Voltage limit V, 1 minute, AC	1000
Insulation resistance MΩ/km, 20°C	5 or more

Connector Manufacturer's Example

- · Fujitsu Limited
- · Japan Aviation Electronics Industry, Limited
- J.S.T. Mfg. Co., Ltd.
- · HIROSE ELECTRIC CO., LTD.


The minimum bending radius of the D-sub connector cable is 20 mm

D-sub connector cable terminal numbers

Terminal no.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
Lead wire color	Black	Brown	Red	Orange	Yellow	Pink	Blue	Purple	Gray	White	White	Yellow	Orange	Yellow	Pink	Blue	Purple	Gray	Orange	Red	Brown	Pink	Gray	Black	White
Dot marking	None	None	None	None	None	None	None	White	Black	Black	Red	Red	Red	Black	Black	White	None	None	Black	White	White	Ped	Red	White	None




Electrical Wiring Specifications



P, PC: Flat ribbon	cable (2	26 pins) –
<double< th=""><th>wiring></th><th></th></double<>	wiring>	
	Terminal no.	Polarity
Station 1 { SOL.a SOL.b -	1 (-)	(+)
SOLIO SOLIO	2 (-)	
Station 2 SOL.b	3 (-)	
SOLIA	4 (-)	
Station 3 SOL.b.	5 (-)	
SOL.a	6 (-)	
Station 4 SOL.b	7 (-)	
SOLa	8 (-)	
Station 5 SOLb	9 (-)	
SOLa o	10 (-)	
Station 6 SOL.b	11 (-)	
SOL.a	12 (-)	
Station 7 SOL b	13 (-)	
9013	14 (-)	
Station 8 SOL.b	15 (–)	
SOLa	16 (-)	
Station 9 SOLb	17 (-)	
SOLa	18 (-)	
Station 10 SOL.b	19 (-)	
SOL.a	20 (-)	
Station 11 SOLb	21 (-)	
9013	22 (-)	
Station 12 SOL.b	23 (-)	
(tww.	24 (-)	(+)
COM.	25 (+)	(-)
COM.	26 (+)	
		ve Negative
	comm	on common


PG, PGC: Flat ribbo	n cable (20 pins)					
<double wiring=""></double>						
	Terminal no. Polarity					
Station 1 SOLa	Termind no. Polarity 1 (-) (+) 2 (-) (+) 3 (-) (+) 4 (-) (+) 5 (-) (+) 5 (-) (+) 7 (-) (+) 7 (-) (+) 10 (-) (+) 11 (-) (+) 12 (-) (+) 13 (-) (+) 15 (-) (+) 16 (-) (+) 16 (-) (+) 16 (-) (+)					
Station 9 {SOL.b_o	17 (-) (+) 18 (-) (+)					
COM.	19 (+) (-) 20 (+) (-) Positive Negative common common					



 When using a valve with no polarity, either positive common or negative common can be used.

Flat Ribbon Cable Connector





Flat ribbon cable connector


	Cable	Assembly part no.				
length (L)		26 pins	20 pins	10 pins		
Г	1.5 m	AXT100-FC26-1	AXT100-FC20-1	AXT100-FC10-1		
Г	3 m	AXT100-FC26-2	AXT100-FC20-2	AXT100-FC10-2		
Г	5 m	AYT100-FC26-3	AYT100-FC20-3	AYT100-FC10-3		

- * When using a standard commercial connector, use a 26-pin, 20-pin, or 10-pin type connector conforming to MIL-C-83503 with strain relief.
- Cannot be used for movable wiring
- Lengths other than the above are also available.

Connector Manufacturer's Example

- · HIROSE ELECTRIC CO., LTD.
- 3M Japan Limited
- Fujitsu Limited
- · Japan Aviation Electronics Industry, Limited
- J.S.T. Mfg. Co., Ltd.
- Oki Electric Cable Co., Ltd.

Specified Layout



A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 24 or less for P and PC, 18 or less for PG and PGC, and 8 or less for PH and PHC. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.

Plug-in Connector Connecting Base

Spring Type Terminal Block Box Terminal Block Box

Type 10 Side Ported


JSY1000/3000/5000 Series





Internal Pilot

How to Order Manifolds



Made to Order (Refer to page 156 for details.)

Specification External pilot (SUP/EXH block assembly)

1 Ser	ies
1	

U Jeiles				
1	JSY1000			
3	JSY3000			
5	JSY5000			

2 Type					
10	Side ported				

3 Wiring

pring type terminal block box
Terminal block box

Valve stations

TC: Spring type terminal block box				Tε	ermina	block box	
Symbol	Stations	Note	Symb	ool	Stations	Note	
02	2 stations		02	2	2 stations		
	:	: Double wiring*1			:	Double wiring*1	
16	16 stations		10)	10 stations		
02	2 stations	Specified layout*2	02	2	2 stations	Specified layout*2	
	:	(Up to 32 solenoids	:		:	(Up to 20 solenoids	
24	24 24 stations available)		20)	20 stations	available)	

*1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations.

The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.

- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- *3 This also includes the number of blanking plates.

P. E port entry

U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 24 stations)

6 SUP/EXH block assembly

Nil	Internal pilot			
S	Internal pilot, Built-in silencer			

- * The 3/5(E) port is plugged for the built-in silencer type.
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

A R port cize (Metric/One-touch fitting)

U A, I	A, B port size (wetric/One-touch fitting)						
Symbol		A, B port	JSY1000	JSY3000	JSY5000		
C2		ø2	•	_	_	~£?	
C4		ø4	•	•	_		
C6	ᆂ	ø6	•	•	•		
C8	Straight	ø8	_	•	•		
C10		ø10	_	_	•		
C12		ø12	_	_	•	00	
CM*1		Straight port, mixed sizes	•	•	•	- Ordina	
	P, E port size (One-touch fittings)			ø10	ø12		

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

Mounting and Option


Symbol	Mounting Mounting			
Nil	Direct mounting			
D□	DIN rail mounting			

- * Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- * Refer to page 160 for details on securing the DIN rail mounting type manifold.

DIN Poil Ontion

Ľ	DIN Hall Option						
ı	Nil	DIN rail mounting (With DIN rail)					
ı	0	DIN rail mounting (Without DIN rail)					
١	3	For 3 stations	0				
ı	- :		Specify a length longer that of the standard rail.				
1	24	For 24 stations	Tinat of the Standard fall.				

How to Order Manifold Assembly



JJ5SY3-10TC-05D-C8 ··· 1 set (Type 10 5-station manifold base part no.)

* JSY3100-5U 2 sets (2-position single part no.) JSY3200-5U 3 sets (2-position double part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the valve, etc.


For the valve arrangement, the valve closest to the D side is considered the 1st station.

Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 Series JSY1000 JSY3000 JSY5000

5

2 Type of actuation Single 2-position Double 3 Closed center 4 3-position Exhaust center 5 Pressure center Δ N.C./N.C.

N.O./N.O.

N.C./N.O.

4-position

dual 3-port

Coil specifications

:	Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
	Nil	Standard	_	•	•
	Т	With power-saving circuit (Continuous duty type)	•	•	•

- * For the JSY1000 series, only the power-saving circuit specification is available
- Be careful of the energizing time when the power-saving circuit is selected For details, refer to page 158

4 Light/surge voltage suppressor and common specification

B

С

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

- * When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.
- * Only "Z" and "NZ" types are available with a power saving circuit.

Manual override

o Manual override			
Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- When ordering a valve individually, the base gasket is not included. Since the base gasket is attached to the manifold, please order the

base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.






Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to 02 and 04 fittings)
Spring Type Terminal Block Box

JJ5SY1-10TC-Stations U-C4(D)









- * These figures show the "JJ5SY1-10TC-05D-C4."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions

L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	138.5	145	151.5	158	164.5	171	177.5	184	190.5	197	203.5	210	216.5	223	229.5
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	173	173	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5
L4	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5	225	225	237.5	237.5	250
L5	17.5	14	17	14	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5


	17	18	19	20	21	22	23	24
L1	236	242.5	249	255.5	262	268.5	275	281.5
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	260.5	273	273	285.5	285.5	298	310.5	310.5
L4	250	262.5	262.5	275	275	287.5	300	300
L5	12.5	15.5	12	15	12	15	18	14.5


Dimensions: JSY1000 Series

JJ5SY1-10TC-Stations P-C6(D)

Spring Type Terminal Block Box







- * These figures show the "JJ5SY1-10TC-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dim	ension	ıs												r	: Stations
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	140 E	150 F	101 E	170 5	170 E	100 E	107 F	000 F	0155	004 E	000 F	040 5	051.5	000 F	000 E


L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	143.5	152.5	161.5	170.5	179.5	188.5	197.5	206.5	215.5	224.5	233.5	242.5	251.5	260.5	269.5
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	173	185.5	185.5	198	210.5	223	223	235.5	248	248	260.5	273	285.5	285.5	298
L4	162.5	175	175	187.5	200	212.5	212.5	225	237.5	237.5	250	262.5	275	275	287.5
L5	15	16.5	12	14	15.5	17.5	13	14.5	16.5	12	13.5	15.5	17	12.5	14.5


L_n	17	18	19	20	21	22	23	24
L1	278.5	287.5	296.5	305.5	314.5	323.5	332.5	341.5
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	310.5	323	323	335.5	348	348	360.5	373
L4	300	312.5	312.5	325	337.5	337.5	350	362.5
L5	16	18	13.5	15	17	12.5	14	16

Dimensions: JSY3000 Series

Type 10/Side Ported
Spring Type Terminal Block Box

JJ5SY3-10TC-Stations D-C6 (D)





- * These figures show the "JJ5SY3-10TC-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions n. Stations 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 146.1 157.6 169.1 180.6 192.1 203.6 215.1 226.6 238.1 249.6 261.1 272.6 284.1 295.6 307.1 L2 66.1 77.6 89.1 100.6 112.1 123.6 135.1 146.6 158.1 169.6 181.1 192.6 204.1 215.6 227.1 L3 173 185.5 198 210.5 223 235.5 248 260.5 273 273 285.5 298 310.5 323 335.5 L4 162.5 175 187.5 200 212.5 225 237.5 250 262.5 262.5 275 287.5 300 312.5 325

17

17.5

11.5

12

12.5

13

13.5

14

16.5

	17	18	19	20	21	22	23	24
L1	318.6	330.1	341.6	353.1	364.6	376.1	387.6	399.1
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	348	360.5	373	385.5	398	410.5	423	423
L4	337.5	350	362.5	375	387.5	400	412.5	412.5
15	14.5	15	15.5	16	16.5	17	17.5	12

15

15.5

16

L5

13.5


14


14.5

Dimensions: JSY5000 Series

Type 10/Side Ported Spring Type Terminal Block Box







- * These figures show the "JJ5SY5-10TC-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

I · Dimensions

n: Stations


_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5	325.5	341.5	357.5	373.5	389.5
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	198	210.5	223	248	260.5	273	285.5	310.5	323	335.5	360.5	373	385.5	398	423
L4	187.5	200	212.5	237.5	250	262.5	275	300	312.5	325	350	362.5	375	387.5	412.5
L5	16.5	14.5	13	17.5	15.5	14	12	16.5	15	13	17.5	16	14	12.5	17


L n	17	18	19	20	21	22	23	24
L1	405.5	421.5	437.5	453.5	469.5	485.5	501.5	517.5
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	435.5	448	473	485.5	498	510.5	535.5	548
L4	425	437.5	462.5	475	487.5	500	525	537.5
L5	15	13.5	18	16	14.5	12.5	17	15.5

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 02 and 04 fittings)
Terminal Block Box

JJ5SY1-10T-Stations U-C2(D)





- * These figures show the "JJ5SY1-10T-05D-C4."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions n: Stations 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 159.8 166.3 172.8 179.3 185.8 192.3 198.8 205.3 211.8 218.3 224.8 231.3 237.8 244.3 250.8 L2 56.4 62.9 69.4 75.9 82.4 88.9 95.4 101.9 108.4 114.9 121.4 127.9 134.4 140.9 147.4 L3 185.5 198 198 210.5 210.5 223 223 235.5 235.5 248 248 260.5 273 273 285.5 L4 175 187.5 187.5 200 200 212.5 212.5 225 237.5 237.5 250 262.5 262.5 275 225 L5 13 16 13 16 13 16 12 15 12 15 12 15 18 15 18


_ n	17	18	19	20
L1	257.3	263.8	270.3	276.8
L2	153.9	160.4	166.9	173.4
L3	285.5	298	298	310.5
L4	275	287.5	287.5	300
L5	14	17	14	17


Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to Ø6 fittings)
Terminal Block Box



JJ5SY1-10T-Stations P-C6(D)





- * These figures show the "JJ5SY1-10T-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


L	.: Dim	: Dimensions n: Stations														
_		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	L1	164.8	173.8	182.8	191.8	200.8	209.8	218.8	227.8	236.8	245.8	254.8	263.8	272.8	281.8	290.8
	L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
	L3	198	198	210.5	223	235.5	235.5	248	260.5	260.5	273	285.5	298	298	310.5	323
	L4	187.5	187.5	200	212.5	225	225	237.5	250	250	262.5	275	287.5	287.5	300	312.5
	L5	17	12	14	16	18	13	15	17	12	14	16	17	13	15	16


_ n	17	18	19	20
L1	299.8	308.8	317.8	326.8
L2	196.4	205.4	214.4	223.4
L3	323	335.5	348	360.5
L4	312.5	325	337.5	350
L5	12	14	15	17

Dimensions: JSY3000 Series

Type 10/Side Ported
Terminal Block Box

JJ5SY3-10T-Stations D-C6 (D)





- * These figures show the "JJ5SY3-10T-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.


L	:: Dimensions n: Stations															
ì	/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	L1	167.4	178.9	190.4	201.9	213.4	224.9	236.4	247.9	259.4	270.9	282.4	293.9	305.4	316.9	328.4
	L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
	L3	198	210.5	223	235.5	248	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5
	L4	187.5	200	212.5	225	237.5	237.5	250	262.5	275	287.5	300	312.5	325	337.5	350
	L5	16	16	17	17	18	12	12	13	13	14	14	15	15	16	16


_ n	17	18	19	20
L1	339.9	351.4	362.9	374.4
L2	238.6	250.1	261.6	273.1
L3	373	385.5	398	398
L4	362.5	375	387.5	387.5
L5	17	17	18	12

Dimensions: JSY5000 Series

Type 10/Side Ported Terminal Block Box

JJ5SY5-10T-Stations D-C66 (D)





- * These figures show the "JJ5SY5-10T-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions n. Stations

L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	186.8	202.8	218.8	234.8	250.8	266.8	282.8	298.8	314.8	330.8	346.8	362.8	378.8	394.8	410.8
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	210.5	235.5	248	260.5	285.5	298	310.5	323	348	360.5	373	398	410.5	423	435.5
L4	200	225	237.5	250	275	287.5	300	312.5	337.5	350	362.5	387.5	400	412.5	425
L5	12	16.5	14.5	13	17.5	15.5	14	12	16.5	15	13	17.5	16	14	12.5

	17	18	19	20
L1	426.8	442.8	458.8	474.8
L2	325.5	341.5	357.5	373.5
L3	460.5	473	485.5	498
L4	450	462.5	475	487.5
L5	17	15	13.5	11.5



C12: ø12 (SMC)

Spring Type Terminal Block "TC" Connection

Step 1. Remove the terminal block cover. Loosen the 4 mounting screws (M3) to remove the terminal block cover. Mounting screw (M3) Gasket Drip proof plug (SY30M-133-1)

Step 3. Mount the terminal block cover.

is mounted

Tightening torque: 0.8 N-m


Securely tighten the mounting screws (M3) to the torque shown below only after confirming that the gasket is installed correctly.

Proper tightening torque [N·m]

0.54 to 0.66


Step 2. The diagram below shows the terminal block wiring. All stations are provided with double wiring regardless of the mounted valves.

Connect each wire to the power supply side, according to the markings provided inside the terminal block. Be sure to connect the wire with the push button pressed down.



0.54 to 0.66 • Applicable wire range: Conductor diameter ø0.5 to ø1.2 mm, Stranded wire AWG24 to 16

Electrical Wiring Specifications (IP67 compliant)




If alignment is not specified, the internal wiring will be double wiring (connected to SOL. a and SOL. b) regardless of number of stations, valve types, and option types.

 When using a valve with no polarity, either positive common or negative common can be used.

Standard wiring						
		ninal i	no. Pol	arity		
٢	SOL.a _o	1A	(-)	(+)		
Station 1	SOL.b _o	1B	(-)	(+)		
f	SOL.a _o	2A	(-)	(+)		
Station 2	SOL.b	2B	(-)	(+)		
a f	SOL.a _o	ЗА	(-)	(+)		
Station 3	SOL.b _o	3B	(-)	(+)		
(°	SOL.a _o	4A	(-)	(+)		
Station 4	SOL.b _o	4B	(-)	(+)		
ا ما الما الما	SOL.a _o	5A	(-)	(+)		
Station 5	m SOL.b	5B	(-)	(+)		
Station 6	SOL.a	6A	(-)	(+)		
Station 67,	-mSOL.b	6B	(-)	(+)		
Station 7	SOL.a	7A	(-)	(+)		
Station /)	SOL.b	7B	(-)	(+)		
Station 8	SOL.a _o	8A	(-)	(+)		
Station 87	SOL.b	8B	(-)	(+)		
Station 9 (SOL.a	9A	(-)	(+)		
Station 9 (SOL.b	9B	(-)	(+)		
Station 10 (SOL.a SOL.b	10A	(-)	(+)		
Station to (601.0	10B	(-)	(+)		
Station 11	eol b	11A	(-)	(+)		
olation in [,	SOL.a	11B	(-)	(+)		
Station 12 (SOL.b	12A	(-)	(+)		
- L.	SOL.a	12B	(-)	(+)		
Station 13	SOL.b	13A	(-)	(+)		
	601.0	13B	(-)	(+)		
Station 14	eol b	14A	(-)	(+)		
	m SOL.a	14B	(-)	(+)		
Station 15 (SOL.b	15A	(-)	(+)		
(-	001	15B	(-)	(+) (+)		
Station 16	001 6	16A	(-)			
Ç	· · · · · · · · · · · · · · · · · · ·	16B	(-)	(+)		
		сом.	(+)	(-)		
		COM.		(-)		
			Positive	Negative		
			common	common		

Specified Layout

A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 32 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.






Terminal Block "T" Connection


Step 1. Remove the terminal block cover.

Loosen the 4 mounting screws (M4) to remove the terminal block cover.



Step 2. The diagram below shows the terminal block wiring. All stations are provided with double wiring regardless of the mounted valves.

Connect each wire to the power supply side, according to the markings provided inside the terminal block.




Step 3. Mount the terminal block cover.

Securely tighten the screws to the torque shown below only after confirming that the gasket is installed correctly.

Proper tightening torque [N·m] 0.7 to 1.2


- Applicable crimped terminal: 1.25-3S, 1.25Y-3, 1.25Y-3N, 1.25Y-3.5
- Name plate: VVQ5000-N-T
- Drip proof plug assembly (for G3/4): AXT100-B06A

Electrical Wiring Specifications (IP67 compliant)



Specified Layout

A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 20 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.





Plug-in Connector Connecting Base

Lead Wire

Type 10 Side Ported

JSY1000/3000/5000 Series


(E UK ROHS





Internal Pilot

How to Order Manifolds



Made to Order (Refer to page 156 for details.) Specification External pilot (SUP/EXH block assembly)

Series JSY1000 JSY3000 JSY5000

10 Side ported Valve stations

L1□	: 34 cc	ores	L2□	: 17 cc	ores
Symbol	Stations	Note	Symbol	Stations	Note
02	2 stations		02	2 stations	
- :	: :	Double wiring*1	:		Double wiring*1
16	16 stations	·	08	8 stations	
02	2 stations	Specified layout*2	02	2 stations	Specified layout*2
- :		(Up to 32	:		(Up to 16
24	24 stations	solenoids available)	16	16 stations	solenoids available)
	1 -				

3 Number of cores (Lead wire)

L1	34 cores
L2	17 cores
L3	9 cores

4	Lead	wire	length

1	0.6 m
2	1.5 m
3	3 m

6 P, E port entry

U	U side (2 to 10 stations)					
D D side (2 to 10 stations)						
В	Both sides (2 to 24 stations)					

SUP/EXH block assembly

Nil	Internal pilot
S	Internal pilot, Built-in silencer

- * The 3/5(E) port is plugged for the built-in silencer type.
- * When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

A B port size (Metric/One-touch fitting)

O A,	Вþ	ort size (ivie				
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	_	_	200
C4		ø4	•	•	_	
C6	ᆂ	ø6	•	•	•	
C8	raight	ø8	_	•	•	
C10	ŝ		_	_	•	
C12		ø12	_	_	•	00
CM*1		Straight port, mixed sizes	•	•	•	OF Gar
		port size uch fittinas)	ø8	ø10	ø12	

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

Symbol S	Stations	Note
		Note
02 2	2 stations	
:		Double wiring*1
04	4 stations	
02	2 stations	Specified layout*2
:	- :	Up to 8
08	8 stations	solenoids available)

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations.
 - The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- *3 This also includes the number of blanking plates.


Mounting and Option

_	
Symbol	Mounting
Nil	Direct mounting
D□	DIN rail mounting

- * Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- * Refer to page 160 for details on securing the DIN rail mounting type manifold.

ווע המו	DIN HAII OPLION											
Nil	DIN rail mounting (With DIN rail)											
0	DIN rail	DIN rail mounting (Without DIN rail)										
3	For 3 stations	0										
:	:	Specify a length longer than that of the standard rail.										
24	For 24 stations	that of the standard rail.										

How to Order Manifold Assembly




For the valve arrangement, the valve closest to the D side is considered the 1st station.

Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 JSY1000 3 JSY3000 5 JSY5000

2 Type of actuation

1	2-position	Single					
2	2-position	Double					
3		Closed center					
4	3-position	Exhaust center					
5		Pressure center					
Α	4	N.C./N.C.					
В	4-position dual 3-port	N.O./N.O.					
С	duai 5-poit	N.C./N.O.					

3 Coil specifications

[Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
	Nil	Standard	_	•	•
	Т	With power-saving circuit (Continuous duty type)	•	•	•

- For the JSY1000 series, only the power-saving circuit specification is available.
- Be careful of the energizing time when the power-saving circuit is selected.
 For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

- When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.
- * Only "Z" and "NZ" types are available with a power saving circuit.

6 Manual override

o Manual override			
Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- When ordering a valve individually, the base gasket is not included.

 Since the base gasket is attached to the manifold, please order the

base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.



If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.







Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to @2 and @4 fittings)
Lead Wire

JJ5SY1-10L $\frac{1}{2}$ \square - Stations $\stackrel{\text{U}}{\text{P}}$ - $\stackrel{\text{C2}}{\text{C4}}$ (D)









- * These figures show the "JJ5SY1-10L1□-05D-C4."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions

_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	107.5	114	120.5	127	133.5	140	146.5	153	159.5	166	172.5	179	185.5	192	198.5
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	148	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223	223
L4	125	137.5	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5	212.5
L5	14	17	14	17	13.5	16.5	13.5	16.5	13	16	13	16	12.5	15.5	12.5


L n	17	18	19	20	21	22	23	24
L1	205	211.5	218	224.5	231	237.5	244	250.5
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	235.5	235.5	248	248	260.5	273	273	285.5
L4	225	225	237.5	237.5	250	262.5	262.5	275
L5	15.5	12	15	12	15	18	14.5	17.5


Dimensions: JSY1000 Series


Type 10/Side Ported (Applicable to o6 fittings)
Lead Wire

JJ5SY1-10L 2 - Stations U-C6(D)









- * These figures show the "JJ5SY1-10L1□-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dimensions n: Stations

	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	112.5	121.5	130.5	139.5	148.5	157.5	166.5	175.5	184.5	193.5	202.5	211.5	220.5	229.5	238.5
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	148	148	160.5	173	173	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5	273
L4	137.5	137.5	150	162.5	162.5	175	187.5	200	200	212.5	225	225	237.5	250	262.5
L5	18	13.5	15	17	12.5	14	16	17.5	13	15	16.5	12	14	15.5	17.5


_ n	17	18	19	20	21	22	23	24
L1	247.5	256.5	265.5	274.5	283.5	292.5	301.5	310.5
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	273	285.5	298	298	310.5	323	335.5	335.5
L4	262.5	275	287.5	287.5	300	312.5	325	325
L5	13	14.5	16.5	12	13.5	15.5	17	12.5


Dimensions: JSY3000 Series


Type 10/Side Ported Lead Wire

JJ5SY3-10L $\frac{1}{2}$ - Stations $\stackrel{\text{U}}{\text{Stations}}$ - $\stackrel{\text{C}_6^4}{\text{C}_6^6}$ (D)









- * These figures show the "JJ5SY3-10L1□-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.


ı	L: Dim	ension	ıs												r	n: Stations
		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	L1	115.1	126.6	138.1	149.6	161.1	172.6	184.1	195.6	207.1	218.6	230.1	241.6	253.1	264.6	276.1


L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	115.1	126.6	138.1	149.6	161.1	172.6	184.1	195.6	207.1	218.6	230.1	241.6	253.1	264.6	276.1
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	148	160.5	173	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5
L4	137.5	150	162.5	162.5	175	187.5	200	212.5	225	237.5	250	262.5	275	287.5	300
L5	16.5	17	17.5	11.5	12	12.5	13	13.5	14	14.5	15	15.5	16	16.5	17

_ r	17	18	19	20	21	22	23	24
L1	287.6	299.1	310.6	322.1	333.6	345.1	356.6	368.1
L2	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1
L3	323	323	335.5	348	360.5	373	385.5	398
L4	312.5	312.5	325	337.5	350	362.5	375	387.5
L5	17.5	12	12.5	13	13.5	14	14.5	15

Dimensions: JSY5000 Series

Type 10/Side Ported
Lead Wire





- * These figures show the "JJ5SY5-10L1□-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

C10: ø10 (SMC)

C12: ø12 (SMC)

L: Dimensions n: Stations <u>_</u> n 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 134.5 150.5 166.5 182.5 198.5 214.5 230.5 246.5 262.5 278.5 294.5 310.5 326.5 342.5 358.5 L2 85.5 101.5 117.5 133.5 149.5 165.5 181.5 197.5 213.5 229.5 245.5 261.5 277.5 293.5 309.5 L3 173 185.5 198 210.5 235.5 248 260.5 285.5 298 310.5 323 348 360.5 373 398 L4 162.5 187.5 200 287.5 300 312.5 337.5 362.5 387.5 175 225 237.5 250 275 350 L5 19.5 17.5 16 14 18.5 17 15 19.5 18 16 14.5 19 17 15.5 20

_ n	17	18	19	20	21	22	23	24
L1	374.5	390.5	406.5	422.5	438.5	454.5	470.5	486.5
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	410.5	423	435.5	460.5	473	485.5	510.5	523
L4	400	412.5	425	450	462.5	475	500	512.5
L5	18	16.5	14.5	19	17.5	15.5	20	18.5

Electrical Wiring Specifications

Lead wire

34 cores Lead wire AWG26 (0.14 mm²) x 34 cores

If alignment is not specified, the internal wiring will be double wiring (connected to SOL. a and SOL. b) regardless of number of stations, valve types, and option types.

Sheath O.D. Approx. ø8.8

			Lead wire	Printed n (Both sid	
Lead v	vire no.	Polarity	color	Type	
CSOL.a_o		(.)	COIOI	туре	Color
Station 1 SOL.b	1 (-) 2 (-)	. ,	Orange	-	Red
SOL.a	- ()	. ,			
Station 2 SOL.b	3 (-) 4 (-)	. ,	Light gray	_	Red Black
SOL.a	. ()	. ,	gray		
Station 3 SOL.b	5 (-) 6 (-)	. ,	White	-	Red
SOL.a	- ()	. ,			Black
Station 4 SOL.b	7 (-) 8 (-)	. ,	Yellow	-	Black
SOL.a	9 (-)				Red
Station 5	0 (-)	. ,	Pink	-	Black
SOL.a 1	1 (-)				Red
Station 6 SOL.b	2 (-)	. ,	Orange		Black
C SOLa 1	3 (-)	. ,	Light		Red
	4 (-)	(+)	gray		Black
SOL.a o 1	5 (-)				Red
Station 8 (SOL.b 1	6 (-)	(+)	White		Black
Station 9 SOL b	7 (-)	(+)	Yellow		Red
(8 (-)	(+)	Yellow		Black
Station 10 SOL.b	9 (-)	(+)	Pink		Red
((+)	FIIK		Black
Station 11 SOL.a SOL.b		(+)	Orange		Red
Station 11 (m SOL.b o 2	22 (-)	(+)	Orange		Black
Station 12	. ,	(+)	Light		Red
Station 12 (m SOL.b o 2	24 (-)	(+)	gray		Black
Station 13	25 (-)	(+)	White		Red
SOL.a 2	26 (-)	(+)	William		Black
Station 14	27 (-)	(+)	Yellow		Red
SOLA o	28 (–)	(+)	10.1011		Black
Station 15	. ,	(+)	Pink		Red
(F7777 eol e	30 (–)	(+)			Black
Station 16 SOL.a 3	31 (–)	(+)	Orange		Red
COM.	32 (-)	(+)	Clarige		Black
COM 3	3 (+)	(-)	Light		Red
O 3	34 (+)	(-)	gray		Black

Electrical characteristics

Item	Property
Conductor resistance Ω/km, 20°C	143 or less
Voltage limit V, 1 minute, AC	2000
Insulation resistance MΩ/km, 20°C	10 or more

* Cannot be used for movable wiring The minimum bending radius of the cable is 55 mm.


* For negative common specification, a valve for negative common or a valve without polarity should be used.

Specified Layout

Positive Negative common common

A mixture of single and double wiring can be specified on the manifold specification sheet. The maximum number of stations is determined according to the number of solenoids. The total number of solenoids should be 32 or less. 1 solenoid is required for the 2-position single, and 2 solenoids for the 2-position double, 3-position, and 4-position.





Plug-in Connector Connecting Base

EX600






JSY1000/3000/5000 Series

Internal Pilot

Type 10 Side Ported

How to Order Manifolds



A Sarias

U Jeiles							
1	JSY1000						
3	JSY3000						
5	JSY5000						

Type

Side ported

3 SI unit

0	Without SI unit					
Q	DeviceNet®					
N	PROFIBUS DP					
V	CC-Link					
EB	EB EtherNet/IP™ (IO-Link unit)					
DA	EtherCAT (IO-Link unit)					
FA	PROFINET (IO-Link unit)					
FB	PROFINET (OPC UA, IO-Link unit)					
1.0	Only negative common					
ws	Wireless remote*1					

- *1 The wireless system is suitable for use only in a country where it is in accordance with the Radio Act and regulations of that country.
- I/O unit cannot be mounted without SI unit.
- * Valve plate which connects manifold and SI unit is included, but it is not mounted to a valve without SI unit For mounting, refer to the EX600 series on page 129.

SI unit output polarity. End plate type (Part no.)

SI unit output	M12 power supply	7/8 inch	M12 power su IN/OUT,	pply connector A-coded		
polarity	connector B-coded (EX600-ED2)	power supply connector (EX600-ED3)	Pin arrangement 1 (EX600-ED4)			
Without SI unit	Nil					
SI unit positive common	2	3	6	8		
SI unit negative common	4	5	7	9		

- * Ensure a match with the common specification of the valve to be used.
- When not selecting an SI unit, the symbol will be "nil."

6 I/O unit stations

Nil	None					
1	1 station					
:	:					
9	9 stations					

- When not selecting an SI unit, the symbol will he "nil '
- SI unit is not included in I/O unit stations.
- * When I/O unit is selected, it is shipped separately, and assembled by users. Refer to the attached operation manual for mounting.

Made to Order (Refer to page 156 for details.)

Specification External pilot (SUP/EXH block assembly)

A Valve stations

• 41.00	314110113					
Stations	Note					
2 stations						
:	Double wiring*1					
16 stations						
2 stations	Considered Involves:					
:	Specified layout*2 (Up to 32 solenoids available)					
24 stations	(Op to 32 soleriolds available)					
	Stations 2 stations : 16 stations 2 stations ::					

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- * This also includes the number of blanking

P. E port entry, SUP/EXH block assembly

• . , = p , ,		,
P, E port entry	Internal pilot	Internal pilot, Built-in silencer
U side (2 to 10 stations)	U	С
D side (2 to 10 stations)	D	E
Both sides (2 to 24 stations)	В	F

- * The 3/5(E) port is plugged for the built-in silencer type.
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156

A. B port size (Metric/One-touch fitting)

<u> </u>	٠,	011 0120 (1110				
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	_	_	20/2
C4		ø4	•	•	_	
C6	ᆂ	ø6	•	•	•	
C8	Straight	ø8	_	•	•	
C10	ŝ	ø10	_	_	•	0
C12		ø12	_	_	•	00
CM*1		Straight port, mixed sizes	•	•	•	O Com
		port size uch fittings)	ø8	ø10	ø12	

*1 Indicate the sizes on the manifold specification sheet in the case of "CM." * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

Mounting and Option

•	a a p
Symbol	Mounting
Nil	Direct mounting
D□	DIN rail mounting

- * Enter the number of stations inside \square when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold


DIN Bail Ontion

Nil	DIN rail r	DIN rail mounting (With DIN rail) DIN rail mounting (Without DIN rail)												
0	DIN rail n													
3	For 3 stations	Specify a length longer than												
:	:	that of the standard rail.												
24	For 24 stations	triat of the standard fail.												

If the DIN rail must be mounted without an SI unit, select D0. Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

For details on the EX600 Integrated Type (For Input/Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to pages 129 and 130. (IP40 specifications may be required according to the I/O unit to be selected.) Please download the Operation Manual via the SMC website, https://www.smcworld.com

How to Order Manifold Assembly



→The asterisk denotes the symbol for the assembly.


Prefix it to the part numbers of the valve, etc.


- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted, then the I/O units in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- *1 Do not enter the SI unit part number and the end plate part number together.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 Series

1	JSY1000
3	JSY3000
5	JSY5000

2 Type of actuation

1	2-position	Single						
2	2-position	Double						
3		Closed center						
4	3-position	Exhaust center						
5		Pressure center						
Α	4	N.C./N.C.						
В	4-position dual 3-port	N.O./N.O.						
С	duai 5-poit	N.C./N.O.						

3 Coil specifications

Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
Nil	Standard	_	•	•
Т	With power-saving circuit (Continuous duty type)	•	•	•

- * For the JSY1000 series, only the power-saving circuit specification is available.
- * Be careful of the energizing time when the power-saving circuit is selected.
- For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

* Only "Z" and "NZ" types are available with a power saving circuit.

6 Manual override

Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.






If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.




Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to @2 and @4 fittings) EX600 (M12 Con







L1 = 6.5 x n1 + 139 + 47 x n2

L2 = 6.5 x n1 + 43.4

L4 = L3 - 10.5


L5 = (L3 - L1) / 2L6 = 47 x n2 + 83.8

n1: Valve stations

n2: I/O unit stations

- * These figures show the "JJ5SY1-10S6Q22-05D-C4."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	298	298	310.5	310.5	323	323
1	223	235.5	235.5	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373
2	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	385.5	385.5	398	398	410.5	410.5	423
3	323	323	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5
4	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	473	473	485.5	485.5	498	498	510.5	510.5
5	410.5	423	435.5	435.5	448	448	460.5	460.5	473	473	485.5	485.5	498	498	510.5	510.5	523	523	535.5	535.5	548	548	560.5
6	460.5	473	473	485.5	485.5	498	498	510.5	510.5	523	523	535.5	535.5	548	560.5	560.5	573	573	585.5	585.5	598	598	610.5
7	510.5	523	523	535.5	535.5	548	548	560.5	560.5	573	573	585.5	585.5	598	598	610.5	610.5	623	623	635.5	635.5	648	648
8	560.5	560.5	573	573	585.5	585.5	598	598	610.5	610.5	623	623	635.5	648	648	660.5	660.5	673	673	685.5	685.5	698	698
9	610.5	610.5	623	623	635.5	635.5	648	648	660.5	660.5	673	673	685.5	685.5	698	698	710.5	710.5	723	723	735.5	735.5	748



- L1 = 9 x n1 + 139 + 47 x n2 L2 = 9 x n1 + 43.4
- L4 = L3 10.5
- L5 = (L3 L1) / 2L6 = 47 x n2 + 83.8
- n1: Valve stations
- n2: I/O unit stations

- * These figures show the "JJ5SY1-10S6Q22-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	360.5	373	385.5
1	235.5	248	248	260.5	273	273	285.5	298	310.5	310.5	323	335.5	335.5	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5
2	285.5	285.5	298	310.5	310.5	323	335.5	348	348	360.5	373	385.5	385.5	398	410.5	410.5	423	435.5	448	448	460.5	473	473
3	323	335.5	348	360.5	360.5	373	385.5	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5	498	510.5	510.5	523
4	373	385.5	398	398	410.5	423	423	435.5	448	460.5	460.5	473	485.5	485.5	498	510.5	523	523	535.5	548	560.5	560.5	573
5	423	435.5	435.5	448	460.5	460.5	473	485.5	498	498	510.5	523	535.5	535.5	548	560.5	560.5	573	585.5	598	598	610.5	623
6	473	473	485.5	498	510.5	510.5	523	535.5	535.5	548	560.5	573	573	585.5	598	598	610.5	623	635.5	635.5	648	660.5	660.5
7	510.5	523	535.5	548	548	560.5	573	573	585.5	598	610.5	610.5	623	635.5	635.5	648	660.5	673	673	685.5	698	710.5	710.5
8	560.5	573	585.5	585.5	598	610.5	610.5	623	635.5	648	648	660.5	673	685.5	685.5	698	710.5	710.5	723	735.5	748	748	760.5
9	610.5	623	623	635.5	648	660.5	660.5	673	685.5	685.5	698	710.5	723	723	735.5	748	748	760.5	773	785.5	785.5	798	810.5


Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 02 and 04 fittings)

EX600 (7/8 Inch Connector)



JJ5SY1-10S6 _ 3 _ - Stations D - C2 (D)



L1 = 6.5 x n1 + 155.5 + 47 x n2

L2 = 6.5 x n1 + 43.4

L4 = L3 - 10.5L5 = (L3 - L1) / 2

 $L6 = 47 \times n2 + 83.8$

n1: Valve stations

n2: I/O unit stations

* These figures show the "JJ5SY1-10S6Q32-05D-C4."

* Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.

* When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.


Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5
1	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5
2	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5
3	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	473	485.5
4	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	473	485.5	485.5	498	498	510.5	510.5	523	523
5	435.5	435.5	448	448	460.5	460.5	473	473	485.5	485.5	498	510.5	510.5	523	523	535.5	535.5	548	548	560.5	560.5	573	573
6	485.5	485.5	498	498	510.5	510.5	523	523	535.5	535.5	548	548	560.5	560.5	573	573	585.5	585.5	598	598	610.5	610.5	623
7	523	535.5	535.5	548	548	560.5	560.5	573	573	585.5	598	598	610.5	610.5	623	623	635.5	635.5	648	648	660.5	660.5	673
8	573	585.5	585.5	598	598	610.5	610.5	623	623	635.5	635.5	648	648	660.5	660.5	673	673	685.5	685.5	698	698	710.5	723
9	623	623	635.5	635.5	648	648	660.5	660.5	673	685.5	685.5	698	698	710.5	710.5	723	723	735.5	735.5	748	748	760.5	760.5

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to Ø6 fittings EX600 (7/8 Inch Connector)

JJ5SY1-10S6 - 3 - Stations 2 - C6(D)





L1 = 9 x n1 + 155.5 + 47 x n2

L2 = 9 x n1 + 43.4

L4 = L3 - 10.5

L5 = (L3 - L1) / 2L6 = 47 x n2 + 83.8

n1: Valve stations


n2: I/O unit stations


- These figures show the "JJ5SY1-10S6Q32-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	198	210.5	223	235.5	235.5	248	260.5	260.5	273	285.5	298	298	310.5	323	323	335.5	348	360.5	360.5	373	385.5	398	398
1	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	373	373	385.5	398	398	410.5	423	435.5	435.5	448
2	298	310.5	310.5	323	335.5	348	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5	435.5	448	460.5	473	473	485.5	498
3	348	348	360.5	373	385.5	385.5	398	410.5	410.5	423	435.5	448	448	460.5	473	473	485.5	498	510.5	510.5	523	535.5	548
4	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5	498	510.5	523	523	535.5	548	548	560.5	573	585.5	585.5
5	435.5	448	460.5	460.5	473	485.5	498	498	510.5	523	523	535.5	548	560.5	560.5	573	585.5	585.5	598	610.5	623	623	635.5
6	485.5	498	498	510.5	523	535.5	535.5	548	560.5	560.5	573	585.5	598	598	610.5	623	623	635.5	648	660.5	660.5	673	685.5
7	535.5	535.5	548	560.5	573	573	585.5	598	598	610.5	623	635.5	635.5	648	660.5	673	673	685.5	698	698	710.5	723	735.5
8	573	585.5	598	610.5	610.5	623	635.5	648	648	660.5	673	673	685.5	698	710.5	710.5	723	735.5	735.5	748	760.5	773	773
9	623	635.5	648	648	660.5	673	685.5	685.5	698	710.5	710.5	723	735.5	748	748	760.5	773	773	785.5	798	810.5	810.5	823

Dimensions: JSY3000 Series

Type 10/Side Ported EX600 (M12 Connector)





L1 = 11.5 x n1 + 136.6 + 47 x n2 L2 = 11.5 x n1 + 43.1

L4 = L3 - 10.5 L5 = (L3 - L1) / 2 $L6 = 47 \times n2 + 82$


n1: Valve stations n2: I/O unit stations

- * These figures show the "JJ5SY3-10S6Q22-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

Valve stations (n1) I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448
1	235.5	248	260.5	273	285.5	298	310.5	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5
2	285.5	298	310.5	323	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	473	485.5	498	510.5	523	535.5
3	335.5	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	485.5	498	510.5	523	535.5	548	560.5	573	585.5
4	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5
5	423	435.5	448	460.5	473	485.5	498	510.5	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	648	660.5	673
6	473	485.5	498	510.5	523	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	660.5	673	685.5	698	710.5	723
7	523	535.5	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	673	673	685.5	698	710.5	723	735.5	748	760.5	773
8	560.5	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823
9	610.5	623	635.5	648	660.5	673	685.5	698	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823	835.5	848	848	860.5

Dimensions: JSY3000 Series

Type 10/Side Ported EX600 (7/8 Inch Connector)




L1 = 11.5 x n1 + 153.1 + 47 x n2 L2 = 11.5 x n1 + 43.1

L2 = 11.5 x n1 + 43.1 L4 = L3 - 10.5 L5 = (L3 - L1) / 2

L6 = 47 x n2 + 82 n1: Valve stations n2: I/O unit stations

- * These figures show the "JJ5SY3-10S6Q32-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

Valve stations (n1) I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	223	235.5	248	260.5	273	285.5	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	423	435.5	448	460.5	473
1	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	435.5	448	460.5	473	485.5	498	510.5	523
2	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573
3	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	610.5
4	410.5	423	435.5	448	460.5	473	473	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	623	635.5	648	660.5
5	460.5	473	485.5	485.5	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	635.5	648	660.5	673	685.5	698	710.5
6	498	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5	648	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5
7	548	560.5	573	585.5	598	610.5	623	635.5	648	660.5	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	798
8	598	610.5	623	635.5	648	660.5	673	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	810.5	823	835.5	848
9	648	660.5	673	685.5	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798	810.5	823	823	835.5	848	860.5	873	885.5	898




Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5
1	260.5	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	585.5	610.5
2	298	323	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5
3	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698
4	398	410.5	423	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	710.5	735.5	748
5	448	460.5	473	485.5	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	785.5	798
6	485.5	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848
7	535.5	548	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5
8	585.5	598	610.5	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	910.5	923	935.5
9	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	785.5	810.5	823	835.5	860.5	873	885.5	898	923	935.5	948	973	985.5

Dimensions: JSY5000 Series

Type 10/Side Ported EX600 (7/8 Inch Connector)

JJ5SY5-10S6 3 - Stations



L1 = 16 x n1 + 163.5 + 47 x n2 L2 = 16 x n1 + 53.5

L4 = L3 - 10.5

L5 = (L3 - L1) / 2

L6 = 47 x n2 + 81.5 n1: Valve stations

n2: I/O unit stations

* These figures show the "JJ5SY5-10S6Q32-05D-C12."

* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

Valve stations (n1) I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	423	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573
1	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	598	610.5	623
2	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5	673
3	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	723
4	410.5	423	448	460.5	473	498	510.5	523	535.5	560.5	573	585.5	610.5	623	635.5	648	673	685.5	698	723	735.5	748	760.5
5	460.5	473	498	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	785.5	798	810.5
6	510.5	523	535.5	560.5	573	585.5	598	623	635.5	648	673	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848	860.5
7	548	573	585.5	598	623	635.5	648	660.5	685.5	698	710.5	735.5	748	760.5	773	798	810.5	823	848	860.5	873	885.5	910.5
8	598	623	635.5	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	910.5	923	935.5	948
9	648	660.5	685.5	698	710.5	723	748	760.5	773	798	810.5	823	835.5	860.5	873	885.5	898	923	935.5	948	973	985.5	

Plug-in Connector Connecting Base

Type 10/ Side Ported


JSY3000/5000 Series

(E UK RoHS





How to Order Manifolds



Only direct mounting is selectable for the manifold.



Made to Order

(Refer to page 156 for details.)

Specification	
External pilot	
(SUP/EXH block assembly)	

Series

3	JSY3000
5	JSY5000

2 Type Side ported

SI unit

Symbol (Output polarity) Negative common (PNP)	Protocol	Communication connector	Communication connector specifications			
0	Without SI unit					
AAN		Push/Pull (SCRJ): 2 pcs.	Push/Pull (24 V): 2 pcs.			
ABN	PROFINET	Push/Pull (RJ45): 2 pcs.	Push/Pull (24 V): 2 pcs.			
ACN		M12: 2 pcs.	7/8 inch: 2 pcs.			

* The valve output polarity for the SI unit is negative common (PNP).

With or without I/O modules

Nil	Without I/O module
Υ	With I/O module

* When not selecting an SI unit, the symbol will he "nil "

U side (2 to 10 stations)

D side (2 to 10 stations)

Both sides (2 to 24 stations)

Number of I/O modules

Nil Without I/O module					
1	1 station				
:	:				
8	8 stations				

* When not selecting an SI unit, the symbol will he "nil"

6 Valve stations

Symbol	Stations	Note				
02	2 stations					
:	:	Double wiring*1				
16	16 stations					
02	2 stations	Specified layout*2				
:	:	(Available up to 32				
24	24 stations	solenoids)				
4 Davids while or Consider a shall davids						

- 8 SUP/EXH block assembly Internal pilot Internal pilot, Built-in silencer
- The 3/5(E) port is plugged for the built-in
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.
- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout
- *2 Specified layout: Indicate the wiring specifications on the manifold specification
 - (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of the blanking plate assembly.

A. B port size (Metric)

P, E port entry

В


Symbol		A, B port	JSY3000	JSY5000	Г
C4		ø4 One-touch fitting	•	_	
C6	_	ø6 One-touch fitting	•	•	1
C8	ight	ø8 One-touch fitting	•	•	1
C10	Stra	ø10 One-touch fitting	_	•	1
C12	٠,	ø12 One-touch fitting	_	•]
CM*1		Straight port, mixed sizes	•	•	
P,	Ε	port size (One-touch fittings)	ø10	ø12	

*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

For details on the EX245 Integrated Type (For Input/Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 131. Please download the Operation Manual via the SMC website, https:// www.smcworld.com



How to Order Manifold Assembly



JJSSY3-10SAANY2-05D-C6...1 set (Type 10 5-station manifold base part no.)

* JSY3100-5U......3 sets (2-position single part no.)

The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the valve, etc.


For the valve arrangement, the valve closest to the D side is considered the 1st station.

- The I/O module station arrangement is numbered starting from the SI unit side.
 Under the manifold part number, state the valves to be mounted, then the I/O modules in order starting with the 1st station as shown in the figure. If the
- modules in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.
- *1 Do not enter the SI unit part number and the end plate part number together.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.







2 Type of actuation

1	2-position	Single		
2	2-position	Double		
3		Closed center		
4	3-position	Exhaust center		
5		Pressure center		
Α	4	N.C./N.C.		
В	4-position dual 3-port	N.O./N.O.		
С		N.C./N.O.		

3 Coil specifications

Sy	mbol	Coil specifications	JSY3000	JSY5000
	Nil	Standard	•	•
	Т	With power-saving circuit (Continuous duty type)	•	•

 Be careful of the energizing time when the power-saving circuit is selected.

For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY3000	JSY5000
U			Non-polar	•	•
NZ	•	•	Polar Negative common	•	•

* Only "NZ" type is available with a power saving circuit.

Manual override

Symbol/Specification	JSY3000	JSY5000
Nil: Non-locking push type	•	•
D: Push-turn locking slotted type	•	•
E: Push-turn locking lever type	•	•

∧ Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification. * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.





JSY3000/5000 Series


Dimensions: JSY3000 Series EX245


Type 10/Side Ported


JJ5SY3-10SA - Stations D-C6



C8: ø8 (SMC)







- L1 = 11.5n1 + 168.2 L2 = 11.5n1 + 43.1
- L3 = 54n2 + 113.6

Dimensions

- * These figures show the "JJ5SY3-10SAANY2-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

* The L1 dimension is the dimension without an I/O module. Add 54 mm to this dimension for each I/O module.


Dillicitati	Ulia	- 4	112 15 1	ie nui	nber o	1 1/0 11	louule	Statio	115.														
Valve stations n1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
L1	191.2	202.7	214.2	225.7	237.2	248.7	260.2	271.7	283.2	294.7	306.2	317.7	329.2	340.7	352.2	363.7	375.2	386.7	398.2	409.7	421.2	432.7	444.2
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1	238.6	250.1	261.6	273.1	284.6	296.1	307.6	319.1


Dimensions: JSY5000 Series


Type 10/Side Ported EX245

JJ5SY5-10SA - Stations D C66









C8: Ø8 (SMC) C10: Ø10 (SMC) C12: Ø12 (SMC)

L1 = 16n1 + 178.6 L2 = 16n1 + 53.5 L3 = 54n2 + 113.1

- * These figures show the "JJ5SY5-10SAANY2-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

* The L1 dimension is the dimension without an I/O module. Add 54 mm to this dimension for each I/O module.

Dimensions * n2 is the number of I/O module stations Valve stations n 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 20 21 22 24 18 | 19 210.6 226.6 242.6 258.6 274.6 290.6 306.6 322.6 338.6 354.6 370.6 386.6 402.6 418.6 434.6 450.6 466.6 482.6 498.6 514.6 530.6 546.6 562.6 L1 12 85.5 | 101.5 | 117.5 | 133.5 | 149.5 | 165.5 | 181.5 | 197.5 | 213.5 | 229.5 | 245.5 | 261.5 | 277.5 | 293.5 | 309.5 | 325.5 | 341.5 | 357.5 | 373.5 | 389.5 | 405.5 | 421.5 | 437.5

Plug-in Connector Connecting Base

Type 10 Side Ported

SY1000/3000/5000 Series

The EX250 series is to be discontinued. When designing new equipment and facilities, consider using another series (EX260/EX600) instead.

(E UK ROHS




Made to Order (Refer to page 156 for details.) Specification External pilot (SUP/EXH block assembly)



Internal Pilot

How to Order Manifolds



Series

• ••	
1	JSY1000
3	JSY3000
5	JSY5000

Side ported

<u> </u>	vaive	stations
Symbol	Stations	Note
02	2 stations	
	:	Double wiring*1
16	16 stations	
02	2 stations	Considered laws which
	:	Specified layout*2 (Up to 32 solenoids available)
24	24 stations	(Op to 32 solerious available)

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.) When determining the number of valve stations, note that the maximum number of solenoids for the AS-Interface applicable SI unit specification is as follows.
 - · 8 in/8 out specification: Max. 8 solenoids
 - · 4 in/4 out specification: Max. 4 solenoids
- This also includes the number of blanking
- For the product without the SI unit (S0), note the maximum number of solenoids of the SI unit that will be mounted. If the layout is specified, indicate it on the manifold specification sheet.

3 SI unit

0	Without SI unit								
Q	DeviceNet™ (Negative common)								
TA	AO 1-4	2 isolated	8 in/8 out						
TB	AS-Interface (Negative	common type	4 in/4 out						
TC	common)	1 common	8 in/8 out						
TD	Common	type	4 in/4 out						
ZE	EtherNet/IP™ (Negative common)								

- * Ensure a match with the common specification of the valve to be used.
- Input block cannot be mounted without SI unit.
- * The supply current from the SI unit of AS-Interface applicable 1 power supply system specification to the input block and valve is limited.

4 Input block stations

Nil	None
1	1 station
:	:
8	8 stations

When not selecting an SI unit, the symbol will be "nil." The maximum number of stations is limited for the AS-Interface applicable SI unit.

Input block type

	PNP sensor input	NPN sensor input
Without input block	N	lil
M12, 2 inputs	Α	D
M12, 4 inputs	В	E
M8, 4 inputs	С	F

* When not selecting an SI unit, the symbol will be "nil."

P. E port entry, SUP/EXH block assembly

P, E port entry	Internal pilot	Internal pilot, Built-in silencer
U side (2 to 10 stations)	U	С
D side (2 to 10 stations)	D	E
Both sides (2 to 24 stations)	В	F

- * The 3/5(E) port is plugged for the built-in silencer type.
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- * The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

A P port size (Metric/One-touch fitting)

O A, I	ÞΡ	ort size (ivie	tric/One-	touch iiti	ing)	
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	_	_	150
C4		ø4	•	•	_	
C6	aight	ø6	•	•	•	
C8		ø8	_	•	•	
C10	ts.	ø10	_	_	•	
C12		ø12	_	_	•	00
CM*1		Straight port, mixed sizes	•	•	•	- Ordina
	P, E port size (One-touch fittings)		ø8	ø10	ø12	

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

For details on the EX250 Integrated Type (For Input/Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 133. Please download the Operation Manual via the SMC website, https://www.smcworld.com

wounting and Option					
Symbol	Mounting				
Nil	Direct mounting				
D	DIN rail mounting				


- * Enter the number of stations inside □ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.
- DIN rail mounting (D□) is not available for the product without the SI unit (S0).

DIN Rail Ontion

Nil	DIN ra	DIN rail mounting (With DIN rail)							
0	DIN rail mounting (Without DIN rail								
3	For 3 stations	Cassifi a langth langur than							
	:	Specify a length longer than that of the standard rail.							
24	For 24 stations	triat of the standard rail.							

Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

How to Order Manifold Assembly



- JJSSY3-10SQ1C-05D-C8 ···1 set (Type 10 5-station manifold base part no.)


 * JSY3100-5U ··············3 sets (2-position single part no.)


 * JSY3200-5U ··················2 sets (2-position double part no.)
- The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the valve, etc.
- · For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 JSY1000 3 JSY3000

JSY5000

2 Type of actuation

1	2-position	Single			
2	2-position	Double			
3		Closed center			
4	3-position	Exhaust center			
5		Pressure center			
Α	4	N.C./N.C.			
В	4-position dual 3-port	N.O./N.O.			
С	duai 5-port	N.C./N.O.			

3 Coil specifications

Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
Nil	Standard	_	•	•
Т	With power-saving circuit (Continuous duty type)	•	•	•


- * For the JSY1000 series, only the power-saving circuit specification is available.
- Be careful of the energizing time when the power-saving circuit is selected.
 For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

9	ou. gc	vollage	ouppi coooi u		.c opco.	u.i.
Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
NZ	•	•	Polar Negative common	•	•	•

* Only "NZ" type is available with a power saving circuit.

Manual override



- * Push-turn locking lever type "E" is not available for the JSY1000.
- * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.



⚠ Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.




Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to Ø2 and Ø4 fittings) EX250

JJ5SY1-10S - Stations P-C2 (D)





L2 = 6.5 x n1 + 43.4 L4 = L3 - 10.5

L5 = (L3 - L1) / 2L6 = 21 x n2 + 83.8

n1: Number of valve stations of the JSY1000

n2: Input block stations

- * These figures show the "JJ5SY1-10SQ1A-05D-C4."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.


Valve stations (n1) I/O unit stations (n2)	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	185.5	198	198	210.5	210.5	223	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	298	298	310.5	310.5	323	323
1	198	210.5	210.5	223	223	235.5	235.5	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348
2	223	235.5	235.5	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5
3	248	248	260.5	260.5	273	273	285.5	285.5	298	298	310.5	310.5	323	323	335.5	348	348	360.5	360.5	373	373	385.5	385.5
4	260.5	273	273	285.5	285.5	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5
5	285.5	298	298	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	435.5
6	310.5	310.5	323	323	335.5	335.5	348	348	360.5	360.5	373	373	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448
7	323	335.5	335.5	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473
8	348	360.5	360.5	373	373	385.5	385.5	398	398	410.5	410.5	423	423	435.5	435.5	448	448	460.5	460.5	473	485.5	485.5	498

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 06 fittings)
EX250

JJ5SY1-10S - Stations B-C6(D)





L1 = 9 x n1 + 139 + 21 x n2

L2 = 9 x n1 + 43.4

L4 = L3 - 10.5

L5 = (L3 - L1) / 2 L6 = 21 x n2 + 83.8

n1: Number of valve stations of the JSY1000

n2: Input block stations


- * These figures show the "JJ5SY1-10SQ1A-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


LO. DIIV	iuii C	7 4 6 1 6	411 E	,,,g																			
Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	210.5	223	235.5	235.5	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	360.5	373	385.5
1	210.5	210.5	223	235.5	248	248	260.5	273	285.5	285.5	298	310.5	310.5	323	335.5	348	348	360.5	373	373	385.5	398	410.5
2	223	235.5	248	260.5	260.5	273	285.5	285.5	298	310.5	323	323	335.5	348	360.5	360.5	373	385.5	385.5	398	410.5	423	423
3	248	260.5	273	273	285.5	298	298	310.5	323	335.5	335.5	348	360.5	360.5	373	385.5	398	398	410.5	423	435.5	435.5	448
4	273	285.5	285.5	298	310.5	310.5	323	335.5	348	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5	435.5	448	460.5	473
5	285.5	298	310.5	323	323	335.5	348	360.5	360.5	373	385.5	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5
6	310.5	323	335.5	335.5	348	360.5	360.5	373	385.5	398	398	410.5	423	435.5	435.5	448	460.5	460.5	473	485.5	498	498	510.5
7	335.5	348	348	360.5	373	373	385.5	398	410.5	410.5	423	435.5	435.5	448	460.5	473	473	485.5	498	510.5	510.5	523	535.5
- 8	360.5	360.5	373	385.5	385.5	398	410.5	423	423	435.5	448	448	460.5	473	485.5	485.5	498	510.5	510.5	523	535.5	548	548

Dimensions: JSY3000 Series

Type 10/Side Ported EX250

JJ5SY3-10S - Stations P-C6 (D)





L1 = 11.5 x n1 + 136.6 + 21 x n2

L2 = 11.5 x n1 + 43.1

L4 = L3 - 10.5 L5 = (L3 - L1) / 2

L6 = 21 x n2 + 82

n1: Number of valve stations of the JSY3000

n2: Input block stations

* These figures show the "JJ5SY3-10SQ1A-05D-C8."

* Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.


LO. DIN F	ian C	VCIO	all Le	nyu																			
Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448
1	210.5	223	235.5	248	260.5	273	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	423	435.5	448	460.5
2	235.5	248	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	398	410.5	423	435.5	448	460.5	473	485.5
3	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5	373	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5
4	273	285.5	298	310.5	323	335.5	348	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	485.5	498	510.5	523
5	298	310.5	323	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	460.5	473	485.5	498	510.5	523	535.5	548
6	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	573
7	335.5	348	360.5	373	385.5	398	410.5	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5	560.5	573	585.5
- 8	360.5	373	385.5	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	535.5	548	560.5	573	585.5	598	610.5


Dimensions: JSY5000 Series

Type 10/Side Ported EX250

JJ5SY5-10S - Stations







L1 = 16 x n1 + 147 + 21 x n2 L2 = 16 x n1 + 53.5 L4 = L3 - 10.5

n1: Number of valve stations of the JSY5000

L6 = 21 x n2 + 81.5 n2: Input block stations

L5 = (L3 - L1) / 2

* These figures show the "JJ5SY5-10SQ1A-05D-C12."

* Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

Valve stations (n1) I/O unit stations (n2)		3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5
1	235.5	248	260.5	273	298	310.5	323	335.5	360.5	373	385.5	410.5	423	435.5	448	473	485.5	498	523	535.5	548	560.5	585.5
2	248	260.5	285.5	298	310.5	335.5	348	360.5	373	398	410.5	423	448	460.5	473	485.5	510.5	523	535.5	560.5	573	585.5	598
3	273	285.5	298	323	335.5	348	373	385.5	398	410.5	435.5	448	460.5	485.5	498	510.5	523	548	560.5	573	585.5	610.5	623
4	298	310.5	323	335.5	360.5	373	385.5	410.5	423	435.5	448	473	485.5	498	510.5	535.5	548	560.5	585.5	598	610.5	623	648
5	310.5	335.5	348	360.5	373	398	410.5	423	435.5	460.5	473	485.5	510.5	523	535.5	548	573	585.5	598	623	635.5	648	660.5
6	335.5	348	360.5	385.5	398	410.5	435.5	448	460.5	473	498	510.5	523	548	560.5	573	585.5	610.5	623	635.5	660.5	673	685.5
7	360.5	373	385.5	398	423	435.5	448	473	485.5	498	510.5	535.5	548	560.5	585.5	598	610.5	623	648	660.5	673	685.5	710.5
- 8	373	398	410.5	423	435.5	460.5	473	485.5	510.5	523	535.5	548	573	585.5	598	610.5	635.5	648	660.5	685.5	698	710.5	723

Plug-in Connector Connecting Base

EX260

Type 10 Side Ported

JSY1000/3000/5000 Series

Refer to page 106 for details on manifolds that support safety communication.


(E UK ROHS





Internal Pilot

How to Order Manifolds



Series

1	JSY1000
3	JSY3000
5	JSY5000

SI unit (Output polarity, Protocol, Number of outputs,

Comm	unication co	onnector)			
	tput polarity)		Number	Communicatio	
Positive common (NPN)	Negative common (PNP)	Protocol	of outputs	connector	
0	*1	Without	SI unit		
QA	QAN	DeviceNet®	32	M12	
QB	QBN	Devicemen	16	IVIIZ	
NA	NAN		32	M12	
NB	NBN	PROFIBUS	16	IVI I Z	
NC	NCN	DP	32	P-sub	
ND	NDN		16	D-Sub	
VA	VAN	CC-Link	32	M12	
VB	VBN	CC-LINK	16	IVITZ	
DA	DAN	EtherCAT	32	M12	
DB	DBN	EllielCAT	16	IVIIZ	
FA	FAN	PROFINET	32	M12	
FB	FBN	PROFINEI	16	IVIIZ	
EA	EAN	EtherNet/IP™	32	M12	
EB	EBN	Euleinel/IP····	16	IVI I Z	
_*2	GAN	Ethernet	32	M12	
*2	GBN	POWERLINK	16		
*2	KAN	IO-Link	32*4	M12	
_*2	CAN	CC-Link IE TSN	32*4	RJ45*3	

<u> </u>	•
10	Side ported

A P E port entry

● F, L	- port entry
U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 24 stations)

6 SUP/EXH block assembly

	· ,
Nil	Internal pilot
S	Internal pilot, Built-in silencer

- * The 3/5(E) port is plugged for the built-in silencer type.
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.
- *1 Without SI unit, the output polarity is decided by the SI unit used. Ensure a match with the common specification of the valves to be used.
- *2 Positive common (NPN) type is not available.
 *3 The enclosure is IP40 when the communication connector is a D-sub connector or an RJ45 connector.

 *4 Only the 32 outputs type is available
- DIN rail cannot be mounted without SI unit.

A. B port size (Metric/One-touch fitting)

•, -	٦,	OII 0120 (IIIC		touon mi	9/	
Symbol		A, B port	JSY1000	JSY3000	JSY5000	
C2		ø2	•	_	_	~ (S)
C4		ø4	•	•	_	
C6	ᆂ	ø6	•	•	•	
C8	Straight	ø8	_	•	•	
C10	ξ	ø10	_	_	•	
C12		ø12	_	_	•	00
CM*1		Straight port, mixed sizes	•	•	•	- Ordina
	P, E port size (One-touch fittings)			ø10	ø12	

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

For details on the EX260 Integrated Type (For Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 134. Please download the Operation Manual via the SMC website, https://www.smcworld.com

Made to Order

(Refer to page 156 for details.)

	(page actually	
	Specification	
Exter	nal pilot (SUP/EXH block assembly)	

4 Valve stations

in the case of the 32-output of unit					
Symbol	Stations	Note			
02	2 stations				
:	:	Double wiring*1			
16	16 stations	_			
02	2 stations	0			
:	:	Specified layout*2 (Up to 32 solenoids available)			
24	24 stations	(Op to 32 soleriolds available)			

In the case of the 16-output SI unit

Symbol	Stations	Note		
02	2 stations			
- :	:	Double wiring*1		
08	8 stations			
02	2 stations	0		
- :	:	Specified layout*2 (Up to 16 solenoids available)		
16	16 stations	(Up to 16 soleriolds available)		

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- * This also includes the number of blanking nlates
- For the product without the SI unit (S0), note the maximum number of solenoids of the SI unit that will be mounted. If the layout is specified, indicate it on the manifold specification sheet.

Mounting and Option

	<u> </u>
Symbol	Mounting
Nil	Direct mounting
D□	DIN rail mounting


- * Enter the number of stations inside \square when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.
- DIN rail mounting (D□) is not available for the product without the SI unit (S0).

DIN Rail Option

Nil	DIN rail mounting (With DIN rail)			
0	DIN rail mounting (Without DIN rail)			
3	For 3 stations	0		
:	:	Specify a length longer than that of the standard rail.		
24	For 24 stations	triat of the standard ran.		

Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

How to Order Manifold Assembly





- JJ5SY3-10SNAN-05D-C8 ·· 1 set (Type 10 5-station manifold base part no.)
- * JSY3100-5U 2 sets (2-position single part no.)
 * JSY3200-5U 3 sets (2-position double part no.)
- The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the valve, etc.
- For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.





1 Series

1	JSY1000
3	JSY3000
5	JSY5000

2 Type of actuation

1	O monition	Single
2	2-position	Double
3		Closed center
4	3-position	Exhaust center
5		Pressure center
Α	4	N.C./N.C.
В	4-position dual 3-port	N.O./N.O.
С	duai 3-port	N.C./N.O.

3 Coil specifications

Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
Nil	Standard	_	•	•
Т	With power-saving circuit (Continuous duty type)	•	•	•

For the JSY1000 series, only the power-saving circuit specification is available.
 Be careful of the energizing time when the power-saving circuit is selected.
 For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

- Select "U" or "Z" for the valve when the SI unit output polarity is positive common.
 - Select "U" or "NZ" for the valve when the SI unit output polarity is negative common.
- * Only "Z" and "NZ" types are available with a power saving circuit.

For details, refer to page 15 Manual override

O manda override	ICV1000	ICVAGGO	ICVEDOO
Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.



⚠ Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.



Plug-in Connector Connecting Base

Type 10 Side Ported

EX260 Safety Communication Protocol (PROFIsafe)

SY1000/3000/5000 Series

Using the safety communication protocol

Refer to the EX260 Web Catalog for details on units that support the safety communication protocol When using a manifold valve within an ISO 13849-compliant safety system, the device needs to be considered from both the pneumatic circuit and the electric side

Devices (including valves) need to be selected based on whether their functions are in line with the safety level of the equipment as a whole.

The use of valves that have been validated as being compliant with ISO 13849-2 may be required. For details on valves that have been validated, please contact SMC

In addition, refer to "Safety Instructions" for precautions on model selection.





Refer to page 104 for details on manifolds that support Fieldbus and Industrial Ethernet.

Internal Pilot

How to Order Manifolds



Series

1	JSY1000
3	JSY3000
5	JSY5000
J	J515000

Valve stations

Symbol	Stations	Note				
02	2 stations					
:	:	Double wiring*1				
16	16 stations					
02	2 stations	0				
:	:	Specified layout*2 (Up to 32 solenoids available				
24	24 stations	(Op to 32 soleriolds available				

- *1 Double wiring: 2-position single, 3-position, and 4-position valves can be used on all manifold stations
 - The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 3-position and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of blanking nlates

2 Type

Side ported

P, E port entry

U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 24 stations)

6 SUP/EXH block assembly

Nil	Internal pilot					
S	Internal pilot, Built-in silencer					

- * The 3/5(E) port is plugged for the built-in silencer type.
- When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

Made to Order (Refer to page 156 for details.)

ĺ		Specificatio	n
	External pilo	t (SUP/EXH b	olock assembly)

SI unit (Output polarity, Protocol, Number of outputs, Communication connector)

Symbol (Ou	tput polarity)		Number	Communication		
Positive common (NPN)	Negative common (PNP)	Protocol	of outputs	connector		
0	*1	Without SI unit				
—*2	FPN	PROFIsafe	32*3	M12		
_*2	DPN	Safety over EtherCAT	32*3	M12		

- *1 Without SI unit, the output polarity is decided by the SI unit used. Ensure a match with the common
- specification of the valves to be used. *2 Positive common (NPN) type is not available.
- *3 Only the 32 outputs type is available.
- * DIN rail cannot be mounted without SI unit.

A, B port size (Metric/One-touch fitting)

Symbol		A, B port	JSY1000	JSY3000	JSY5000
C2		ø2	•	_	_
C4		ø4	•	•	_
C6	ᆂ	ø6	•	•	•
C8	raigl	ø8	-	•	•
C10	क्र	ø10	_	_	•
C12		ø12	_	_	•
CM*1		Straight port, mixed sizes	•	•	•
P, E	por	t size (One-touch fittings)	ø8	ø10	ø12



- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

8 Mounting and Option

Symbol	Mounting
Nil	Direct mounting
D□	DIN rail mounting

- * Enter the number of stations inside \square when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold. DIN rail mounting (DD) is not available for
- the product without the SI unit (S0).

DIN Rail Option

Nil	DIN ra	il mounting (With DIN rail)					
0	DIN rail mounting (Without DIN rail)						
3	For 3 stations	0					
:	:	Specify a length longer than that of the standard rail.					
24	For 24 stations	triat of the standard rail.					

Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

For details on the EX260 Integrated Type (For Output) Serial Transmission System, refer to the Web Catalog and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 134. Please download the Operation Manual via the SMC website, https://www.smcworld.com


[Validated product examples]

Please contact SMC for further details as supported variations are continually being added.

* 2-position double of rubber seal and manual override with locking function (D, E type) are excluded, because they don't comply with safety standard.

Internal Pilot

How to Order Valves (With mounting screw)





Series

1	JSY1000
3	JSY3000
5	JSY5000

2 Type of actuation

1	2-position Single Closed center Exhaust center Pressure center N.C./N.C. 4-position dual 3-port					
3		Closed center				
4	3-position	Exhaust center				
5		Pressure center				
Α	4	N.C./N.C.				
В		N.O./N.O.				
С	duai 3-port	N.C./N.O.				

3 Coil specifications

Symbol	7		JSY3000	JSY5000
Nil	Standard	_	•	•
Т	With power-saving circuit (Continuous duty type)	•	•	•

- * For the JSY1000 series, only the power-saving circuit specification is available.
- * Be careful of the energizing time when the power-saving circuit is selected.

For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
NZ	•	•	Polar Negative common	•	•	•

* Only "NZ" type is available with a power saving circuit.

6 Manual override

Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.

* When ordering a valve individually, the base gasket is not included.


Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance. Refer to page 137 for base gasket and mounting screw part numbers.




Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 92 and 94 fittings)

JJ5SY1-10S - Stations P-C4(D)





- * These figures show the "JJ5SY1-10SQA-05D-C4."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: Dimensions


	=======================================														
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	99.2	105.7	112.2	118.7	125.2	131.7	138.2	144.7	151.2	157.7	164.2	170.7	177.2	183.7	190.2
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	123	135.5	135.5	148	160.5	160.5	173	173	185.5	185.5	198	198	210.5	210.5	223
L4	112.5	125	125	137.5	150	150	162.5	162.5	175	175	187.5	187.5	200	200	212.5
L5	12	15	12	15	18	15	18	14	17	14	17	14	17	14	17


/ / /	17	18	19	20	21	22	23	24
L1	196.7	203.2	209.7	216.2	222.7	229.2	235.7	242.2
L2	153.9	160.4	166.9	173.4	179.9	186.4	192.9	199.4
L3	223	235.5	235.5	248	248	260.5	260.5	273
L4	212.5	225	225	237.5	237.5	250	250	262.5
L5	13	16	13	16	13	16	13	16

Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to ø6 fittings)
EX260

JJ5SY1-10S - Stations P-C6(D)





- * These figures show the "JJ5SY1-10SQA-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.

L: Dimensions n: Stations 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 104.2 113.2 122.2 131.2 140.2 149.2 158.2 167.2 176.2 185.2 194.2 203.2 212.2 221.2 230.2 L2 61.4 70.4 79.4 88.4 97.4 106.4 115.4 124.4 133.4 142.4 151.4 160.4 169.4 178.4 187.4 L3 135.5 148 148 160.5 173 173 185.5 198 210.5 210.5 223 235.5 235.5 248 260.5 L4 125 137.5 137.5 150 162.5 162.5 187.5 200 200 212.5 225 225 237.5 250 175

16

17

13

15

16

12

14

L n	17	18	19	20	21	22	23	24
L1	239.2	248.2	257.2	266.2	275.2	248.2	293.2	302.2
L2	196.4	205.4	214.4	223.4	232.4	241.4	250.4	259.4
L3	273	273	285.5	298	310.5	310.5	323	335.5
L4	262.5	262.5	275	287.5	300	300	312.5	325
L5	17	13	14	16	18	13	15	17

15

17

12

L5

16

18


13


15

Dimensions: JSY3000 Series

Type 10/Side Ported EX260

JJ5SY3-10S - Stations D-C6 (D)







- * These figures show the "JJ5SY3-10SQA-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions n: Stations 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 L1 106.8 118.3 129.8 141.3 152.8 164.3 175.8 187.3 198.8 210.3 221.8 233.3 244.8 256.3 267.8 L2 66.1 77.6 89.1 100.6 112.1 123.6 135.1 146.6 158.1 169.6 181.1 192.6 204.1 215.6 227.1 L3 135.5 148 160.5 173 185.5 198 210.5 210.5 223 235.5 248 260.5 273 285.5 298 L4 125 137.5 150 162.5 175 187.5 200 200 212.5 225 237.5 250 262.5 275 287.5 L5 15 15 16 16 17 17 18 12 12 13 13 14 14 15 15

_	n	17	18	19	20	21	22	23	24
	L1	279.3	290.8	302.3	313.8	325.3	336.8	348.3	359.8
	L2	238.6	250.1	261.1	273.1	284.6	296.1	307.6	319.1
	L3	310.5	323	335.5	348	360.5	360.5	373	385.5
- 1	L4	300	312.5	325	337.5	350	350	362.5	375
	L5	16	16	17	17	18	12	13	13





- * These figures show the "JJ5SY5-10SQA-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dimensions								r	n: Stations							
ī	/	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	L1	126.2	142.2	158.2	174.2	190.2	206.2	222.2	238.2	254.2	270.2	286.2	302.2	318.2	334.2	350.2
	L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
	L3	160.5	173	185.5	198	223	235.5	248	273	285.5	298	310.5	335.5	348	360.5	385.5
	L4	150	162.5	175	187.5	212.5	225	237.5	262.5	275	287.5	300	325	337.5	350	375
	L5	17	16	14	12	17	15	13	18	16	14	12	17	15	13	18

_ n	17	18	19	20	21	22	23	24
L1	366.2	382.2	398.2	414.2	430.2	446.2	462.2	478.2
L2	325.5	341.5	357.5	373.5	389.5	405.5	421.5	437.5
L3	398	410.5	423	448	460.5	473	485.5	510.5
L4	387.5	400	412.5	437.5	450	462.5	475	500
L5	16	14	13	17	15	14	12	16

Plug-in Connector Connecting Base

EX120


Type 10 Side Ported

JSY1000/3000/5000 Series

(E UK ROHS

Internal Pilot

How to Order Manifolds



Series

1	JSY1000
3	JSY3000
5	JSY5000

2 Type

Side ported

🚯 SI unit

0	Without SI unit					
Q	DeviceNet® (Positive common NPN)					
V	CC-Link (Positive common NPN)					
ZB *1	CompoNet®	Positive common NPN				
ZBN*1	Componer	Negative common PNP				

- *1 The communication connector (for the opposite side) is not provided. Please orde it separately.
- Ensure a match with the common specification of the valve to be used.

5 P, E port entry

U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 16 stations)

6 SUP/EXH block

	/EATT BIOOK
Nil	Internal pilot
S	Internal pilot, Built-in silencer

- The 3/5(E) port is plugged for the built-in silencer type.
- The external pilot specification should be ordered as Made to Order. For details, refer to page 156.

Made to Order Made to Order (Refer to page 156 for details.)

Specification
External pilot (SUP/EXH block assembly)

Valve stations

_		014110110
Symbol	Stations	Note
02	2 stations	
:	:	Double wiring*1
08	8 stations	
02	2 stations	Considered laws with 2
:	:	
16	16 stations	(Op to 16 soleriolds available)
02	2 stations	Double wiring*1 Specified layout*2 (Up to 16 solenoids available)

- 1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal. If this is not desired, order with a specified layout.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- This also includes the number of blanking nlates
- Since R2 type SI unit has 8 outputs, note that up to 8 solenoids can be accommodated.

A, B port size (Metric/One-touch fitting)

A, B port size (wetric/one-touch inting)							
Symbol		A, B port	JSY1000	JSY3000	JSY5000		
C2		ø2	•	_	_		
C4		ø4	•	•	_		
C6	ᆴ	ø6	•	•	•		
C8	Straight	ø8	_	•	•		
C10	캾	ø10	_	_	•	0	
C12		ø12	_	_	•	00	
CM*1		Straight port, mixed sizes	•	•	•	000	
	P, E port size (One-touch fittings)			ø10	ø12		

- *1 Indicate the sizes on the manifold specification sheet in the case of "CM."
- * The JSY1000 manifold pitch for C2 and C4 is 6.5 mm, and 9 mm for C6. When CM is selected, the manifold pitch is different depending on the selected fitting.

Mounting and Option

	woulding and Option							
	Symbol	Mounting						
I	Nil	Direct mounting						
	D.	DIN rail mounting						

- Enter the number of stations inside ☐ when it is larger than the number of valve stations. (Refer to "DIN Rail Option" shown below.)
- Refer to page 160 for details on securing the DIN rail mounting type manifold.

DIN Bail Option

ſ	Nil	il mounting (With DIN rail)	
Γ	0	DIN rail	mounting (Without DIN rail)
Γ	3	For 3 stations	0
Γ	:	:	Specify a length longer than that of the standard rail.
	16	For 16 stations	triat of the standard rail.

If the DIN rail must be mounted without an SI unit, select D0. Refer to L3 of the dimensions for the DIN rail length and order separately. (Refer to page 152 for the DIN rail part number.)

For details on the EX120 Integrated Type (For Output) Serial Transmission System, refer to the **Web Catalog** and the Operation Manual. For the part numbers of the SI units to be mounted, refer to page 135. Please download the Operation Manual via the SMC website, https://www.smcworld.com

How to Order Manifold Assembly

Example (JJ5SY3-10S3V-□) 2-position double (24 VDC) JSY3100-5U (2 sets) Manifold base (5 stations) JJ5SY3-10S3V-05D-C8

- JJ5SY3-10S3V-05D-C8 ··· 1 set (Type 10 5-station manifold base part no.)
- * JSY3100-5U-----2 sets (2-position single part no.)


 * JSY3200-5U-----3 sets (2-position double part no.)
- → The asterisk denotes the symbol for the assembly.


 Prefix it to the part numbers of the valve, etc.
- · For the valve arrangement, the valve closest to the D side is considered the 1st station.
- Under the manifold part number, state the valves to be mounted in order starting with the 1st station as shown in the figure. If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.







1 3ci	169
1	JSY1000
3	JSY3000
5	JSY5000

2 Type of actuation

1	O manitian	Single
2	2-position	Double
3		Closed center
4	3-position	Exhaust center
5]	Pressure center
Α	4	N.C./N.C.
В	4-position dual 3-port	N.O./N.O.
С	duai 5-port	N.C./N.O.

3 Coil specifications

Symbol	Coil specifications	JSY1000	JSY3000	JSY5000
Nil	Standard	_	•	•
Т	With power-saving circuit (Continuous duty type)	•	•	•

For the JSY1000 series, only the power-saving circuit specification is available.
 Be careful of the energizing time when the power-saving circuit is selected.
 For details, refer to page 158.

4 Light/surge voltage suppressor and common specification

Symbol	With light	Surge voltage suppressor	Common specification	JSY1000	JSY3000	JSY5000
U			Non-polar	_	•	•
z	•	•	Polar Positive common	•	•	•
NZ			Polar Negative common	•	•	•

* Only "Z" and "NZ" types are available with a power saving circuit.

Manual override

Symbol/Specification	JSY1000	JSY3000	JSY5000
Nil: Non-locking push type	•	•	•
D: Push-turn locking slotted type	•	•	•
E: Push-turn locking lever type	_	•	•

- * Push-turn locking lever type "E" is not available for the JSY1000.
- * When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.



∧ Caution

If the JSY3000/5000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.





Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to 02 and 04 fittings)



JJ5SY1-10S3 - Stations D-C4(D)





- * These figures show the "JJ5SY1-10S3V-05D-C4."
- Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- When CM is selected for mixed A, B port size and C6 (9 mm pitch) is included, refer to page 121 for dimensions.

L: DIM	iension	ıs												r	n: Stations
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	104.3	110.8	117.3	123.8	130.3	136.8	143.3	149.8	156.3	162.8	169.3	175.8	182.3	188.8	195.3
L2	56.4	62.9	69.4	75.9	82.4	88.9	95.4	101.9	108.4	114.9	121.4	127.9	134.4	140.9	147.4
L3	135.5	135.5	148	148	160.5	160.5	173	173	185.5	198	198	210.5	210.5	223	223
L4	125	125	137.5	137.5	150	150	162.5	162.5	175	187.5	187.5	200	200	212.5	212.5
L5	16	12	15	12	15	12	15	12	15	18	14	17	14	17	14


SMC


Dimensions: JSY1000 Series

Type 10/Side Ported (Applicable to ø6 fittings)



JJ5SY1-10S3 - Stations P-C6(D)






- * These figures show the "JJ5SY1-10S3V-05D-C6."
- * Refer to page 118 for dimensions of external pilot (Made to Order) and silencer.
- * When CM is selected for mixed A, B port size, refer to page 121 for dimensions.


L: Dim	ension	ıs												r	n: Stations
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	109.3	118.3	127.3	136.3	145.3	154.3	163.3	172.3	181.3	190.3	199.3	208.3	217.3	226.3	235.3
L2	61.4	70.4	79.4	88.4	97.4	106.4	115.4	124.4	133.4	142.4	151.4	160.4	169.4	178.4	187.4
L3	135.5	148	160.5	160.5	173	185.5	198	198	210.5	223	223	235.5	248	260.5	260.5
L4	125	137.5	150	150	162.5	175	187.5	187.5	200	212.5	212.5	225	237.5	250	250
L5	13	15	17	12	14	16	17	13	15	16	12	14	15	17	13

Dimensions: JSY3000 Series

Type 10/Side Ported EX120

JJ5SY3-10S3 - Stations P-C6 (D)





- * These figures show the "JJ5SY3-10S3V-05D-C8."
- * Refer to page 119 for dimensions of external pilot (Made to Order) and silencer.


L: Dim	ension	IS												r	n: Stations
/ />	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	111.9	123.4	134.9	146.4	157.9	169.4	180.9	192.4	203.9	215.4	226.9	238.4	249.9	261.4	272.9
L2	66.1	77.6	89.1	100.6	112.1	123.6	135.1	146.6	158.1	169.6	181.1	192.6	204.1	215.6	227.1
L3	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	273	285.5	298
L4	125	137.5	150	162.5	175	187.5	200	212.5	225	237.5	250	262.5	262.5	275	287.5
15	12	12	13	13	14	14	15	15	16	16	17	17	12	12	13


Dimensions: JSY5000 Series

Type 10/Side Ported EX120



JJ5SY5-10S3 \square - Stations $\stackrel{\text{U}}{\stackrel{\text{C6}}{\stackrel{\text{C8}}{\stackrel{\text{C8}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}}{\stackrel{\text{C9}}}}\stackrel{\text{C9}}{\stackrel{\text{C9}}}}\stackrel{\text{C9}}{\stackrel{\text{C9}}}}\stackrel{\text{C9}}{\stackrel{\text{C9}}}\stackrel$





- * These figures show the "JJ5SY5-10S3V-05D-C12."
- * Refer to page 120 for dimensions of external pilot (Made to Order) and silencer.

L: Dim	ension	ıs												r	n: Stations
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	131.3	147.3	163.3	179.3	195.3	211.3	227.3	243.3	259.3	275.3	291.3	307.3	323.3	339.3	355.3
L2	85.5	101.5	117.5	133.5	149.5	165.5	181.5	197.5	213.5	229.5	245.5	261.5	277.5	293.5	309.5
L3	160.5	173	198	210.5	223	235.5	260.5	273	285.5	310.5	323	335.5	348	373	385.5
L4	150	162.5	187.5	200	212.5	225	250	262.5	275	300	312.5	325	337.5	362.5	375
L5	15	13	17	16	14	12	17	15	13	18	16	14	12	17	15

Common Dimensions


Type 10/Side Ported
External Pilot, Built-in Silencer


Dimensions: JSY1000 Series


JJ5SY1-10 \square - Stations $\stackrel{\text{U}}{\stackrel{\text{R}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}\stackrel{\text{C}}}{\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}\stackrel{\text{C}}}\stackrel{$


External pilot (Made to Order)

P, E port entry: D









Calculation formula for L dimensions

L = 6.5 x n1 + 9 x n2 + 39.6

- n1: Number of 6.5 mm pitch manifold block stations (Applicable fitting: ø2, ø4)
- n2: Number of 9 mm pitch manifold block stations (Applicable fitting: ø6)

* These figures show the "JJ5SY1-10F2-05DR-C4."

Common Dimensions JSY1000/3000/5000 Series


Type 10/Side Ported
External Pilot, Built-in Silencer


Dimensions: **JSY3000** Series

JJ5SY3-10 \square - Stations $\stackrel{\text{U}}{\stackrel{\text{R}}{\stackrel{\text{U}}{\stackrel{\text{C}}{\stackrel{\text{R}}{\stackrel{\text{C}}{\stackrel{\text{C}}{\stackrel{\text{R}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}}\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C$

External pilot (Made to Order)

P, E port entry: D







Calculation formula for L dimensions

L = 11.5 x n + 33.4

n: Manifold stations



* These figures show the "JJ5SY3-10F2-05DR-C8."




Dimensions: JSY5000 Series


Type 10/Side Ported
External Pilot, Built-in Silencer

JJ5SY5-10 \square -Stations $\stackrel{\text{U}}{\stackrel{\text{C}}}{\stackrel{\text{C}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}{\stackrel{\text{C}}}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}{\stackrel{\text{C}}}}\stackrel{\text{C}}{\stackrel{\text{C}}}\stackrel{\text{C}}}\stackrel{\text{C}}\stackrel{\text{C}}}\stackrel{\text{C$


External pilot (Made to Order)

P, E port entry: D






Calculation formula for L dimensions
L = 16 x n + 41.5
n: Manifold stations



* These figures show the "JJ5SY5-10F2-05DR-C12."




Common Dimensions JSY1000/3000/5000 Series


Dimensions: JSY1000 Series

Type 10/Side Ported Mixed Size, Straight Port Type




JJ5SY1-10 - Stations P-CM





(Fitting for the type with P/E ports on the U and/or D sides)



- * Refer to page 118 for dimensions of external pilot and built-in silencer.
- Refer to pages 86 to 89, 100, and 101 for dimensions when L6, b, and d are used for the calculation formula.
- Refer to pages below for dimensions that are not specified in each wiring specification.

D-sub connector (IP40/Connector entry direction adjustable): pp. 44, 45 D-sub connector (IP20/Compact type) : pp. 50, 51 Flat ribbon cable (IP40/Connector entry direction adjustable): pp. 53, 54 Flat ribbon cable (IP20/Compact type) : pp. 57, 58 Spring type terminal block box : pp. 66, 67 Terminal block box : pp. 70, 71 Lead wire : pp. 78, 79 EX600 : pp. 86 to 89 FX250 : pp. 100, 101 EX260 : pp. 108, 109 EX120 : pp. 114, 115

Calculation formula for dimensions $L1 = 6.5 \times n1 + 9 \times n2 + a + b \times n3$

L2 = 6.5 x n1 + 9 x n2 + 43.4

M = {(L1 + c) / 12.5} + 1 Decimal fractions are truncated L3 = 12.5 x M + 23

L4 = L3 - 10.5

L5 = (L3 - L1 + c) / 2

 $L6 = \dot{b} \times n3 + d$

n1: Number of 6.5 mm pitch manifold block stations (Applicable fitti	ngs: ø2, ø4)
n2: Number of 9 mm pitch manifold block stations (Applicable f	ittings: ø6)


n3: Number of I/O units or input block stations

Coefficient	а	b	С	d
D-sub connector (IP20/Compact type)	64.1	_	6.1	_
D-sub connector/Flat ribbon cable (IP40/Connector entry direction adjustable)	83	_	6.1	_
Flat ribbon cable (IP20/Compact type)	59.1	_	11.2	_
Spring type terminal block box	125.5	_	_	_
Terminal block box	146.8	_	_	_
Lead wire	94.5	_	_	_
Serial transmission: EX600 (M12 connector)	139	47	_	83.8
Serial transmission: EX600 (7/8 inch connector)	155.5	47	_	83.8
Serial transmission: EX250	139	21	_	83.8
Serial transmission: EX260	86.2	_	_	_
Serial transmission: EX120	91.3	_	_	_


^{*} FW [D-sub connector (IP67)] is not available for the JSY1000.



JSY1000/3000/5000 Series Type 10 Connector Connecting Base Manifold Exploded View



Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series




Manifold Parts Nos.

wiring. Refer to page 161.

Mounted only on the DIN rail mounting type

The holding screw of the clamp bracket is tightened at one point (for the JSY3000). * The clamp bracket fixing method for the JSY1000 is different depending on



Connector entry direction

Upward

Lateral

Internal

External

Made to Order

.

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block

2 Clamp bracket

Symbol

Nil

s

R

Series	Part no.	
JSY1000	JSY11M-15P-1A	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	

Built-in

silencer

1


2




The 3/5(E) port is plugged for the built-in silencer type.

^{*} The part number is for 1 piece.

JSY3000/5000 Series



Manifold Parts Nos.



SUP/EXH block assembly (D side) accessories and the number of accessories

and the maniber of	40000001100	
Accessories	JSY3000	JSY5000
(a) Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block

2 D-sub connector block <for IP67>

The 3/5(E) port is plugged for the built-in

silencer type.


Part no.	Connector entry direction		
SY30M-14-9A1	Upward		
SY30M-14-9A2	Lateral		

(3) Clamp bracket


Series	Part no.	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	

^{*} The part number is for 1 piece.

Connector Connecting Base Manifold Exploded View JSY1000/3000 Series



Manifold Parts Nos.




② Clamp bracket

silencer type.


Series	Part no.	
JSY1000	JSY11M-15P-1A	
JSY3000	SY30M-15-1A	

^{*} The part number is for 1 piece.



* The clamp bracket fixing method for the JSY1000 is different depending on

Manifold Parts Nos.



wiring. Refer to page 161.

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block

②Terminal block assembly

SY30M-130-1A


3 Clamp bracket

Series	Part no.		
JSY1000	JSY11M-15P-1A		
JSY3000	SY30M-15-1A		
JSY5000	SY50M-15-1A		


^{*} The part number is for 1 piece.

The 3/5(E) port is plugged for the built-in silencer type.





Manifold Parts Nos.



The 3/5(E) port is plugged for the built-in silencer type.

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block

2 Terminal block box housing assembly

VVQC1000-T0-1

3 Clamp bracket for terminal block box

SY30M-15-4A


(4)	C	lam	n h	ra	ck	et
J.	•	alli	pν	ı a	Un	CL

Series	Part no.	
JSY1000	JSY11M-15P-2A	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	


^{*} The part number is for 1 piece.



Not available for "R" type



Manifold Parts Nos.




depending on wiring. Refer to page 161.

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000
a Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block




³ Clamp bracket

9 1	
Series	Part no.
JSY1000	JSY11M-15P-1A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A

^{*} The part number is for 1 piece.

The 3/5(E) port is plugged for the built-in silencer type.

Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series



Manifold Parts Nos.

1) SUP/EXH block assembly



Pilot, Silencer type

	Pilot	Built-in		
Symbol	Internal	External (Made to Order)	silencer	
Nil	•	_	_	
S	•	_	•	
R	_	•	_	

* The 3/5(E) port is plugged for the built-in silencer type.

Symbol	iviounting	J5Y1000	J5 Y3000	J5 Y5000
Nil	Direct mounting	•	•	•
D00	DIN rail mounting (Without DIN rail)	•	_	_
D0	DIN rail mounting (Without DIN rail)	_	•	•

P, E port size (One-touch fittings)

P, E port	JSY1000	JSY3000	JSY5000
ø8 One-touch fitting	•	_	_
ø10 One-touch fitting	_	•	_
ø12 One-touch fitting	_	_	•
Plug	•	•	•
	ø8 One-touch fitting ø10 One-touch fitting ø12 One-touch fitting	ø8 One-touch fitting ø10 One-touch fitting w12 One-touch fitting —	ø8 One-touch fitting ● ø10 One-touch fitting — ø12 One-touch fitting —

*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

SUP/EXH block assembly (D side)

accessories and the number of accessories

Accessories	JSY1000/3000	JSY5000
a Tension bolt	None*1	3 pcs.

^{*1} Since the nuts are embedded in the SUP/EXH block

2 Valve plate

EX600-ZMV2

* With mounting screws (2 pcs. of M4 x 6 and 2 pcs. of M3 x 8)



Manifold Parts Nos.


③EX600 SI unit

EX600-S

Comr	nunication protocol		
Symbol	Protocol	Output polarity	
PR1A	PROFIBUS DP	PNP (Negative common)	
PR2A	PROFIBUS DP	NPN (Positive common)	
DN1A	DeviceNet®	PNP (Negative common)	
DN2A	Devicemen	NPN (Positive common)	
MJ1	CC-Link	PNP (Negative common)	
MJ2	CC-LIIK	NPN (Positive common)	
EN7	EtherNet/IP™	PNP (Negative common)	
EN8	(IO-Link unit)	NPN (Positive common)	
EC3	EtherCAT	PNP (Negative common)	
EC4	(IO-Link unit)	NPN (Positive common)	
PN3	PROFINET	PNP (Negative common)	
PN4	(IO-Link unit)	NPN (Positive common)	
PN31	PROFINET	PNP (Negative common)	
LIASI	(OPC UA, IO-Link unit)	FINE (Negative common)	



③EX600 SI unit (Wireless compatible)





Symbol	Description
1	PNP (Negative common)
2	NPN (Positive common)

Symbol	SI unit type	Description
SV	Wireless remote module	*1

^{*1} The wireless system is suitable for use only in a country where it is in accordance with the Radio Act and regulations of that country.

4Clamp bracket

Series	Part no.
For JSY1000	JSY11M-15P-2A
For JSY3000	SY30M-15-1A
For JSY5000	SY50M-15-1A

^{*} The part number is for 1 piece.




Manifold Parts Nos.

5 EX600 digital input unit

EX600-DXPB

Input type



Symbol	Number of inputs Open-circuit detection 8 No		Connector		
В			M12 connector (5 pins) 4 pcs.		
С	8	No	M8 connector (3 pins) 8 pcs.		
C1	8	Yes	M8 connector (3 pins) 8 pcs.		
D	D 16 No E 16 No		M12 connector (5 pins) 8 pcs.		
E			D-sub connector (25 pins)		
F	16	No	Spring type terminal block (32 pins)		



5 EX600 digital output unit



Output type		,	Number of outputs and connector			
Symbol	Description	1 [Symbol	Number of outputs	Connector	
P	PNP] [В	8	M12 connector (5 pins)	
N	NPN] [E	16	D-sub connector (25 p	
N	NPN	J	E	16	D-sub connector (25	

Symbo	Number of outputs	Connector
В	8	M12 connector (5 pins) 4 pcs.
E	16	D-sub connector (25 pins)
F	16	Spring type terminal block (32 pins)

5 EX600 digital input/output unit



Symbol Description PNF

Number	of i	nputs/outp	uts and	connecto
--------------------------	------	------------	---------	----------

Symbol Number of inputs		Number of outputs	Connector	
E 8		8	D-sub connector (25 pins)	
F	8	8	Spring type terminal block (32 pins)	

5 EX600 analog input/output unit



Analog input/output Symbol Description AX Analog input AY Analog output Number of input channels and connector

Symbol	Number of input channels			
Α	2 channels	M12 connector (5 pins) 2 pcs.		

5 EX600 analog input/output unit


EX600-AMB

Analog input/output

Number of input/output channels and connector

Symbol	Number of input channels	Number of output channels	Connector		
В	2 channels	2 channels	M12 connector (5 pins) 4 pcs.		

(5) EX600 IO-Link unit



Number of ports and connector

Port specification			
	Symbol	Description	
	Α	Port class A	
	R	Port class B	

Symbol Number of ports Connector M12 connector 4 ports (5 pins) 4 pcs.

⚠ Caution

The compatible SI unit models are as shown below. PROFINET compatible: EX600-SPN3/EX600-SPN4/EX600-SPN31 EtherNet/IP™ compatible: EX600-SEN7/EX600-SEN8 EtherCAT compatible: EX600-SEC3/EX600-SEC4





7 Clamp bracket for EX600

EX600-ZMA3

Enclosed parts


Round head screw with washer (M4 x 20) 1 pc. P-tight screw (4 x 14) 2 pcs.







7/8 inch power supply connector M12 power supply connector IN/OUT A-coded, Pin arrangement 1 M12 power supply connector IN/OUT A-coded, Pin arrangement 2

The pin layout for the "4" and "5" pin connectors is different.









Manifold Parts Nos.

1) SUP/EXH block assembly



3 JSY3000 5 JSY5000

Pilot Silencer

	icei type •			
	Pilot	type	D 111 1	
Symbol	Symbol Internal External (Made to Orde		Built-in silencer	
Nil	•	_	_	
S	•	_	•	
R	_	•	_	

^{*} The 3/5(E) port is plugged for the built-in silencer type.

P, E port size (One-touch fittings)

Symbol	P, E port	JSY3000	JSY5000
C10	ø10 One-touch fitting	•	_
C12	ø12 One-touch fitting	_	•
00*1	Plug	•	•


^{*1} Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

SUP/EXH block assembly (D side) accessories and the number of accessories

ı	Accessories	JSY3000	JSY5000		
ı	a Tension bolt	None*1	3 pcs.		

^{*1} Since the nuts are embedded in the SUP/EXH block

②EX245 SI unit









	Symbol	Communication connector
	1A	Push Pull connector (SCRJ): 2 pcs.
	2A	Push Pull connector (RJ45): 2 pcs.
	3A	M12 connector (4-pin, Socket, D-coded): 2 pc

Connector type

	Push Pull connector (24 V): 2 pcs.
	Push Pull connector (24 V): 2 pcs.
cs.	7/8 inch connector (5-pin, Plug): 1 pc. 7/8 inch connector (5-pin, Socket): 1 pc.

EX245-SPN1A EX245-SPN2A



JSY3000/5000 Series

Manifold Parts Nos.

③ EX245 digital input module



Digital input module specification

DX1 Digital input (16 inputs)



③ EX245 digital output module



Digital output module specification

DY1 Digital output (8 outputs)



3EX245 IO-Link module

EX245-LA1

Port specification

Symbol	Description
Α	Port class A
В	Port class B



⚠ Caution

The only available SI unit part number is "EX245-SPNmA" (PROFINET compatible). Refer to page 131.

4 EX245 end plate

EX245-EA2-3

Bracket

For JSY



^{*} Refer to page 94 for manifold valve part numbers.


Bracket 3 to 5 correspond to the mounting hole pitch of each manifold valve.



Connector Connecting Base Manifold Exploded View JSY1000/3000/5000 Series

The EX250 series is to be discontinued. When designing new equipment and facilities, consider using another series (EX260/EX600) instead.





Manifold Parts Nos.

1) SUP/EXH block assembly



	Pilot	type	Duille in	
Symbol	Internal	External (Made to Order)	Built-in silencer	
Nil	Nil •		_	
S	•	_	•	
R	_	•	_	

* The 3/5(E) port is plugged for the built-in silencer type.

Mounting

on wiring. Refer to page 161.

:	Symbol	Mounting	JSY1000	JSY3000	JSY5000
Γ	Nil	Direct mounting	•	•	•
Γ	D00	DIN rail mounting (Without DIN rail)	•	_	_
	D0	DIN rail mounting (Without DIN rail)	_	•	•

P. E port size (One-touch fittings)

Symbol	P, E port	JSY1000	JSY3000	JSY5000
C8	ø8 One-touch fitting	•	_	_
C10	ø10 One-touch fitting	_	•	_
C12	ø12 One-touch fitting	_	_	•
00*1	Plug	•	•	•

*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S"

Not available for "R" type

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories	JSY1000 JSY3000	JSY5000			
Tension bolt	None*1	3 pcs.			

*1 Since the nuts are embedded in the SUP/EXH block

2 EX250 SI unit

EX250-S DN1

Communication protocol


DN1	DeviceNet® (Negative common)			
AS3	AS-Interface (8 in/8 out, 2 isolated common type) (Negative common)			
AS5	AS-Interface (4 in/4 out, 2 isolated common type) (Negative common)			
AS7	AS-Interface (8 in/8 out, 1 common type) (Negative common)			
AS9	AS-Interface (4 in/4 out, 1 common type) (Negative common)			
EN1	EtherNet/IP™ (Negative common)			

③ Clamp bracket

Series	Part no.
JSY1000	JSY11M-15P-2A
JSY3000	SY30M-15-1A
JSY5000	SY50M-15-1A

* The part number is for 1 piece.

4 Input block



1 M12 connector, 2 inputs M12 connector, 4 inputs 3 M8 connector, 4 inputs

(5) EX250 end plate assembly

EX250 - EA1


* With mounting screws (2 pcs. of M3 x 10)

6 Clamp bracket assembly for EX250

SY30M-15-3A


* The part number is for 1 assembly.





Manifold Parts Nos.





00*1

	Pilot	Built-in		
Symbol	Internal	External (Made to Order)	silencer	
Nil	•	_	_	
S	•	_	•	
R	_	•	_	

* The 3/5(E) port is plugged for the built-in silencer type.

*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

Plug

SUP/EXH block assembly (D side) accessories and the number of accessories

Accessories JSY1000/3000 JSY5000 a Tension bolt None*1 3 pcs.

*1 Since the nuts are embedded in the SUP/EXH block

2 EX260 SI unit (Fieldbus and Industrial Ethernet)

EX260-S PR1

Communication protocol

Symbol	Protocol	Number of outputs	SI unit output polarity	Communication connector	Manifold symbol	Symbol	Protocol	Number of outputs	SI unit output polarity	Communication connector	Manifold symbol
DN1		32	Source/PNP (Negative common)		QAN	EC1		32	Source/PNP (Negative common)		DAN
DN2	DeviceNet®	32	Sink/NPN (Positive common)	M12	QA	EC2	EtherCAT	32	Sink/NPN (Positive common)	M12	DA
DN3	Deviceivei.	16	Source/PNP (Negative common)	IVITZ	QBN	EC3	EllielCAT	16	Source/PNP (Negative common)	IVITZ	DBN
DN4		10	Sink/NPN (Positive common)		QB	EC4		10	Sink/NPN (Positive common)		DB
PR1		32	Source/PNP (Negative common)		NAN P	PN1		32	Source/PNP (Negative common)		FAN
PR2		32	Sink/NPN (Positive common)	M12	NA	PN2	PROFINET	32	Sink/NPN (Positive common)	M12	FA
PR3 PR4		16	Source/PNP (Negative common)	IVITZ	NBN	PN3	I HOI INE	16	Source/PNP (Negative common)	IVITZ	FBN
PR4	PROFIBUS DP	10	Sink/NPN (Positive common)		NB	PN4	1	10	Sink/NPN (Positive common)		FB
PR5	FNOFIDUO DE	32	Source/PNP (Negative common)		NCN	EN1	V1	32	Source/PNP (Negative common)		EAN
PR6 PR7		32	Sink/NPN (Positive common)	D-sub*1	NC	EN2	EtherNet/IP™		Sink/NPN (Positive common)	M12	EA
		16	Source/PNP (Negative common)	D-Sub ·	NDN	EN3	Elliellvel/iF	16	Source/PNP (Negative common)	IVITZ	EBN
PR8		10	Sink/NPN (Positive common)		ND EN4		4 10	10	Sink/NPN (Positive common)		EB
MJ1		32	Source/PNP (Negative common)		VAN	PL1	Ethernet	32	Source/PNP (Negative common)	M12	GAN
MJ2	CC-Link	32	Sink/NPN (Positive common)	M12	VA	PL3	POWERLINK	16	Source/FIVE (IVegative continion)	IVITZ	GBN
MJ3	3 CC-LINK 16	Source/PNP (Negative common)	14112	VBN	IL1	IO-Link	32	Source/PNP (Negative common)	M12	KAN	
MJ4		10	Sink/NPN (Positive common)		VB	CT1	CC-Link IE TSN	32	Source/PNP (Negative common)	RJ45*1	CAN

^{*1} The enclosure is IP40 when the communication connector is a D-sub connector or an RJ45 connector.

EX260 SI Unit (Safety Communication)

EX260 - F PS1


Communication protocol

Symbol	Protocol	Number of outputs	SI unit output polarity	Communication connector	Manifold symb
PS1	PROFIsafe	32	Source/PNP (Negative common)	M12	FPN
SE1	Safety over EtherCAT	32	Source/PNP (Negative common)	M12	DPN

3 Clamp bracket


Series	Part no.	
JSY1000	JSY11M-15P-1A	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	

The part number is for 1 piece.



Manifold Parts Nos.





The 3/5(E) port is plugged for the built-in silencer type.

*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type

SUP/EXH block assembly (D side) accessories

and the number of accessories					
Accessories	JSY1000/3000	JSY5000			
a Tension bolt	None*1	3 pcs.			

*1 Since the nuts are embedded in the SUP/EXH block

② EX120 SI unit

R

EX120-S DN1

Communication protocol


- 00	Communication protocol				
DN1	DN1 DeviceNet® (Positive common)				
MJ1 CC-Link (Positive common)					
CM1 CompoNet® NPN (Positive common)					
CM3 CompoNet® PNP (Negative common					

(3) Clamp bracket


Series	Part no.	
JSY1000	JSY11M-15P-1A	
JSY3000	SY30M-15-1A	
JSY5000	SY50M-15-1A	


^{*} The part number is for 1 piece.

Manifold Exploded View [Common Parts]



Type 10: How to Increase Connector Type Manifolds





Screw them in until there is no gap between the tie-rods.

3 Connect the (a) manifold block assembly and (b) SUP/EXH end block assembly to be added, and tighten the tension bolt (a).


Tightening torque for tension bolt @ (M3): 0.8 N·m

⚠ Caution

Be sure to shut off the power and air supplies before disassembly.

Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.

When disassembly and assembly are performed, air leakage may result if the tightening of the tension bolt is inadequate.



*1 Manifold block assembly

No.	Description	Quantity	Note
123	Gasket	1 pc. of each	For base, connector, and manifold block
4	Tie-rod for additional stations	3	

Refer to page 137 for ordering single unit.

* 2 Connector gasket is not applicable to the JSY1000.



For the JJ5SY1-10, JJ5SY3-10, JJ5SY5-10


No.	lo. Description		JSY ⁻	1000	JSY3000	JSY5000	Note
INO.		Description	6.5 mm pitch	9 mm pitch	3313000	3515000	Note
A- ①	Base gasket (for connector connecting base) JSY11M-9P-1A		JSY31M-9P-1A	JSY51M-9P-1A	Part numbers shown on the left are for 10 valves. (10 pcs.)		
A- ②	호효	Connector gasket	-	-	SX3000	0-146-2	Supplied individually
A- ③	nifold	Manifold block gasket	JSY11	M-9P-2	JSY31M-9P-2	JSY51M-9P-2	Supplied individually
A -(4)	Mai	Tie-rod for	JSY11M-49P-1-1-A	JSY11M-49P-2-1-A	JSY31M-49P-1-1-A	SV2000-55-2A-A	3 pcs. supplied
A	-	additional stations*1	(6.5 mm pitch)	(9 mm pitch)	(11.5 mm pitch)	(16 mm pitch)	3 pcs. supplied
(5)	Tie-rod		JSY11M-49P-1-□-A	JSY11M-49P-2-□-A	JSY31M-49P-1-□-A	SV2000-55-1-□-A	☐: Manifold stations (2 to 24
9			(6.5 mm pitch)	(9 mm pitch)	(11.5 mm pitch)	(16 mm pitch)	stations) 3 pcs. supplied
6	Valv	e mounting screw	JSY11\		JSY31V-23-1A	JSY51V-23-1A	Part numbers shown on the
-			(M1.4	x 21.5)	(M2 x 25)	(M3 x 29)	left are for 10 valves. (20 pcs.)
7	DIN rail			VZ1000-11-1-□		VZ1000-11-4-□	Refer to page 152.
8	8 Clamp bracket*2 (for connector connecting base)		JSY11M-15P-1A (Ref JSY11M-15P-2A (Ref	er to the table below.)*2 er to the table below.)	SY30M-15-1A	SY50M-15-1A	Supplied individually

- *1 The manifold of the JSY1000/3000 (JJ5SY1-10/JJ5SY3-10) can be assembled by connecting the tie-rods for number of manifold stations. The manifold of the JSY5000 (JJ5SY5-10) cannot be assembled by connecting the tie-rods for additional stations for the number of manifold. Tie-rod (SV2000-55-1-□-A) is necessary.
- *2 Part number of the clamp bracket for the JSY1000 is different depending on the manifold wiring. Refer to the table below. Refer to page 161 for assembly.


Table. JSY1000 series clamp bracket

	Wiring (JSY1000 series)	JSY11M-15P-1A	JSY11M-15P-2A
F	D-sub connector	•	_
P□	Flat ribbon cable	•	_
TC	Spring type terminal block box	•	_
Т	Terminal block box	_	•
L	Lead wire	•	_
S6	EX600	_	•
S□	EX250	_	•
S	EX260	•	_
S3	EX120	•	_

Manifold Parts Nos.



	A, B port size (One-touch fittings)				fittings) •
Symbol	A, B port	JSY1000		JSY3000	ISVENIN
Syllibol	A, B port	6.5 mm pitch	9 mm pitch	3313000	0313000
C2	ø2 One-touch fitting	•	_	_	_
C4	ø4 One-touch fitting	•	_	•	_
C6	ø6 One-touch fitting	_	•	•	•
C8	ø8 One-touch fitting	-	_	•	•
C10	ø10 One-touch fitting	-	_	_	•
C12	ø12 One-touch fitting	_	_	_	•



Manifold block assembly accessories and the number of accessories

Accessories	Quantity
Base gasket	1 pc.
② Connector gasket*1	1 pc.
3 Manifold block gasket	1 pc.
4 Tie-rod for additional stations	3 pcs.

^{*1} Not applicable to the JSY1000 series

Manifold Parts Nos.

Symbol

Nil S

BSUP/EXH end block assembly



Pilot type Built-in External Interna silencer (Made to Order


The 3/5(E) port is plugged for the built-in silencer type.

.

P. E port size (One-touch fittings)

Symbol	P, E port	JSY1000	JSY3000	JSY5000
C8	ø8 One-touch fitting	•	_	_
C10	ø10 One-touch fitting	_	•	_
C12	ø12 One-touch fitting	_	_	•
00*1	Plug	•	•	•

*1 Can be selected when the pilot, silencer type symbol is "Nil" or "S" Not available for "R" type



Mounting

Nil	Direct mounting
	DIN rail mounting (Without DIN rail)
D00*1	DIN rail mounting (Without DIN rail)

*1 Part number only for the JSY1000 Part number is different depending on the wiring. Refer to Table 1.

Table 1, JSY1000 series DIN rail mounting

Symbol	Wiring
D0	D-sub connector (F type) Flat ribbon cable (P□ type) Spring type terminal block box (TC type) Lead wire (L type) EX260 (S□□ type) EX120 (S3 type)
D00	Terminal block box (T type) EX600 (S6 type) EX250 (S □ type)

SUP/EXH end block assembly accessories and the number of accessories

Accessories	Quantity
(a) Tension bolt	3 pcs.
A-③ Manifold block gasket	1 pc.

* Gasket is mounted.


® Clamp bracket

Series		Part no.
JSY1000	For D0	JSY11M-15P-1A
3311000	For D00	JSY11M-15P-2A
JSY3000		SY30M-15-1A
JSY5000		SY50M-15-1A

- * The part number is for 1 piece.
- * Part number of the JSY1000 is different depending on the manifold wiring.


Refer to the Table 1. JSY1000 series DIN rail mounting for selecting a clamp bracket

■ Cover, Silencer cover, Port block for SUP/EXH (end) block assembly



- block assembly, but they need to be ordered for piping specification change. Mounting screws (2 pcs.) for SUP/EXH end block assembly are included.
- Tightening torque for mounting screw

JSY1000 (M2.5): 0.32 N·m JSY3000 (M3): 0.8 N·m JSY5000 (M4): 1.4 N·m



- 1. Be sure to shut off the power and air supplies before disassembly. Furthermore, since air may remain inside the actuator, piping, and manifold, confirm that the air is completely exhausted before performing any work.
- 2. When disassembly and assembly are performed, air leakage may result if the tightening of the cover and port block assemblies are inadequate.



JSY3000

JSY5000

Plug-in Connector Connecting Base

Vacuum Unit ZK2 Combination Manifold

Type 10 Side Ported

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

Internal Pilot

How to Order Manifolds



Combination manifold

RoHS

Valve Manifold

Series

Connector type, Wiring, Number of cores, SI unit

rtumber or cores, or ann				
Symbol	Туре	Page		
F	D t	IP40		
FW	D-sub connector (25 pins)	IP67		
FC	(25 piris)	IP20		
P		26 pins		
PG	Flat ribbon cable	20 pins	42	
PH		10 pins		
PC	Flat ribbon cable	26 pins		
PGC	Compact type	20 pins		
PHC	Compact type	10 pins		
TC	Spring type terminal	block box	64	
Т	Terminal block	box	04	
L1		34 cores		
L2	Lead wire	17 cores	76	
L3		9 cores		
S6□		EX600	84	
S□	Serial	EX245	94	
S□	transmission	EX250	98	
S□	tiansmission	EX260	104	
S3□		EX120	112	

Refer to the pages shown in the table above for details.

2 Type

Side ported

 Connector entry direction (F□/P□ 			
Symbol	Туре		
1	Upward		
2	Downward		

· Lead wire length (L1/L2/L3)

Symbol	Туре		
1	0.6 m		
2	1.5 m		
3	3 m		
01 - 21 - 1 - 1 - 1 - 21			

- SI unit output polarity, End plate type (S6□) Refer to page 84.
 - · With or without I/O modules (S□) Refer to page 94.
- Input block stations (S□) Refer to page 98.
- I/O unit stations (S6□) Refer to page 84. Number of I/O modules (S□) Refer to page 94. Input block type (S□)

Refer to page 98.

P. E port entry, SUP/EXH block assembly

Symbol	P, E port entry	SUP/EXH block assembly	Application
U	U side (2 to 10 stations)		
D	D side (2 to 10 stations)	Internal pilot	All
В	Both sides (2 to 24 stations)		
US	U side (2 to 10 stations)	Internal pilot,	D-sub connector (F□), Terminal block box (TC, T),
DS	D side (2 to 10 stations)	Built-in	Flat ribbon cable (P□), Lead wire (L□)
BS	Both sides (2 to 24 stations)	silencer	EX260(S□)/EX245(S□)/EX120(S3□)
С	U side (2 to 10 stations)	Internal pilot,	EX600(S6□)
E	D side (2 to 10 stations)	Built-in	EX000(S0□) EX250(S□)
F	Both sides (2 to 24 stations)	silencer	EX230(3⊟)

- The 3/5(E) port is plugged for the built-in silencer type.
- * When the built-in silencer type is used, keep the exhaust port from coming into direct contact with water or other liquids.
- The external pilot specification should be ordered as Made to Order. For details,

A, B port size (Metric/One-touch fitting)

Symbol	A, B port	P, E port
C4	Straight ø4	
C6	Straight ø6	ø10
C8	Straight ø8	010
CM*1	Straight port, mixed sizes	

*1 Indicate the sizes on the manifold specification sheet in the case of "CM."

6 Valve stations

· For 32 output points · For 24 output points (TC/L1/S6\(\sigmu/S\(\sigmu)\)

(F/FW/FC/P/PC) Symbol Stations Symbol Stations Note Note 02 2 stations 02 2 stations Double wiring*1 Double wiring*1 15 stations 11 stations 02 2 stations Specified layout*2 02 2 stations Specified layout*2 (Up to 30 solenoids (Up to 22 solenoids 24 stations available) available) 22 22 stations

· For 20 output points(1)				· For 1	8 outpu	points (PG/PGC
Symbol	Stations	Note	Ш	Symbol	Stations	Note
02	2 stations		Ш	02	2 stations	
- :	:	Double wiring*1	Ш	:	:	Double wiring*1
09	9 stations		Ш	08	8 stations	
02	2 stations	Specified layout*2	Ш	02	2 stations	Specified layout*2
- :	:	(Up to 18 solenoids	Ш	:	:	(Up to 16 solenoids
18	18 stations	available)	Ш	16	16 stations	available)

· For 16 output points

(L2	(L2/S□/S3□)				
Symbo	Stations	Note			
02	2 stations				
		Double wiring*1			
07 7 stations					
02	2 stations				
:	1	(Up to 14 solenoids			
14	14 stations	available)			

For 8 output points (DH/DHC/L3)

	(F11/F110/E3)				
	Symbol	Stations	Note		
	02	2 stations			
J*1	:	:	Double wiring*1		
	03	3 stations			
t*2	02	2 stations	Specified layout*2		
oids		:	(Up to 6 solenoids		
	06	6 stations	available)		

- *1 Double wiring: 2-position single, double, 3-position, and 4-position valves can be used on all manifold stations. The use of a 2-position single solenoid will result in an unused control signal.
- *2 Specified layout: Indicate the wiring specifications on the manifold specification sheet. (Note that 2-position double, 3-position, and 4-position valves cannot be used where single wiring has been specified.)
- The total number of solenoids for the valve and ejector should not exceed the number of output points. (Number of ejector solenoids: 2 per station)
- This also includes the number of blanking plates.
- For models without an SI unit (S0), note the number of output points of the SI unit that will be mounted.

Mounting

Symbol	Symbol Mounting	
Nil	Direct mounting	
D	DIN rail mounting (With DIN rail)	
D0	DIN rail mounting (Without DIN rail)	

* Refer to page 160 for details on securing the DIN rail mounting type manifold.

Plug-in Connector Connecting Base

Vacuum Unit ZK2 Combination Man


JSY3000 Series

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to the bottom of this page for an order example.

Internal Pilot

How to Order Valves (With mounting screw)

Refer to page 34 for valve specifications.



Series

Symbol

Nil

_	
3	JSY3000

2 Type of actuation

1	0	Single
2	2-position	Double
3		Closed center
4	3-position	Exhaust center
5		Pressure center
Α		N.C./N.C.
B	4-position dual 3-port	N.O./N.O.
	duai 5-poit	N.C./N.O.

4 Light/surge voltage suppressor and common enecification

	common opcomounon				
Symbol	With light	Surge voltage suppressor	Common specification	JSY3000	
U			Non-polar	•	
z	•	•	Polar Positive common	•	
NZ			Polar Negative common	•	

- * When the non-polar common specification type is selected, take measures to prevent surge voltage. For details, refer to page 159.
- * Only "Z" and "NZ" types are available with a power saving circuit.

Made to Order (Refer to page 156 for details.) Specification External pilot

Manual override

Symbol/Specification	JSY3000
Nil: Non-locking push type	•
D: Push-turn locking slotted type	•
E: Push-turn locking lever type	•

When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the manifold, please order the base gasket separately if it is needed for maintenance.

Refer to page 137 for base gasket and mounting screw part numbers.

Coil specifications


Coil specifications

Standard

With power-saving circuit (Continuous duty type) Be careful of the energizing time when the power-saving circuit is selected. For details, refer to page 158.

If the JSY3000 series is to be continuously energized, please be sure to select the power-saving circuit (continuous duty type) specification.

How to Order Manifold Assembly



JSY3000

Refer to pages 121 and 122 for how to order ZK2 vacuum units.

JJ5SY3-10SFA-05D-C8-M ··· 1 set (Type 10 5-station manifold base part no.) * JSY3100-5U -.....2 sets (2-position single valve part no.) * JSY3200-5U -....3 sets (2-position double valve part no.) * ZZK204A-A1S0......1 set (Ejector manifold part no.)

* ZK2C12K5NC1A-08------4 sets (Ejector unit part no.)

The asterisk denotes the symbol for the assembly Prefix it to the part numbers of the ejector manifold, valve, etc.

- · For the valve and ejector arrangement, the valves closest to the D side are considered the 1st stations respectively
- · Under the manifold part number, state the valves, ejector manifold, and ejector units to be mounted in order starting with the 1st station as shown in the figure.
- · Complex exhaust and individual port exhaust cannot be mixed in the ejector manifold
- · If the arrangement becomes too complicated, specify the details on a manifold specification sheet.

JSY3000 Series

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

How to Order Manifolds



1 Stations*1

Symbol	Stations
01	1 station
02	2 stations
÷	:
08	8 stations

For adequate performance, the number of stations that can be operated simultaneously depends on the nozzle diameter. For details, refer to the ZK2□A series catalog.

2 System/Port

Symbol	System	Port
A	Ejector system	ø8 (Common PV)

3 Exhaust

Symbol	Exhaust	Selectable single unit number
1	Complex exhaust*2	ZK2C Direct exhaust End plate exhaust
2	Individual exhaust	ZK2F, ZK2H

*2 Combination of direct exhaust and end plate exhaust from each station

4 Supply valve and release valve wiring*3

Symbol Wiring Selectable wiring for manifo (Refer to "How to Order Ejectors" on page 143.)	_	•								
	Symbol Wiring									
C C1			С	C1						
S0 Centralized wiring	S0	Centralized wiring	• •							

*3 Individual wiring is specified for pressure switches for vacuum and sensors.

Option*4

Symbol	Туре	Selectable options for manifold (Refer to "How to Order Ejectors" on page 143.)					
		Е	J	K	L	Р	W
Nil	Without option	•	•	•	_	_	•
В	With DIN rail mounting bracket*5	•	•	•			•
D	With common release pressure supply (PD) port	•	•	•	_	⊚*6	•
L	Manifold individual supply specification	•	•	•	⊚*6	_	•

- *4 When more than one option is selected, list the option symbols in alphabetical order. (Example -BD)
- *5 Be sure to select the DIN rail mounting for the mounting method of the valve manifold.
- *6 When option "D" is selected, select option "P" for the single unit for manifold. When option "L" is selected, select option "L" for the single unit for manifold. (() must be selected.)
- * For details, refer to "Optional Specifications/Functions/Applications" below.


Optional Specifications/Functions/Applications

Symbol			Туре		Function/Application
E		Screwdriver operation type long lock nut		Screwdriver operation type long lock nut	Used when the port position is close to the manifold's individual supply and needle adjustment is difficult
J	Vacuum break flow adjusting needle	Round lock nut	- S	Lock nut	Thicker than the standard hexagon type More suitable for hand tightening The round lock nut improves operability when the manifold or exhaust port type is used.
к		Screwdriver operation type		Vacuum break flow adjusting needle	The slotted type allows for fine adjustment when the manifold or exhaust port type is used.
L	Manifold individ supply specific			Individual supply port	· For adjusting the manifold's supply pressure and the vacuum pressure reached by each ejector individually
Р	With manifold common release pressure supply (PD) port		with manifold common release supply (PD) port, supply (PD) port, a		When selecting option "D" (with common release pressure supply (PD) port), a pressure which is different from the common PV can be supplied to the common PD.
w	With exhaust ir prevention valv	l exhaust interference backward from the V ports of ejectors that are entire valve		When ejectors are operated individually, exhausted air may flow backward from the V ports of ejectors that are turned off. The exhaust interference prevention valve prevents this backflow.	

Specify the valve manifold and mounted valve part numbers as well as the ejector manifold and mounted ejector part numbers for ordering. Refer to page 141 for an order example.

For ejector specifications, refer to the **Web Catalog**.

How to Order Ejectors



Body/Exhaust type

Symbol	Body	Exhaust type				
С		Complex Er	rect exhaust nd plate haust			
F	For Manifold	Individual port exhaust	Individual port exhaust			
Н			igh-noise reduction lencer exhaust			

*1 Combination of direct exhaust and end plate exhaust from each station

5 Pressure switch for vacuum/Pressure sensor

					cifications
Symbol	Type	Pressure range [kPa]	NPN	PNP	With unit selection
		range [ki aj	2 ou	tputs	function*3
Α			•	_	•
В	for	0 to -101	•	_	None (SI unit only)
С	Pressure switch for vacuum	010-101	_	•	•
D	swi		_	•	None (SI unit only)
E	ure /act		•	_	•
F	essi.	9 –100 to 100	•	_	None (SI unit only)
Н	P	-100 to 100	_	•	•
J	1		_	•	None (SI unit only)
Р	Pressure	Pressure 0 to -101			output 1 to 5 V
Т	sensor	-100 to 100	Analog output 1 to 5 V		
N	Without p	pressure switch for vacuum/pressure sensor			

*3 The unit selection function is not available in Japan due to the New Measurement Law. The unit for the type without the unit selection function is fixed as kPa.

Vacuum (V) port

Symbol	Vacuum (V) port
06	ø6
08	ø8

2 Nominal nozzle size

Symbol	Nominal nozzle size
07	ø0.7
10	ø1.0
12	ø1.2
15	ø1.5

Refer to the ZK2

A series
catalog for the standard
supply pressure per nozzle
diameter.

Combination of supply valve and release valve

Symbol	Supply	Release valve	
Syllibol	N.C.	N.C. Self-holding	
K	•	_	•
J	•	_	_
R	_	●*2	•

*2 Supply valve maintains vacuum by energization (20 ms or more). Stopping the vacuum turns on the release valve.

4 Rated voltage

(Supply valve/Release valve)

Symbol	Voltage
5	24 VDC

6 Connector

(Supply valve/Release valve/Pressure switch for vacuum)

Symbol	For supply valve/ release valve	For pressure switch for vacuum:	Pressure sensor assembly: 3 m	Note
Symbol	Centralized wiring specification (Plug-in)	2 m (Lead wire with connector)	(With lead wire)	Note
С	•	•		Cannot be selected when 5 is N
C1	•	None		Cannot be selected when 6 is P or T

Option*4 (For details on the Function/Application, refer to page 142.)

<u> </u>	ption*4	(For details on the	e Function/Application, refer	to page 142.)
Symbol		Ty	Note	
Nil	Without o	ption		_
E	reak flow needle	Screwdriver operation type long lock nut	Screwdriver operation type long lock nut	Cannot be selected when 3
J	/acuum break flow adjusting needle	Round lock nut	Lock nut	is J Can be selected only for the
K	Vacu adju	Screwdriver operation type	Vacuum break flow adjusting needle	combination of J and K
L		individual pecification*5	Individual supply port	_
Р		nifold common rele supply (PD) port	Cannot be selected when 3 is J	
w	With exhi	aust interference on valve	Exhaust interference prevention valve	When J is selected for §, install the release valve or vacuum breaker in the middle of the vacuum piping

- *4 When more than one option is selected, list the option symbols in alphabetical order. (Example -EL)
- S When F or H is selected for
 and L is selected for the option, the space for adjusting the needle is reduced. Products which can be operated more easily can be specified by option E or K.

JSY3000 Series

Type 10/Side Ported


Dimensions: JSY3000 Series

Vacuum Unit ZK2 Combination Manifold

JJ5SY3-10□- Stations D-M

For details on ejectors, refer to the Web Catalog.

* ZZK2 Stations A-A 2 S0-□



- * Refer to page 146 for dimensions of external nilot and built-in silencer
- * Refer to pages 90, 91, and 102 for dimensions when L6 and b are used for the calculation formula.
- * Refer to the reference pages shown in the table to the right for dimensions that are not specified in each wiring specification.

Calculation formula for dimensions

L1 = 11.5 x n1 + 15 x n2 + a + b x n3 + e

L2 = 11.5 x n1 + 15 x n2 + e + 93.7

M = (L1 + c)/12.5 + 1 Decimal fractions are truncated. L3 = 12.5 x M + 23

L4 = L3 - 10.5

1.5 = (1.3 - 1.1 + c)/2

 $L6 = b \times n3 + 82$

L7 = 15 x n2 + 41.5

- n1: Number of valve stations of the JSY3000
- n2: Number of ejector stations of the ZK2A
- n3: Number of I/O units or input block stations


	Coefficient		Reference	
	а	b	С	page
D-sub connector (IP40/Connector entry direction adjustable)	120.4	_	6.1	46
D-sub connector (IP67)	135.2	_	4.5	48
D-sub connector (IP20/Compact type)	133.4	_	6.1	52
Flat ribbon cable (IP40/Connector entry direction adjustable)	120.4	_	6.1	55
Flat ribbon cable (IP20/Compact type)	114.9	_	11.2	59
Spring type terminal block box	172.7	_	_	68
Terminal block box	194	_	_	72
Lead wire	141.7	_	_	80
Serial transmission: EX600 (M12 connector)	186.2	47	_	90
Serial transmission: EX600 (7/8 inch connector)	202.7	47		91
Serial transmission: EX245	217.8	54	_	96
Serial transmission: EX250	186.2	21	_	102
Serial transmission: EX260	133.4	_	_	110
Serial transmission: EX120	138.5	_	_	116

Coefficient	е
D side entry	_
U side/Both sides entry	23


Dimensions

For details on ejectors, refer to the Web Catalog.


With pressure sensor




With pressure switch




For port exhaust



PS and PD port dimensions



For the screwdriver operation type long lock nut



For high-noise reduction silencer exhaust



- *1 The common pilot pressure supply (PS) port is only available when manifold option "L" (manifold individual supply specification) is selected.
- *2 The common supply (PD) port is only available when manifold option "D" is selected.

JSY3000 Series

Type 10/Side Ported


External Pilot, Built-in Silencer

Dimensions: JSY3000 Series


Vacuum Unit ZK2 Combination Manifold

JJ5SY3-10□- Stations U(S, R)-M

* ZZK2 Stations A-A 2 S0-




* These figures show the JJ5SY3-10F2-05DR-C8-M * ZZK204A-A1S0



JSY3000 Series ZK2 Combination Manifold Exploded View

Manifold Exploded View



^{*} For details on the ZK2 ejector unit and replacement parts for the manifold, refer to the ZK2□A series catalog.


For the JJ5SY3-10-M (ZZK2□A)

Manifold end plate assembly

The assembly number includes end plate D, end plate U, and a tension bolt assembly.

ZZK2	S0	- <u>A</u>
Refer to page 142 for	the manifold part number.	Manifold end plate assembly

No.	Description	ZK2	Note
10	Clamp bracket	ZK2-DA5-A	2 pcs. per set
11)	DIN rail mounting spacer	ZK2-EU3-A	






JSY3000 Series

Manifold Parts Nos.

© End block assembly

JSY31M-3P-2A





End block assembly accessories and the number of accessories

and the number of decessiones					
Quantity					
1 pc.					
2 pcs.					
2 sets					
2 pcs.					
1 pc.					

* Gasket is mounted.







Intermediate SUP/EXH block assembly accessories and the number of accessories

Accessories	Quantity
Tie-rod for additional stations	3 pcs.
A-③ Manifold block gasket	1 pc.

^{*} Gasket is mounted.

® Clamp bracket

Series	Part no.	
JSY3000	SY30M-15-1A	


⚠ Caution


- Be sure to shut off the power and air supplies before disassembly.
 - Furthermore, since air may remain inside the actuator, piping and manifold, confirm that the air is completely exhausted before performing any work.
- When disassembly and assembly are performed, air leakage may result if the tightening of the cover and port block assemblies are inadequate.




JSY3000 Series ZK2□A Vacuum Ejector Manifold Exploded View

How to Increase Manifold Stations







[To increase the number of stations from an odd number (1, 3, 5, 7) to an even number (2, 4, 6, 8)] (Odd numbered stations have a vacant lead wire for one station, so additional orders are not required.)

- 1) Remove the tension bolt.
- 2) Remove end plate U.
- Remove the valve assembly from the single unit for manifold to be added.
- Remove the switch assembly if there is one. (Be careful not to drop the O-ring. Refer to Fig. 1.)

 Remove the switch assembly if there is one. (Be careful not to drop the O-ring. Refer to Fig. 1.)

 Remove the switch assembly if there is one. (Be careful not to drop the O-ring.)
- Remove junction box B (top) using a precision screwdriver. (Refer to Fig. 2.)
- Mount the extra connector to junction box B. (Refer to Fig. 3.) (Engage the recess of the connector and the protruding part of junction box B. Refer to Fig. 3-A.)
- Mount the single unit for manifold to be added to the end surface on the U side.
- 8) Mount end plate U with tension bolts of the appropriate length for the number of stations required. (Tightening torque: 0.75 N·m)
- 9) Mount junction box B to junction box A.
- 10) Mount the valve assembly. (Tightening torque: 0.15 N·m)
- For products with a switch, mount the switch assembly. (Be careful not to drop the O-ring. Tightening torque: 0.08 to 0.10 N·m)

[To increase the number of stations from an even number to an odd number or to increase by 2 stations or more]

- Remove the valve assemblies from all stations. (Remove from the single units to be added also.)
- Remove the switch assemblies if there are any. (Be careful not to drop the O-rings. Refer to Fig. 1.)
- Remove junction box B (top) from all stations using a precision screwdriver. (Refer to Fig. 2.) (Remove each junction box B from the D side.)
- Remove all connectors mounted to each junction box B. (Be careful not to break the connector clips.)
- 5) Remove the tension bolts.
- Bemove the end plate D assembly.
- Remove the linkage-printed circuit board, and then remove the connector assembly. (Refer to Fig. 4.)
- 8) Connect the lead wire assembly. (Refer to Fig. 5.)
- Remount the connector assembly and linkage-printed circuit board. (Refer to [19, 4].)
- 10) Remove end plate U. (Be careful not to drop the gasket.)
- 11) Mount the single units for manifold to be added to the end surface on the U side. (Do not let the gasket get caught.)
- Mount end plates U and D with tension bolts of the appropriate length for the number of stations required. (Tightening torque: 0.75 N·m)
- Mount the connectors for all stations to each junction box B. (Refer to Fig. 3.) (Engage the recess of the connector and the protruding part of junction box B. Refer to Fig. 3-A.)
- 14) Mount each junction box B to each junction box A. Push the wires down and mount each junction box B to each junction box A starting with the connector station numbers on the U side. (Refer to Fig. 6) (Do not let the lead wire get caught.)
- 15) Mount the valve assemblies. (Tightening torque: 0.15 N·m)
- 16) For products with a switch, mount the switch assemblies. (Be careful not to drop the O-rings. Tightening torque: 0.08 to 0.10 N·m)

12 Lead wire assembly

ZK2-CHS 04-A

Applicable stations

03	For 3-station manifold
:	:
nα	For 8-station manifold

COM. (Red)

How to Increase Manifold Stations: Vacuum Ejector Manifold for JSY3000

Connect the lead wire assembly to the positions shown in the diagram below.

2) Do not pull the lead wire forcefully when connecting. Also, take care that lead wires do not get caught between manifolds when mounting end plates U and D.


Wiring

Procedure) A station number is indicated on the connector of the lead wire assembly. Refer to the pin arrangement and insert the pins starting with black and then alternating between white and black from the top for the supply valves and the release valves. Also, starting from the bottom, insert the pins according to the corresponding station number for the common. Supply valve (Black) indication Pin arrangement Terminal Lead wire color COM. 2 Station 1: Black, Supply valve Black (Red) 2 ---- Station 1: White, Release valve Station 1 Station 2: Black, Supply valve ---- 3 2 White 4 ---- Station 2: White. Release valve Station 3: Black, Supply valve ---- 5 Black Release valve 6 ---- Station 3: White, Release valve (White) Station 4: Black, Supply valve --- 7 White 8 ---- Station 4: White Release valve Station 5: Black, Supply valve ---- 9 5 Black 10 ---- Station 5: White, Release valve Station 3 Release valve Station 6: Black, Supply valve ---- 11 6 White 12 ---- Station 6: White Release valve Supply valve Station 7: Black, Supply valve ---- 13 Black 14 ---- Station 7: White, Release valve Station 4 Release valve Station 8: Black, Supply valve --- 15 White 16 ---- Station 8: White, Release valve Supply valve 17 9 Black 18 Release valve 19 10 White Supply valve 20 21 11 Black 22 Release valve 23 12 White 24 Supply valve (Unused) 25 (Unused) 13 Black 26 Release valve 27 14 White Supply valve 28 29 15 Black 30 Protruding 31 White 32 33 34 ---- Red (COM.) COM Red (COM.) ----35 36 --- Red (COM.) COM. Red (COM.) ---- 37 35 Red 38 ---- Red (COM.) Red (COM.) ---- 39 ┰ 40 ---- Red (COM.) сом. Red (COM.) ---- 41 Red

40

JSY1000/3000/5000 series
One-touch Fittings, Plug, Clip,
Port Plate, Tube Releasing Tool

Refer to "How to Replace One-touch Fittings" on page 160 for the replacement method.



1) One-touch Fittings

© one touch i tunge						
	Series	JSY ⁻	1000	JSY3000	JSY5000	Note
Port size		6.5 mm pitch	9 mm pitch	3313000	0515000	Note
	ø2	KQSY10-C2	_	_	_	
	ø4	KQSY10-C4-X1336	_	KQSY30-C4	_	
A D north	ø6	_	KQSY11-C6	KQSY30-C6	KQSY50-C6	
A, B port	ø8	-	_	KQSY30-C8	KQSY50-C8	L
	ø10	_	-	_	KQSY50-C10	The part number is for 1 piece. (Sales unit: 10 pcs.)
	ø12	-	-	_	KQSY50-C12-X1336	(Sales unit. 10 pcs.)
	ø8	KQSY	30-C8	_	_	
P, E port	ø10	_	-	KQSY31-C10-X1336	_	
	ø12	-	-	_	KQSY50-C12-X1336	

^{*} Refer to page 160 for assembling when a fitting is replaced.

2 Plug

Pip	Series ing port	JSY1000	JSY3000	JSY5000	Note
	P, E port	JSY11M-62P-1A	JSY31M-62P-1A	JSY51M-62P-1A	The part number is for 1 piece.

^{*} A, B port plug does not exist. Use the KQ2P series.

(3) Clip, Port Plate


Series	JSY1000				
Piping port	For A, B port C2/C4 fittings	For A, B port C6 fittings	JSY3000	JSY5000	Note
A, B port (Clip)	SJ1000-CL-1	JSY11M-19P-1A	JSY31M-19P-1A	JSY51M-19P-1A	The part number is for 10 pieces.
P, E port (Port plate)	JSY11M-10P-1		JSY31M-10P-1	JSY51M-10P-1	The part number is for 1 piece.

^{*} Refer to page 160 for assembling when a fitting is replaced.

■ Tube Releasing Tool (This tool can be used to remove tubes from ports A and B.)

			•	•
Series	TG-0204	TG-0608	TG-1012	
Applicable tubing O.D.	ø2/ø4	ø6/ø8	ø10/ø12	






JSY1000/3000/5000 Series Manifold Options

■ DIN rail dimensions/weight for the JSY1000/3000 Plug-in connector connecting base VZ1000-11-1-□


* After confirming the L3 dimension in the dimensions table of each series, refer to the DIN rail dimensions table below and specify the number in the box □.



No.	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
L dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5	323
Weight [g]	17.6	19.9	22.1	24.4	26.6	28.9	31.1	33.4	35.6	37.9	40.1	42.4	44.6	46.9	49.1	51.4	53.6	55.9	58.1
No.	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
L dimension	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5
Weight [g]	60.4	62.5	64.9	67.1	69.4	71.6	73.9	76.1	78.4	80.6	82.9	85.1	87.4	89.6	91.9	94.1	96.4	98.6	100.9
No.	38	39	40	41	42	43	44	45	46	47	40	40	=0				54		56
INO.	30	39	40	41	42	43	44	45	40	47	48	49	50	51	52	53	54	55	56
L dimension	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798
	573													-					
L dimension	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798
L dimension Weight [g] No.	573 103.1 57	585.5 105.4	598 107.6	610.5 109.9	623 112.1	635.5 114.4	648 116.6	660.5 118.9	673 121.1	685.5 123.4	698 125.6	710.5 127.9	723 130.1	735.5 132.4	748 134.6	760.5	773	785.5	798

■DIN rail dimensions/weight for the JSY5000 Plug-in connector connecting base VZ1000-11-4-□

* After confirming the L3 dimension in the dimensions table of each series, refer to the DIN rail dimensions table below and specify the number in the box \Box .



No.	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
L dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5	273	285.5	298	310.5	323
Weight [g]	24.8	28	31.1	34.3	37.4	40.6	43.8	46.9	50.1	53.3	56.4	59.6	62.7	65.9	69.1	72.2	75.4	78.6	81.7
No.	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
L dimension	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5	523	535.5	548	560.5
Weight [g]	84.9	88	91.2	94.4	97.5	100.7	103.9	107	110.2	113.3	116.5	119.7	122.8	126	129.2	132.3	135.5	138.6	141.8
No.	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56
No. L dimension	38 573	39 585.5	40 598	41 610.5	42 623	43 635.5	44 648	45 660.5	46 673	47 685.5	48 698	49 710.5	50 723	51 735.5	52 748	53 760.5	54 773	55 785.5	56 798
	573		_		623			_						-	_			785.5	
L dimension	573	585.5	598	610.5	623	635.5	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773	785.5	798
L dimension Weight [g] No.	573 145	585.5 148.1	598 151.3	610.5 154.5	623 157.6	635.5 160.8	648 163.9	660.5 167.1	673 170.3	685.5 173.4	698 176.6	710.5 179.8	723 182.9	735.5 186.1	748 189.2	760.5	773	785.5	798



Manifold Options JSY1000/3000/5000 Series

↑ Caution Tightening torque for mounting screw M1.4: 0.06 N·m (JSY1000)

M2: 0.16 N·m (JSY3000) M3: 0.8 N·m (JSY5000)

Manifold Options

Refer to page 155 for dimensions.


■Blanking plate


[With two mounting screws]

Used when valve additions are expected or for maintenance











■ Individual SUP spacer

[With a connector gasket, a base gasket, and two mounting screws] When the same manifold is to be used for different pressures, an

individual SUP spacer assembly can be used to act as a supply port for different pressures.






	I	Port size (One-touch	fittings) 🖢
Symbol	P, E port	JSY1000	JSY3000	JSY5000
C4	ø4 One-touch fitting	•	_	_
C6	ø6 One-touch fitting	_	•	_
C8	ø8 One-touch fitting	_	_	•
C10	ø10 One-touch fitting	_	_	•
C12	ø12 One-touch fitting	_	_	•

■Individual EXH spacer

[With a connector gasket, a base gasket, and two mounting screws] When valve exhaust affects other stations due to the circuit configuration, this spacer can be used for individual valve exhaust.



Caution


Tightening torque for mounting screw M1.4: 0.06 N·m (JSY1000)

Manifold Options

* Refer to page 155-1 for dimensions.

■ SUP stop valve spacer with residual pressure release valve [With a base gasket and two mounting screws]

It is used to shut off the supply air to valves individually.



[How to mount SUP stop valve spacer with residual pressure release valve] Mount the plug-in spacer to the manifold block.

Insert the SUP stop valve mounting screw into the spacer screw hole, and mount it to the manifold block.

Tighten the SUP stop valve mounting screw to the specified tightening torque. Mount the valve and tighten the valve mounting screws to the specified tightening torque after mounting the SUP stop valve spacer with residual pressure release valve.

- * Be aware that the square nut may come off. If the square nut comes off, attach it to the spacer as shown in the drawing.
- * Tightening with a hexagon wrench is possible with the square nut attached.
- This product is only for internal pilot specifications, as the external pilot air cannot be shut off.
- If the product is equipped with a 3-position closed center, residual pressure cannot be released, so use in combination with a 3-port valve, which can be connected to the 4(A), 2(B) piping port.
- * Note that other spacer combinations are not possible.

JSY11M-50P-1A

Manual	Push-turn locking
override	slotted type

If you want to lock the manual override, push it down until it stops, and then turn it 90° clockwise. Be careful to avoid turning it without pushing it all the way down as this may result in spacer damage, air leakage, or another form of malfunction.

* Only compatible when the JSY1000 series 4(A), 2(B) ports are port size C6

To release the manual override, turn it counterclockwise. When turning the manual override, do not apply more torque than necessary. (0.1 N·m)



Circuit diagram

(Mounting example of a 2-position single valve)

Valve mounting screw (Refer to page 137.)

Hexagon wrench
Nominal wrench size: 0.9

SUP stop valve spacer with residual pressure release valve

Square nut

JSY11M-57P-1A (20 pcs. included)

SUP stop valve mounting screw

Z2-SR1-A (10 pcs. included)

Manifold block

Plug-in spacer

SUP stop valve accessory

	Port	size	Flow rate characteristics				
Model	1, 3/5	4, 2	1 → 4/2(P →	A/B)	4/2 → 3/5(A/E	3 → E)	
	(P, E)	(A, B)	C [dm3/(s-bar)]	b	C [dm3/(s-bar)]	b	
JSY11M-50P-1A	C8	C6	0.65	0.21	0.86	0.36	

nting screw (For repairs)

JSY1000: Z2-SR1-A (10 pcs.)

- * Calculation of effective area S and sonic conductance C: S = 5.0 x C
- * The value is for manifold base with 5 stations and individually operated 2-position type.
- * For connector connecting base (type 10) manifolds



Manifold Options

■SUP/EXH blocking disk

[SUP blocking disk]

Inserting an SUP blocking disk in the pressure supply passage of a manifold valve can allow for the use of 2 different pressures (high and low) in 1 manifold.

[EXH blocking disk]

Inserting an EXH blocking disk in the exhaust passage of a manifold valve can separate the exhaust from the valve so it does not affect the other valves. It can also be used in positive pressure and vacuum pressure mixed manifolds. (2 pieces are required to block both the EA and EB sides of the EXH.)



Series	SUP blocking disk	EXH blocking disk
JSY1000	JSY11M-40P-1A	JSY11M-40P-1A
JSY3000	JSY31M-40P-1A	JSY31M-40P-2A
JSY5000	JSY51M-40P-1A	JSY51M-40P-1A

* If the blocking disk is ordered using the

■Labels for blocking disks

These labels can be used to indicate and confirm where on the manifold the SUP/EXH blocking disk assemblies were inserted. (3 labels of each)

SUP/EXH blocking disk label





manifold specification sheet and ordered at the same time as the manifold, the position where the blocking disk is inserted will be labeled and shipped out.


Series	Part no.
JSY1000	
JSY3000	SJ3000-155-1A
JSY5000	

■ Silencer

(One-touch fitting connection type)

This silencer can be mounted to the 3/5 (E: EXH) port of the manifold in one step.

* Shipped together with the product




Series (ø d)	Model	Effective area	Α	В	С
For JSY1000 (ø8)	AN15-C08	20 mm ²	45	13	20
For JSY3000 (ø10)	AN20-C10	30 mm ²	57.5	16.5	30.5
For JSY5000 (ø12)	AN30-C12	41 mm ²	71.5	20	43.5

Manifold Options JSY1000/3000/5000 Series

Dimensions: Manifold Options


■ Blanking plate

JSY1000 series







JSY3000 series






JSY5000 series







■ Individual SUP/EXH spacer


JSY1000 series







JSY3000 series





JSY5000 series







Dimensions: Manifold Options

■SUP stop valve spacer with residual pressure release valve

* Only compatible when the JSY1000 series 4(A), 2(B) ports are port size C6



SUP stop valve spacer with residual pressure release valve





Made to Order





1 External pilot

How to Order Manifolds

Refer to the How to Order manifolds for each type.

The combination of external pilot type "R" and silencer type "S" is not available.

* Only the JSY3000/5000 can be selected for the EX245.

For EX600/EX250 pp. 84, 98, 140

P. E port entry, SUP/EXH block assembly

P, E port entry	External pilot
U side (2 to 10 stations)	G
D side (2 to 10 stations)	Н
Both sides (2 to 24 stations)	J

How to Order Valves

- * Only the JSY3000 can be selected for the 4-position dual 3-port valve external pilot specification.
- * When pilot type "R" is selected, select the external pilot type "R" for the manifold SUP/EXH block assembly, and select either of "G/H/J" for the EX600/EX250 manifold.



JSY1000/3000/5000 Series Specific Product Precautions 1

Be sure to read this before handling the products. For safety instructions and 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Environment

.↑.Warning

- Do not use valves in atmospheres of corrosive gases, chemicals, sea water, water, water vapor, or where there is direct contact with any of these.
- Products compliant with IP67 enclosures (based on IEC 60529) are protected against dust and water, however, these products cannot be used in water. If using in an environment that is exposed to water and dust splashes, take measures such as using a protective cover.
- When using built-in silencer type manifold with an IP67 enclosure, keep the exhaust port of the silencer from coming into direct contact with water or other liquids.

Valve Mounting

⚠ Caution

Mount it so that there is no slippage or deformation in gaskets, and tighten with the tightening torque as shown on the right.

Series	Thread size	Tightening torque
JSY1000	M1.4	0.06 N·m
JSY3000	M2	0.16 N·m
JSY5000	M3	0.8 N·m

Manual Override

.⚠Warning

Manual override is used to switch the main valve without inputting an electrical signal for the valve. When manual operation is performed, the connected actuator will start operating, so be sure to confirm that it is safe to operate beforehand.

■ Non-locking push type


Push down on the manual override button until it stops.



■ Push-turn locking slotted type [D type]

Push down on the manual override with a small flat head screwdriver until it stops, and then turn it 90° clockwise. The manual override is then locked. To release it, turn it counterclockwise.

If it is not turned, it can be operated the same way as the non-locking push type.




Manual Override

⚠ Warning

■ Push-turn locking lever type [E type] (Only for the JSY3000/5000)

Push down on the manual override by finger until it stops, and then turn it 60° clockwise. The manual override is then locked. To release it, turn it counterclockwise. If it is not turned, it can be operated the same way as the non-locking push type.



Carefully check the manual override projection amount.
Max. (at OFF): 3.7 mm

⚠ Caution

Do not apply excessive torque when turning the manual override. [0.1 N·m]

When locking the manual override, be sure to push it down before turning. Turning without first pushing it down can cause damage to the manual override and other trouble such as air leakage, etc.

Used as a 3-Port Valve

⚠ Caution

■ In case of using a 5-port valve as a 3-port valve

The JSY1000/3000/5000 series can be used as normally closed (N.C.) or normally open (N.O.) 3-port port valves by closing one of the cylinder ports 4(A) or 2(B) with a plug. However, they should be used with the exhaust ports kept open. Use them when a double solenoid type 3-port valve is required.

Plu	g position	B port	A port
Type	of actuation	N.C.	N.O.
Number of solenoids	Single	(A)4 2(B) (EA)5 1 3(EB)	(A)4 2(B)
Number of	Double	(A)4 2(B) (EA)5 1 3(EB) (P)	(A)4 2(B) (EA)5 1 3(EB) (P)



JSY1000/3000/5000 Series Specific Product Precautions 2

Be sure to read this before handling the products. For safety instructions and 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Light/Surge Voltage Suppressor


⚠ Caution

■ Polar type

Positive common

Single solenoid

Light/surge voltage suppressor (□Z)



Negative common Single solenoid

Light/surge voltage suppressor (□NZ)


Polarity protection diode



Positive common


Double solenoid, 3-position, 4-position

Light/surge voltage suppressor (□Z)



Negative common

Double solenoid, 3-position, 4-position



■ Non-polar type

With light/surge voltage suppressor (□U)

COM (+,-) Varistor SOL.a

Single solenoid


Double solenoid



* Non-polar type is not available for the JSY1000.


■ With power-saving circuit

Power consumption is decreased to approx. 1/2.5 to 1/4 of the amount consumed at startup by reducing the wattage required to hold the valve in an energized state. (Effective energizing time is over 67 ms at 24 VDC.)



The circuit shown to the left reduces the power consumption for holding in order to save energy. Refer to the electrical power waveform as shown below.

<Electrical power waveform with power-saving circuit>



 Since the voltage will drop by approx. 0.5 V due to the transistor, pay attention to the allowable voltage fluctuation. (For details, refer to the solenoid specifications of each type of valve.)

Residual voltage of the surge voltage suppressor

If a varistor or diode surge voltage suppressor is used, there is some residual voltage to the protection element and rated voltage. Therefore, refer to the table below and pay attention to the surge voltage protection on the controller side. Also, since the response time does change, refer to the valve specifications on page 35.

Residual Voltage

	Surge voltage suppressor	24 VDC
1	Z	Approx. 1 V
	U	Approx. 47 V

Continuous Duty

↑ Caution

If a valve is energized continuously for long periods of time, the rise in temperature due to heat-up of the coil assembly may cause a decline in solenoid valve performance, reduce service life, or have adverse effects on peripheral equipment. If the valve is energized continuously for long periods of time, be sure to use a valve with power-saving circuit. In particular, if three or more adjacent stations on the manifold are energized simultaneously for extended periods of time or if the valves on A side and B side are energized simultaneously for long periods of time, take special care as the temperature rise will be greater.

Energization of a 2-Position Double Solenoid Valve

⚠ Caution

To avoid operation failure, do not energize the A side and B side of 2-position double solenoid valve at the same time.



JSY1000/3000/5000 Series Specific Product Precautions 3

Be sure to read this before handling the products. For safety instructions and 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Countermeasure for Surge Voltage Intrusion

∕ Caution

■ Surge voltage intrusion

With non-polar type valves, at times of sudden interruption of the loading power supply, such as emergency shutdown, surge voltage intrusion may be generated from loading equipment with a large capacity (power consumption), and the valve in a de-energized state may switch over (see Figure 1). When installing a breaker circuit for the loading power supply, consider using a valve with polarity (with polarity protection diode), or install a surge absorption diode between the loading equipment COM line and the output equipment COM line (see Figure 2).




Figure 1. Surge intrusion circuit example (NPN outlet example) (24 VDC)




Figure 2. Surge intrusion countermeasure example (NPN outlet example) (24 VDC)


Light Indication

⚠ Caution

When equipped with indicator light and surge voltage suppressor, the light window turns orange when solenoid a is energized, and it turns green when solenoid b is energized.

<JSY1000 series>

<JSY3000/5000 series>




Changing Connector Entry Direction

⚠ Caution

Connector direction for electrical entry of D-sub connector and flat ribbon cable <|P40> can be changed. If the directional change is required, slide the lever on the side of the connector block to the FREE position, and then change the direction as shown in the figure. Also, before connecting the connector, be sure to return the lever to the LOCK position. (If the lever is difficult to slide, move the connector a little bit to make it easier to slide the lever.)

If an excessive force is applied on the connector in the LOCK position, the connector block may be damaged. Also, using in such a way that the connector floats in the FREE position, it may cause the lead wire, etc., to break.

 Direction cannot be changed for D-sub connector <IP67> or compact type.



UL Approved Product

. Caution

When conformity to UL is required, the product should be used with a UL1310 Class 2 power supply.

The product is a UL approved product only if it has a call mark on the body.





JSY1000/3000/5000 Series Specific Product Precautions 4


Be sure to read this before handling the products. For safety instructions and 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Manifold Indication Symbol

▲ Caution

The letter "[S]" is indicated on manifold blocks for the JSY series as shown below. This indication refers to the type of substrate (single wiring) inside the manifold blocks. When there is no symbol, double wiring is used.

When the manifold specification sheet does not include a wiring specification, all stations will be double wiring specification. In this case, single and double solenoid valves can be mounted in any position, but when a single valve is used, there will be an unused control signal. To avoid this, indicate positions of manifold blocks for single wiring specification and double wiring specification on a manifold specification sheet. (Note that double, 3- or 4-position valves cannot be used for manifolds blocks with single wiring specification [S].)



Substrate inside Manifolds

↑ Caution

The substrate inside of manifolds cannot be taken apart. Attempting to do so may damage parts.

Securing the DIN Rail Mounting Type Manifold

⚠ Caution

- 1. When the manifold is secured with bolts on a mounting surface, etc., it can be operated just by securing both ends of the DIN rail if the bottom surface of the DIN rail is entirely in contact with the mounting surface when mounted horizontally. However, if it is used with other mounting or with side or reverse mounting, secure the DIN rail with bolts at regular intervals. As a guide, insert bolts in 2 locations for 2-5 stations, 3 locations for 6-10 stations, 4 locations for 11-15 stations, 5 locations for 16-20 stations, and 6 locations for 21-24 stations.
- 2. When using the manifold with DIN rail in an environment where any vibration or impact is applied to it, the DIN rail itself may be broken. In particular, if the installation surface vibrates when mounting the manifold on the wall or if a load is directly applied to the manifold, the DIN rail may be broken, causing the manifold to drop. When any vibration, impact, or load is applied to the manifold, be sure to use the direct mounting manifold.


How to Replace One-touch Fittings

⚠ Caution

By replacing One-touch fittings of manifold base, it is possible to change the connection diameter of the 4(A), 2(B), 1(P), 3/5(E) ports. When replacing the One-touch fittings, remove the clip or the plate before pulling the One-touch fittings off. Mount the One-touch fittings by following the removal procedure in reverse. Use caution as it may cause air leakage if the clip and the plate are not inserted securely enough when they are switched. Refer to page

■ Connector connecting base

151 for part numbers of One-touch fittings.



- block assembly needs to be replaced Please select the manifold block assembly on page 137. * Refer to page 151 for One-touch
- fitting, clip, and port plate part numbers.

<Assembly method>

· SUP/EXH (end) block

Fitting direction is specified when the fittings below are used. Assemble the fitting so that the D-cut surfaces of the fitting face <u>up and down</u>.

Fitting part no.: KQSY50-C12-X1336 (JSY5000)

Manifold block

Assemble the fitting so that the D-cut surfaces of the fitting face sideways.

Fitting part no.: KQSY10-C4-X1336 (JSY1000) KQSY50-C12-X1336 (JSY5000)



JSY1000/3000/5000 Series Specific Product Precautions 5

Be sure to read this before handling the products. For safety instructions and 3/4/5-port solenoid valve precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Other Tube Brands

** ⚠** Caution

 When using other than SMC brand tube, confirm that the following specifications are satisfied with respect to the tube outside diameter tolerance.

Nylon tube
 Soft nylon tube

within ±0.1 mm within ±0.1 mm

2) Soft nylon tube3) Polyurethane tube

within +0.15 mm within -0.2 mm

Do not use tube which do not meet these outside diameter tolerances. It may not be possible to connect them, or they may cause other trouble, such as air leakage or the tube pulling out after connection.

One-touch Fittings

∧ Caution

■ Tube attachment/detachment for One-touch fittings

1) Tube attachment

- 1. Take a tube having no flaws on its periphery and cut it off at a right angle. When cutting the tube, use tube cutters TK-1, 2, or 3. Do not use pliers, nippers, scissors, etc. If cutting is done with tools other than tube cutters, the tube may be cut diagonally or become flattened, etc., making a secure installation impossible, and causing problems such as the tube pulling out after installation or air leakage. Allow some extra length in the tube.
- Grasp the tube and push it in slowly, inserting it securely all the way into the fitting.
- 3. After inserting the tube, pull on it lightly to confirm that it will not come out. If it is not installed securely all the way into the fitting, this can cause problems such as air leakage or the tube pulling out.

2) Tube detachment

Use the release tool when the removal of tube is difficult due to the tube size. Refer to page 151 for releasing tools.

- Push in the release button sufficiently, pushing its collar equally around the circumference.
- 2. Pull out the tube while holding down the release button so that it does not come out. If the release button is not pressed down sufficiently, there will be increased bite on the tube and it will become more difficult to pull it out.
- 3. When the removed tube is to be used again, cut off the portion which has been chewed before reusing it. If the chewed portion of the tube is used as is, this can cause trouble such as air leakage or difficulty in removing the tube.

Fixing Method of JSY1000 Series Clamp Bracket


. Caution

The clamp bracket fixing method for the JSY1000 series is different depending on wiring.

■ Wiring

<For D-sub connector/Flat ribbon cable/Spring type terminal block box/Lead wire/EX260/EX120>

* When the DIN rail is not accommodated in the clamp bracket, loosen the DIN rail holding screw once and insert the DIN rail.




JSY11M-15P-1A

Clamp bracket holding screw

<For Terminal block box/EX600/EX250>

DIN rail holding screw Tightening torque (1.4 N·m)

 If the tightening torque of the holding screws is too much, the SUP/EXH end block will be broken.



Installation

∧ Caution

Even though the inlet pressure is within the operating pressure range, when the piping diameter is restricted due to size reduction of supply port (P), the flow will be insufficient. In this case, the valve does not switch completely and the cylinder may malfunction

■ Trademark

DeviceNet[®] is a registered trademark of ODVA, Inc. EtherNet/IP® is a registered trademark of ODVA, Inc. CompoNet[®] is a registered trademark of ODVA, Inc.







Manifold Option How to Order Spacer Type Ejector (With mounting screw



Optional specifications

E	Spacer type ejector

2 Body type

Symbol Body typ		Body type
1 Supply valve (N.C.)		
	2	Supply valve (N.O.)
	3	Supply valve (N.C.)/Release valve (N.C.)

Nominal nozzle size

07	ø0.7
10	ø1.0

4 Achievable vacuum pressure

S	-90 kPa
3	-90 KFa

Exhaust type

Symbol	Exhaust type	Element
Nil	Silencer	Without
Н	High-noise reduction silencer	With
C6	ø6 One-touch fitting	

6 Vacuum break flow adjusting unit

_					
Nil Without					
N	With (Only with body model "3" Release valve)				


Spacer Type Ejector is connection to both A port and B port. (See p. 161-4 circuit diagram). One of them can be connected to vacuum pad and the other to pressure switch without a branch piping to manifold. When only one of them is turned piping, be sure to turn plug the unused port.

* Refer to "Ejector Specifications" on page 161-2 for the max. number of ejector stations that can operate simultaneously.

The following solenoid is recommended for mounting of spacer type ejector.

Ejector Supply Valve/Release Valve

JSY1000 Series





Series

JSY1000

3 Pilot valve exhaust method Pilot valve individual exhaust

Rated voltage	
5	24 VDC

Type of actuation

Symbol	Туре	of actuation	Applicable spacer type ejector body type symbo
1	2-position	Single	1.2
2		Double	1, 2
3	3-position	Closed center	3

NZ

5 Ligh	t/surge voltage s	uppressor and co	ommon specification
Symbol	With light	Surge voltage suppressor	Common specification
7			Positive common


When SI unit is used Select a valve from Z when the SI Unit output polarity is positive common.

Negative common

Select a valve from NZ when the SI Unit output polarity is negative common.



6 Manual override



When ordering a valve individually, the base gasket is not included.

Since the base gasket is attached to the ejector, please order the base gasket separately if it is needed for maintenance. Refer to page 161-8 for base gasket and mounting screw part numbers.

Spacer Type Ejector

Ejector Specifications*1, *2

	Model	Standard supply	Standard supply Nominal pressure nozzle size [MPa] [mm]	Supply pressure range [MPa]	Achievable vacuum pressure [kPa]	Max. suction flow [L/min (ANR)]	Air consumption	Noise level* ^{3, *4} [dB (A)]	
					Type S	Type S			High-noise reduction silencer exhaust type
JSY11M-EP-□A-07S□ JSY11M-EP-□A-10S□	0.45	0.7	0.1 to 0.6	0.1 to 0.6	-90	11.5	27	68	58
	0.45	1.0		-90	21	52	80	65	

- *1 The values indicating characteristics are representative values and may vary depending on the atmospheric pressure (weather, altitude, etc.).
- *2 Value at supply pressure.
- *3 Actual values under SMC's measurement conditions (Not guaranteed values)
- *4 This is a value obtained with a single ejector performing vacuum suction in the silencer air discharge system.

Max. Number of Manifold Stations that Can Operate Simultaneously [units]

Model	Max. number of manifold stations that can operate simultaneously [units]*1, *2, *3		
Model	U or D side Air supply to one side	U and D side Air supply to both sides	
JSY11M-EP-□A-07S□	8	12	
JSY11M-EP-□A-10S□	2	4	

- *1 Value at supply pressure.
- *2 Actual values under SMC's measurement conditions (Not guaranteed values)
- *3 This is the maximum number of stations that can simultaneously operate when vacuum is simultaneously generated by the ejectors only (excluding the solenoid valve for actuator). When a solenoid valve for actuator and a spacer type ejector are mounted on the same manifold, simultaneously operating them may affect each other and degrade their performances. As a countermeasure against this problem, by using a single SUP spacer (mountable only on the solenoid valve for actuator) and a SUP blocking disk, separate air supply to those components (refer to pages 153 and 154).

Weight

		1	
Spacer type Ejector model	Exhaust type	Vacuum break flow adjusting unit	Weight [g]
JSY11M-EP-□A-□S	Silencer exhaust		16
JSY11M-EP-□A-□SC6	ø6 One-touch fitting	Without	20
JSY11M-EP-□A-□SH	High-noise reduction silencer exhaust		18
JSY11M-EP-□A-□S-N	Silencer exhaust	With	23
JSY11M-EP-□A-□SC6-N	ø6 One-touch fitting		27
JSY11M-EP-□A-□SH-N	High-noise reduction silencer exhaust		25

Solenoid Valve (Supply Valve/Release Valve) Flow Rate Characteristics


	Port	size	Valve flow rate characteristics				
Valve model	1, 3/5 (P, E)	4, 2 (A, B)	Passage	C [dm ³ /(s·bar)]	b		
JSY1100			$1 \rightarrow 4/2 \ (P \rightarrow A/B)$	0.96	0.30		
JSY1200	C8	C6	(0.91	0.48		
JSY1300	00	06		0.64	0.37		
3311300			4/2 → 3/5 (A/B → E)	0.66	0.46		


- * Calculation of effective area S and sonic conductance C: S = 5.0 x C
- * Values measured in accordance with ISO 6358:1989, JIS B 8390:2000
- * Characteristics in solenoid valve JSY1000 series single unit.

Exhaust Characteristics/Flow Rate Characteristics


(Exhaust characteristics: Supply pressure 0.45 MPa)


JSY11M-EP-□A-07S□-□







JSY11M-EP-□A-10S□-□






Release Flow Rate Characteristics The graph when vacuum release flow adusting needle is from fully closed to open in supply pressure 0.45 MPa.





It is the vacuum release flow rate from one of the two vacuum port (A, B port). The other is turned plug.


Construction



For the ø6 One-touch fitting exhaust type



For the high-noise reduction silencer exhaust type




oomponent raits						
No.	Description	Material				
1	Body	Resin				
2	Nozzle	Resin				
3	Diffuser	Resin				
4	Silencer	Resin				
5	Clip	Stainless steel				
6	Base gasket	HNBR				
7	Needle block	Resin				
8	Needle	Resin				
9	Knob	Resin				
10	Needle guide	Brass				
11	Lock pin	Stainless steel				
12	Plug-in spacer	Resin				
13	ø6 One-touch fitting	Stainless steel/Brass/ Resin/NBR/HNBR				
14	High-noise reduction silencer	Resin				
15	Sound absorbing material	Resin				
_	O-ring	NBR/HNBR				

Circuit Diagrams


* The valves in the above circuit diagram are examples.

3-position closed center Supply valve [N.C.] Supply valve [N.C.]




* The valves in the above circuit diagram are examples.

JSY11M-EP-3A-□S□-N



How to Order Manifold Assembly (When mixed manifold block range 6.5 mm/9 mm is used)



Spacer type ejector can only be mounted on 9 mm wide manifold block.
 If the layout is complicated or you want to specify a desired layout, please specify it by means of the manifold specification sheet.

Example of Manifold Specification Sheet Entry

		-	D sid	de	1	2	3	4	5	6	ſ	24	U side
model		(J) JSY1000 series			1	3					Ī		
Valve mo	Type of actuation	(K) Ejector Supply/Release valve					1	1	3				
(L) Internal pilot] \] [
	Spacer type ejector model	(N) Body type	1 \	ſ			1	1	3] [
_		(O) Nominal nozzle size] \	ſ			07	07	07		ſ		1 / 1
		(P) Exhaust type	1 \	ſ			C6						
		(Q) Vacuum break flow adjusting unit	1 \	ſ					N				1 / 1
d option	Blanking plate JSY11M-26P-1A		$ \ $										
Blanking plate JSY11M-26P-1A JSY11M-38P-1A-C4			'	\setminus]
-	- Omission -		1	1	- Omission -							1/	
	(G) A, B port size	A, B port		1	C4	C4	C6	C6	C6				1/
l l	Plug	A port		1							Ī		1
		B port							С				

Order procedure of the above order example indicates that vacuum port of spacer type ejector is either A or B port. When only one vacuum port is desired, manifold specification sheet must be used to specify plug. It shows the manifold specification sheet in which plug is specified on B port of the fifth station.




How to Order Manifold Assembly (For manifold block Width 9 mm only)

Example (JJ5SY1-10F1 -C6) Supply/Release valve: 3-position closed center valve Supply valve: 2-position single valve JSY1300T-5Z (1 set) JSY1100T-5Z (1 set) Spacer type ejector Supply valve [N.C.]/Release valve [N.C.]/ 3-position closed center valve Silencer exhaust With vacuum break flow adjusting unit JSY1300T-5Z (1 set) JSY11M-EP-3A-07S-N (1 set) 2-position double valve Spacer type ejector JSY1100T-5Z (1 set) Supply valve [N.C.]/Port exhaust JSY11M-EP-1A-07SC6 (1 set) Spacer type ejector Manifold base Supply valve [N.C.]/Silencer exhaust JJ5SY1-10F1-05D-C6 (1 set) JSY11M-EP-1A-07S (1 set)


JJ5SY1-10F1-05D-C61 set (Type10 5stations manifold base product number/manifold block wide 9 mm limited specifications)
* JSY1100T-5Z1 set (2-position single valve)
* JSY1300T-5Z1 set (3-position closed center valve)
* JSY1100T-5Z1 set (Supply valve: 2-position single valve)
* JSY11M-EP-1A-07SC61 set (Spacer type ejector: Supply valve [N.C.]/Port exhaust)
* JSY1100T-5Z1 set (Supply valve: 2-position single valve)
* JSY11M-EP-1A-07S1 set (Spacer type ejector: Supply valve [N.C.]/Silencer exhaust)
* JSY1300T-5Z1 set (Supply/Release valve: 3-position closed center valve)
* JSY11M-EP-3A-07S-N1 set (Spacer type ejector: Supply valve [N.C.]/Release valve [N.C.]/Silencer exhaust: With vacuum break flow adjusting unit)
→The asterisk denotes the symbol for the assembly.
* Prefix the product number of the mounted valve or spacer type elector with "*."

- · For the valve arrangement, the valves closest to the D side are considered the 1st stations respectively.
- Below the manifold part number, write down the valves and spacer type ejectors to be mounted in order from the first station as shown in the figure.
- · Write down spacer type ejectors next to the valves they are to be combined with.
- · Spacer type ejector can only be mounted on 9 mm wide manifold block.
- If the layout is complicated or you want to specify a desired layout, please specify it by means of the manifold specification sheet.

Dimensions: Spacer Type Ejector



Order parts for Spacer Type Ejector



No.	Description	Part no.	Note
1	Spacer type ejector mounting screw (M1.4 x 4.5)	Z2-SR1-A	10 pcs. (for 5 ejectors) Hexagon socket head cap screw (Hexagon width across flats: 0.9 mm)
2	Base gasket	JSY11M-9P-1A	10 pcs.
3	Silencer	Z2-SC1-A	The part number is for 1 piece.
4	One-touch fitting assembly (ø6)	KQSY11-C6	The part number is for 1 piece. (Sales unit: 10 pcs.)
(5)	High-noise reduction silencer	Z2-SC2-A	The part number is for 1 piece.
6	Clip	Z2-CL1-A	The part number is for 1 piece.
7	Valve mounting screw (M1.4 x 21.5)	JSY11V-23-1A	20 pcs. (for 10 valves)
8	Vacuum break flow adjusting unit	Z2-NU1-A	Plug-in spacer assembly, mounting screw (2 pcs.) included
9	Valve/Unit mounting screw (M1.4 x 31.5)	JSY11V-23-2A	2 pcs. (1 unit).



JSY1000 Series Spacer Type Ejector/Specific Product Precautions 1

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve and vacuum equipment precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Spacer Type Ejector

Design / Selection

.⚠Warning

1. Vacuum adsorption

At the time of vacuum adsorption, be sure to supply a constant supply of vacuum. Failure to do so may result in foreign matter sticking to the adsorption pad or air leakage, causing the workpiece to drop.

2. Ventilation

Provide ventilation when using a spacer type ejector in a confined area, such as in a closed control panel. For example, install a ventilation opening, etc., in order to prevent pressure from increasing inside of the confined area and to release the heat generated by the valve.

3. Mounting the suction filter

This product is not mounted with a suction filter. The vacuum ejector suctions surrounding dust and water droplets during suctioning of the workpiece. Therefore, it is necessary to avoid the entry of the dust and water droplets into the product. We recommend that you separately install a suction filter in the vacuum side piping. If water droplets or others could be suctioned, please consider installation of a drain separator for vacuum or the like.

4. Vacuum holding

Since valves are subject to air leakage, they cannot be used for applications such as holding vacuum in a pressure vessel. SMC can issue no guarantees regarding the maintenance of workpiece adsorption when using check valves. Take separate safety measures to prevent workpieces from dropping in the case of an electrical power outage, etc.

Exhaust / Exhaust Noise

∧Caution

1. Exhaust


The exhaust resistance should be as small as possible to obtain the full spacer type ejector performance. There should be no shield around the exhaust slit for silencer exhaust type.

Exhaust / Exhaust Noise

∴ Caution

2. Exhaust noise

When spacer type ejector generates vacuum, noise can be heard from the exhaust port when the standard supply pressure is close to the pressure that generates peak vacuum pressure making vacuum pressure unstable. If the vacuum pressure range is adequate for adsorption, there should not be a problem. If the noise causes a problem or affects the setting of the SI Unit, change the supply pressure slightly to avoid the pressure range of the noise.



3. Exhaust air

If solid substances are sucked in through the vacuum (A, B) port, they will be discharged from the exhaust port at a high speed if the exhaust (EXH) port is opened. Therefore, do not look into the exhaust port or direct the exhaust port toward a person when the spacer type ejector is operating.

How to Mount the Product

∧Caution

 Do not drop, hit, or apply excessive impact to the product when handling it.

Even if the body looks undamaged, the internal components may be damaged, leading to a malfunction.

2. Load to the body

The product body is made of resin; therefore, do not apply load to the port after mounting. Prevent any kind of operation which generates moment as this may cause reduced performance or damage to the body.





JSY1000 Series Spacer Type Ejector/Specific Product Precautions 2

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For 3/4/5-port solenoid valve and vacuum equipment precautions, refer to the "Handling Precautions for SMC Products" and the "Operation Manual" on the SMC website: https://www.smcworld.com

Spacer Type Ejector

Piping

∧Caution

When piping to the product, be careful not to confuse the vacuum port (A, B port) with the exhaust port of the spacer type ejector. Otherwise this can result in damage or reduced performance. Apply compressed air after confirming that the piping is connected correctly.

If each exhaust piping for the port exhaust ejectors are connected and made into centralized piping, the exhausted air will flow back into the exhaust path which is not operating, and will then be exhausted from the vacuum port. Exhaust individually.

Air Consumption

∧Caution

When the spacer type ejector is generating vacuum, air is consumed. Therefore, if the air supply capacity is insufficient, the supply pressure may drop. As a guide for sufficient air supply capacity, we recommend that you secure a supply capacity three times or more the air consumption of the ejector.

